MIL-H-19910C(YD)
16 April 1984
SUPERSEDING
MIL-H-19910B(YD)
18 August 1978

MILITARY SPECIFICATION

HEATERS, SPACE, ELECTRIC

This specification is approved for use by the Naval Facilities Engineering Command, Department of the Navy, and is available for use by all Departments and Agencies of the Department of Defense.

1. SCOPE

1.1 Scope. This specification covers horizontal, fan type, electric, alternating current (ac) space heaters.

1.2 Classification. The space heaters shall be of the following types and sizes, as specified (see 6.2.1):

Type I - Portable.

Size 1.5 - 1.5 kilowatt (kW).
Size 3 - 3 kW.
Size 5 - 5 kW.

Type II - Suspension.

Size 3 - 3 kW.
Size 5 - 5 kW.
Size 7.5 - 7.5 kW.
Size 10 - 10 kW.

2. APPLICABLE DOCUMENTS

2.1 Government documents.

2.1.1 Specifications, standards, and handbooks. Unless otherwise specified (see 6.2.1), the following specifications, standards, and handbooks of the issue listed in that issue of the Department of Defense Index of Specifications and Standards (DoDISS) specified in the solicitation, form a part of this specification to the extent specified herein.

Beneficial comments (recommendations, additions, deletions) and any pertinent data which may be of use in improving this document should be addressed to: Commanding Officer (Code 156), Naval Construction Battalion Center, Port Hueneme, CA 93043, by using the self-addressed Standardization Document Improvement Proposal (DD Form 1426) appearing at the end of this document or by letter.

FSC 4520

Source: https://assist.dla.mil -- Downloaded: 202610-19T06:53Z
Check the source to verify that this is the current version before use.

SPECIFICATIONS

FEDERAL

PPP-B-636 - Boxes, Shipping, Fiberboard.

MILITARY

MIL-P-116 - Preservation, Methods of.
MIL-V-173 - Varnish, Moisture and Fungus Resistant (for Treatment of Communications, Electronic, and Associated Equipment).
MIL-H-22577 - Heating Elements, Electrical, Cartridge, Straipp and Tubular Type.

STANDARDS

MILITARY

MIL-STD-105 - Sampling Procedures and Tables for Inspection by Attributes.
MIL-STD-129 - Marking for Shipment and Storage.
MIL-STD-147 - Palletized Unit Loads.
MIL-STD-461 - Electromagnetic Emission and Susceptibility Requirements for the Control of Electromagnetic Interference.
MIL-STD-462 - Electromagnetic Interference Characteristics, Measurement of.
MIL-STD-794 - Parts and Equipment, Procedures for Packaging and Packing of.

(Copies of specifications, standards, handbooks, drawings, and publications required by manufacturers in connection with specific acquisition functions should be obtained from the contracting activity or as directed by the contracting officer.)

2.2 Other publications. The following document(s) form a part of this specification to the extent specified herein. The issues of the documents which are indicated as DoD adopted shall be the issue listed in the current DoDISS and the supplement thereto, if applicable.

AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)

D - 3951 - Commercial Packaging, Standard Practice for.

(Application for copies should be addressed to the American Society for Testing and Materials, 1916 Race Street, Philadelphia, PA 19103.)

NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION (NEMA)

MG 1 - Motors and Generators.

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T06:53Z
Check the source to verify that this is the current version before use.

(Application for copies should be addressed to the National Electrical Manufacturers Association, 2101 L Street, N.W., Washington, DC 20037.)

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

No. 70 - National Electrical Code.

(Application for copies should be addressed to the National Fire Protection Association, Batterymarch Park, Quincy, MA 02269.)

UNDERWRITERS' LABORATORIES, INC. (UL)

UL 1025 - Electric Air Heaters.

(Application for copies should be addressed to the Underwriters Laboratories Inc., 333 Pfingsten Road, Northbrook, IL 60062.)

(Industry association specifications and standards are generally available for reference from libraries. They are also distributed among technical groups and using Federal agencies.)

2.3 Order of precedence. In the event of a conflict between the text of this specification and the references cited herein, the text of this specification shall take precedence.

3. REQUIREMENTS

3.1 Description. The unit heaters shall be of the type and size specified (see 1.2), and shall be self-contained, factory-assembled units consisting essentially of a heating element, fan, electric motor, and enclosure. Type I heaters shall be free-standing and provided with a suitable handle for carrying. Type II heaters shall be provided with the necessary facilities for wall or ceiling mounting, as specified (see 6.2.1). The heaters shall be operable with minimum noise consistent with its capacity, velocity, and fan speed. Supply air shall be drawn in the back of the heaters and discharged through horizontal air deflectors or louvers, located on the front of the heaters, as specified herein.

3.2 First article. When specified (see 6.2.1), the contractor shall furnish a complete unit heater for first article inspection and approval (see 4.2.1 and 6.4).

3.3 Standards compliance. The heaters shall meet the requirements of UL 1025.

3.3.1 Certification. Prior to approval of the first article sample, or if none is submitted, prior to approval of the first shipment, the contractor shall submit to the procuring agency or to his authorized representative, satisfactory evidence that each heater shall meet the requirements of UL 1025. Acceptable evidence of meeting the requirements of this standard shall be the official UL Listing Mark prescribed in the Electrical Appliance and Utilization Equipment Directory or a certificate of compliance (see 6.3), from a recognized independent test laboratory acceptable to the Government, indi-

Source: https://assist.dla.mil -- Downloaded: 202610-19T06:53Z
Check the source to verify that this is the currentversion before use.

cating that the heaters have been tested and conform to all applicable requirements. Such evidence must be acceptable to the contracting officer.

3.4 Standard commercial product. The heaters shall, as a minimum, be in accordance with the requirements of this specification and shall be the manufacturer's standard commercial product. Additional or better features which are not specifically prohibited by this specification but which are a part of the manufacturer's standard commercial product, shall be included in the heaters being furnished. A standard commercial product is a product which has been sold or is being currently offered for sale on the commercial market through advertisements or manufacturer's catalogs, or brochures, and represents the latest production model.

3.5 Interchangeability. All units of the same classification furnished with similar options under a specific contract shall be identical to the extent necessary to insure interchangeability of component parts, assemblies, accessories, and spare parts.

3.6 Materials. Materials used shall be free from defects which would adversely affect the performance or maintainability of individual components or of the overall assembly. Materials not specified herein shall be of the same quality used for the intended purpose in commercial practice. Unless otherwise specified herein, all equipment, material, and articles incorporated in the work covered by this specification are to be new and fabricated using materials produced from recovered materials to the maximum extent possible without jeopardizing the intended use. The term "recovered materials" means materials which have been collected or recovered from solid waste and reprocessed to become a source of raw materials, as opposed to virgin raw materials. None of the above shall be interpreted to mean that the use of used or rebuilt products are allowed under this specification unless otherwise specified.

3.7 Design. Heaters shall be operable from a single power source and shall be equipped with a thermal cutout device which shall automatically disconnect the heating element, in the event that the normal operating temperature is being exceeded. This cutout shall be designed to include either a manually operated reset push button type or an automatic reset type limit control. When required, on heaters exceeding 277 volts (V), a built-in transformer may be provided to step down the supply voltage to the motor and control circuit. As designed, the heaters shall be capable of manual or automatic operation, as required. Unless manual control is otherwise specified (see 6.2.1), the heaters shall be thermostatically controlled. Heaters shall be designed with either a separate manual "ON-OFF" switch, or the thermostat shall have a built-in "OFF" switch. The switches and the thermostat at the marked "OFF" position shall interrupt all ungrounded contuctors of the supply circuit.

3.8 Construction. Construction of the unit heaters shall be in accordance with the applicable requirements of UL 1025. The assembled heater, when connected to the specified power supply, shall function in accordance with the performance requirements specified herein.

3.8.1 Enclosure. The enclosure shall be of a galvanized steel, electrogalvanized steel, cold rolled steel with zinc chromate and baked paint finish, or nonferrous sheet metal, and shall be equipped with supporting

Source: https://assist.dla.mil -- Downloaded: 202640-19T06:53Z
Check the source to verify that this is the currentversion before use.

members and bracing, as required, to insure its rigidity. The enclosure shall be capable of withstanding without permanent damage or deformation, strains, jarring, and vibrations incidental to shipping, storage, installation, and operational service. Means of access shall permit ease of wiring, thermostat installation, and inspection of controls. The cord-entry hole of the enclosure shall be bushed. The means of support for type I units shall be nonmarring to its mounting surface, and provide a clearance of no less than 2 inches between the enclosures bottom side and the mounting surface.

3.8.2 Deflectors. Louvered deflectors shall be provided at the front of the enclosure. The deflectors shall be individually adjustable, except that for heaters supported by a swivel type bracket, the up and down adjustment of the enclosure can be used as the adjustment means. The adjustment shall be capable of directing the discharged air within ±45 degree (°) from the axis of the fan.

3.8.3 Heating element. The heating elements shall be in accordance with MIL-H-22577, as applicable, and shall consist of chromium alloy resistance wire embedded and completely surrounded by magnesium oxide, enclosed and swedged into corrosion-resistant sheaths or corrosion resistant finned sheaths. The heating element shall have permanently attached corrosion-resistant steel fins on elements operating on more than 120V; or a chromium alloy resistance wire embedded within a cast aluminum heating grid. The heating element shall operate on single phase ac for 120V input power; single or three phase for 208V, 240V, and 277V input power; and three phase for 416V and 480V input power (see 3.9).

3.8.4 Fan unit. The fan shall be directly driven by an electric motor. The fan shall be fabricated from aluminum or steel and shall be an axial-flow propeller-type which is dynamically balanced. The fan unit shall be designed specifically for heater application. The fan unit shall be resiliently mounted and all moving parts hazardous to personnel shall be enclosed or guarded.

3.8.5 Dimensions and weight. Heaters shall not exceed the following dimensions and weight:

Maximum dimensions

Type	Width (inches)	Depth (inches)	Height (inches)	Maximum Weight (lb)
I	18	15	18	50
II	24	20	22	110

3.9 Electrical system. The electrical system, wiring, shall conform to NFPA No. 70. Provisions shall be madae to ground all electrical equipment. The input power voltage and phase characteristics shall be as specified (see 6.2.1). For three phase operation, the load presented by the heater shall be balanced among the three phases of supply.

3.9.1 Electrical motors. The fan motor shall conform to NEMA MG 1. The motor shall be single speed, continuous duty, totally enclosed, have sleeve bearings with means of lubrication or permanently sealed bearings, and shall

Source: https://assist.dla.mil -- Downloaded: 202640-19T06:53Z
Check the source to verify that this is the currenversion before use.

be equipped with impedance protection, or built-in thermal overload protection. Unless otherwise specified (see 6.2.1), 120V motors may be of the open bearing type suitable for performance requirements and in accordance with the manufacturer's standard practice.

3.9.2 Electric controls. Heater control circuits and components shall be provided to control the operation of the fan and heating elements by cycling the fan and heating elements on and off as required. Control circuits shall operate on single phase, 60 Hertz, at not more than 277V ac. Heaters rated at 1.5 kW, 120V; or 3 kW, 208 to 277V shall have an ON-OFF switch mounted on the enclosure. All heaters rated 7.5 kW and larger, and all 480V heaters shall have line contactors for controlling power to the heating elements.

3.9.2.1 Automatic control. Automatic control shall be thermostat actuated. Type I heaters shall have thermostats attached. Unless otherwise specified (see 6.2.1) type II heaters shall have remote wall-mounted thermostats. A fan time delay switch, which delays fan starting and stopping to allow heat build-up when the heater is cycled on and to purge heat when the heater is cycled off, shall be provided, as required, and on heaters rated 5 kW and larger. When specified (see 6.2.1), a fan switch shall be furnished to permit manual fan operation independent of temperature control.

3.9.3 Electrical power connections. Electrical power supply leads and connections shall conform to UL 1025. Type I heaters shall have a flexible power supply cord not less than 6 feet and not more than 8 feet in length. The cord shall not be heavy-duty heater cord with a ground conductor and grounding type plug. Type II heaters shall be equipped for permanent type connection to the power supply.

3.10 Performance. Unit heaters shall have the performance characteristics specified herein, and in table I.

TABLE I. Performance characteristics.

Heater size	Nominal Heater output (1) kW	Btu/h	Air temp. rise (F°)(2)	Air volume cfm	Air throw (ft)(3)
1.5	1.5	5118	35 - 60	100 - 120	12 - 15
3	3	10236	26 - 65	160 - 400	10 - 15
5	5	17060	39 - 50	350 - 500	12 - 18
7.5	7.5	25590	34 - 67	350 - 700	15 - 22
10	10	34120	45 - 63	500 - 700	15 - 22

3.11 Fungus resistance. When specified (see 6.2.1), electrical components and circuit elements, including terminal and circuit connections, shall be coated with varnish conforming to MIL-V-173, except that:

a. Components and elements inherently inert to fungi or in hermetically sealed enclosures need not be coated.
b. Current-carrying contact surfaces, such as relay contact points, shall not be coated.

3.12 Treatment and painting. Unless otherwise specified (see 6.2.1), the unit heater shall be treated and painted in accordance with the best standard practice of the manufacturer.

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T06:53Z
Check the source to verify that this is the current version before use.

3.13 Marking. The heater shall be marked in accordance with UL 1025.

3.14 Identification plate. An identification plate will be furnished by the contracting officer for each heater. The contractor shall stamp all necessary data in the blank spaces of the plate provided for that purpose, and securely affix a plate to each heater in a conspicuous place at the source of manufacturer. The applicable nomenclature contained in the contract item description shall be placed in the top blank.
Nomenclature shall be "SPACE HEATER, ELECTRIC."

3.15 Wiring diagram. A legible, permanent, wiring diagram shall be permanently affixed inside the heater control compartment. Wiring diagrams are not required to be affixed to the heater on type I portable heaters operated on 120V ac.

3.16 Instruction plates. The heater shall be equipped with instruction plates suitably located, describing any special or important procedures to be followed in operating and servicing the equipment. Plates shall be of a material which will last and remain legible for the life of the equipment, and shall be securely affixed thereto with nonferrous screws or bolts of not less than 1/8-inch diameter.

3.17 Electromagnetic interference control. When specified (see 6.2.1), the equipment shall conform to the electromagnetic interference requirements of MIL-STD-461, group III, class 3.

3.18 Instruction and service manuals. The manufacturer's standard commercial instruction and service manuals shall be provided with each heater attached to or packed with each unit (see 6.3).

3.19 Workmanship. The quality of workmanship shall be such as to produce unit heaters that are in accordance with the requirements of this specification, and insure proper functioning of all parts of the unit.

3.19.1 Steel fabrication. The steel used in fabrication shall be free from kinks, sharp bends, and other conditions which would be deleterious to the finished product. Manufacturing processes shall not reduce the strength of the steel to a value less than intended by the design. Manufacturing processes shall be done neatly and accurately. All bends shall be made by controlled means to insure uniformity of size and shape.

3.19.2 Bolted connections. Bolt holes shall be accurately punched or drilled and shall have the burrs removed. Washers or lockwashers shall be provided in accordance with good commercial practice, and all bolts, nuts, and screws shall be tight.

3.19.3 Riveted connections. Rivet holes shall be accurately punched or drilled and shall have the burrs removed. Rivets shall be driven with pressure tools and shall completely fill the holes. Rivet heads, when not countersunk or flattened, shall be of approved shape and of uniform size for the same diameter of rivet. Rivet heads shall be full, neatly made, concentric with the rivet holes, and in full contact with the surface of the member.

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T06:53Z
Check the source to verify that this is the current version before use.

3.19.4 Welding. Welding procedures shall be in accordance with a nationally recognized welding code. The surface of parts to be welded shall be free from rust, scale, paint, grease, or other foreign matter. Welds shall be of sufficient size and shape to develop the full strength of the parts connected by the welds. Welds shall transmit stress without permanent deformation or failure when the parts connected by the weld are subjected to proof and service loadings.

3.19.5 Castings. All castings shall be sound and free from patching, misplaced coring, warping, or any other defect which reduces the castings ability to perform its intended function.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the contractor is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract or purchase order, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

4.1.1 Component and material inspection. Components and materials shall be inspected in accordance with all the requirements specified herein and in applicable referenced documents.

4.1.2 Standards compliance. The contractor shall make available to the contracting officer or his authorized representative evidence of compliance with the applicable standard(s) cited in 3.3.

4.2 Classification of inspections. The inspection requirements specified herein are classified as follows:

a. First article inspection (see 4.2.1).
b. Quality conformance inspection (see 4.2.2).

4.2.1 First article inspection. The first article inspection shall be performed on one heater when a first article is required (see 3.2 and 6.2.1). This inspection shall include the examination of 4.4 and the tests of 4.5. The first article may be either a first production item or a standard production item from the supplier's current inventory provided the item meets the requirements of the specification and is representative of the design, construction, and manufacturing technique applicable to the remaining items to be furnished under the contract.

4.2.2 Quality conformance inspection. The quality conformance inspection shall include the examination of 4.4, the tests of 4.5.2, and the packaging inspection of 4.6. This inspection shall be performed on the samples selected in accordance with 4.3.

4.3 Sampling. Sampling and inspection procedures shall be in accordance with MIL-STD-105. All heaters offered for delivery at one time shall be considered a lot for the purpose of inspection. The inspection level shall be

Source: https://assist.dla.mil -- Downloaded: 202640-19T06:53Z
Check the source to verify that this is the currentversion before use.

level S-3 and the Acceptable Quality Level shall be 4.0 percent defective. If an inspection lot is rejected, the contractor may rework it to correct the defects, or screen out the defective units, and resubmit for a complete reinspection. Resubmitted lots shall be reinspected using tightened inspection. If the rejected lot was screened, reinspection shall be limited to the defect causing rejection. If the lot was reprocessed, reinspection shall be performed for all defects. Rejected lots shall be separate from new lots, and shall be clearly identified as reinspected lots.

4.4 Examination. Each sample selected shall be examined for compliance with the requirements in section 3 of this specification. This element of inspection shall encompass all visual examinations and dimensional measurements.

4.5 Tests. The first article, when a first article is required, and each sample selected in accordance with 4.3 shall be tested. Any unit failing to pass the following tests shall be rejected, and if the number of defective units in any sample exceeds the acceptable number for that sample, the lot represented by the sample shall be rejected.

4.5.1 Performance test. The first article sample shall be operated continuously, at least 2 hours in a stable operating temperature, at rated voltage and full load. Required data shall be obtained to determine compliance with all the performance characteristics of table I, including measurement of heat output.

4.5.2 Operational test. Each sample heater shall be operated for not less than 15 minutes, to determine that operation is satisfactory. Fan motor, switches, heating element, and other components, as applicable, shall be subjected to not less than five operations. Any malfunction, including excessive vibration, overheating, or loose parts, shall be cause for rejection.

4.5.3 Test for electromagnetic interference characteristics. When conformance to electromagnetic characteristic limits is required, the equipment shall be tested in accordance with MIL-STD-462 to determine conformance to the electromagnetic characteristics of 3.17.

4.6 Packaging inspection. The preservation, packing, palletization, and marking of the item shall be inspected to verify conformance to the requirements of section 5.

5. PACKAGING

5.1 Preservation. Preservation shall be level A or C as specified (see 6.2.1).

5.1.1 Level A. Each heater shall be packaged method III in accordance with MIL-P-116. Each item shall be placed in a close-fitting, fiberboard box conforming to PPP-B-636, class weather-resistant. The contents shall be cushioned to prevent movement or damage. The box shall be closed method V in accordance with the appendix to the box specification.

5.1.2 Level C. Material shall be packaged in accordance with ASTM D 3951.

5.2 Packing. Packing shall be level A, B, or C as specified (see 6.2.1).

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T06:53Z
Check the source to verify that this is the current version before use.

5.2.1 Levels A and B. Packing shall be accordance with MIL-STD-794. Containers shall be selected from table I for the appropriate level.

5.2.2 Level C. Material shall be packed in accordance with ATM D 3951.

5.3 Palletization. Material shall be palletized in accordance with MIL-STD-147 when the following criteria is met:

a. Load to consist of four or more unskidded containers; and,
b. Load shall utilize a minimum of 80 percent of the pallet base.

5.4 Marking. Marking shall be in accordance with MIL-STD-129.

6. NOTES

6.1 Intended use. Space heaters covered by this specification are intended for use in providing heated air to balance heat losses in any room or building.

6.2 Ordering data.

6.2.1 Acquisition requirements. Acquisition documents should specify the following:

a. Title, date and number of this specification.
b. Type and size of unit heater (see 1.2).
c. If specifications and standards are different (see 2.1.1).
d. Style of mounting required for type II heaters (see 3.1).
e. When first article is required for inspection and approval (see 3.2, 4.2.1, and 6.4).
f. When manual control is required (see 3.7).
g. Input power phase and voltage requirements (see 3.9).
h. Type of bearing required, if different (see 3.9.1).
i. When a fan switch is required (see 3.9.2.1).
j. When thermostat for type II heaters shall be other that specified (3.9.2.1)
k. When fungus resistance is required (see 3.11).
l. Treatment and painting, if different (see 3.12).
m. When electromagnetic interference control is required (see 3.17).
n. Level of preservation and level of packing required (see 5.1 and 5.2).

6.3 Data requirements. When this specification is used in an acquisition which incorporates a DD Form 1423, Contract Data Requirements List (CDRL), the data requirements identified below shall be developed as specified by an approved DD Form 1664, Data Item Description (DID), and delivered in accordance with the approved CDRL incorporated into the contract. When the provisions of paragraph 7-104.9(n) of the Defense Acquisition Regulations are invoked and the DD Form 1423 is not used, the data specified below shall be delivered by the contractor in accordance with the contract or purchase order requirements. Deliverable data required by this specification is cited in the following paragraphs:

Source: https://assist.dla.mil -- Downloaded: 202610-19T06:53Z
Check the source to verify that this is the current version before use.

Paragraph No.	Data requirements title	Applicable DID No.	Option
3.3.1	Certification of Compliance	DI-E-2121	----
3.18	Publication, Commercial	UDI-E-240101	----

(DIDs related to this specification, and identified in section 6 will be approved and listed as such in DoD 5000.19L, Vol. II, Acquisition Management Systems and Data Requirements Control List. Copies of DIDs required by the contractors in connection with specific acquisition functions should be obtained from the Naval Publications and Forms Center or as directed by the contracting officer.)

6.4 First article. When a first article inspection is required, the item will be tested and should be a first article sample, or it may be a standard production item from the contractor's current inventory as specified in 4.2.1. The first article should consist of one unit. The contracting officer should include specific instructions in acquisition documents regarding arrangements for examination, test, and approval of the first article.

6.5 Changes from previous issue. Asterisks are not used in this revision to identify changes with respect to the previous issue, due to the extensiveness of the changes.

Preparing activity:

Navy - YD

(Project 4520-N287)

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T06:53Z
Check the source to verify that this is the current version before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

(See Instructions – Reverse Side)

1. DOCUMENT NUMBER	2. DOCUMENT TITLE
MIL-H-19910C(YD)	HEATERS, SPACE, ELECTRIC

3a. NAME OF SUBMITTING ORGANIZATION	4. TYPE OF ORGANIZATION *(Mark one)*
	☐ VENDOR ☐ USER ☐ MANUFACTURER ☐ OTHER *(Specify)*: _____
b. ADDRESS *(Street, City, State, ZIP Code)*	

5. PROBLEM AREAS

a. Paragraph Number and Wording:

b. Recommended Wording:

c. Reason/Rationale for Recommendation:

6. REMARKS

7a. NAME OF SUBMITTER *(Last, First, MI)* – Optional	b. WORK TELEPHONE NUMBER *(Include Area Code)* – Optional
c. MAILING ADDRESS *(Street, City, State, ZIP Code)* – Optional	8. DATE OF SUBMISSION *(YYMMDD)*

DD FORM 82 MAR 1426 PREVIOUS EDITION IS OBSOLETE.

(TO DETACH THIS FORM, CUT ALONG THIS LINE.)

Source: https://assist.dla.mil -- Downloaded: 20261O-19T06:53Z
Check the source to verify that this is the current version before use.