A-A-50056
August 8, 1983

COMMERCIAL ITEM DESCRIPTION

REFRIGERATORS, MECHANICAL, MORTUARY

The General Services Administration has authorized the use of this commercial item description in preference to MIL-R-2470 for procurement of size 5 items.

Intended use. The refrigerators are for mortuary use in Military or other Government installations.

Salient characteristics.

The mortuary refrigerator shall be a self-contained type equipped with telescoping racks and shall be capable of holding five cadavers. The refrigerator shall be free-standing when assembled and shall consist essentially of the cabinet, carriage assembly, and refrigeration system. The refrigerator shall be of sectional design and of a size to permit passage of sections through a 32 inch by 80 inch doorway. Any design incorporating the assembly of panels shall have mating surfaces designed to seal tightly and give complete rigidity to the assembled refrigerator. The structural framing shall be designed to provide support for the fully loaded refrigerator. The refrigerator, when assembled for operation, shall be fully self-supporting. The joints of all sections of the refrigerator shall be provided with gaskets to prevent the infiltration of air and moisture. The space between the inner liner and outer shell of the refrigerator, including the doors, shall be completely filled with insulation. The insulation shall be industrial-type fiberglass insulation board, expanded polystyrene, or fluorocarbon expanded polyurethane preformed to shape or foamed-in-place.

The inner liners and outer shells of the refrigerator, including the doors, shall be fabricated of aluminum. The aluminum shall have either a stucco embossed finish or a bright, smooth finish. All sections and doors shall be covered with one-piece aluminum skins inside and outside.

Each door shall be furnished with a replaceable cushion type gasket. Each door shall be supported by two hinges and secured, when in a closed position, by a latch and strike assembly with sufficient force to affect a gasket seal. The latch and strike assembly shall be of the adjustable type and shall have locking facilities capable of taking a 1-3/4 inch padlock. Doors opening toward adjacent doors shall be equipped with 135 degree stop hinges. Each door shall have a card holder mounted to the outside surface and shall be fabricated of the same material as the outer skin of the door. The card holder shall accommodate a name card 2-1/4 inches by 2-7/8 inches.

FSC 4110

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:38Z
Check the source to verify that this is the current version before use.

The refrigerator shall be provided with a trap drain having a removable strainer and a removable, perforated, disc-type cover.

Each cadaver compartment shall be equipped with a mortuary rack consist-consisting of rack frame, carriage assembly, and removable tray. The rack assembly shall be constructed so that the tray shall clear the door sills as closely as possible without contract. The carriage shall be of two-piece telescopic construction. The overall length of carriage assembly shall be not greater than 86 inches and shall be able to pass through door openings at least 27 inches wide. The extended tray and carriage shall support a 500 pound load without sagging or racking. The outer end of the carriage shall be equipped with an automatic trip latch and handle for locking carriage and tray in position inside the refrigerator, and designed to allow tray only, or tray and carriage to be withdrawn. Bumpers shall be provided on the carriage to absorb any shock of telescoping the carriage assembly. Trays shall be fabricated of one-piece drawn stainless steel and shall have an overall minimum dimension of 22 inches wide by 83 inches long by 2-3/4 inches deep. The trays shall be removable and designed to support a uniformly distributed load of 500 pounds. The trays shall be provided with handles or hand holes at each end for lifting the tray.

The refrigerator shall be equipped with an interior light or lights mounted in a vaporproof fixture on the interior of the front section of the refrigerator. Lights shall be controlled by a switch on the refrigerator exterior front. The switch shall be equipped with a pilot light to indicate when the interior light is turned on.

The refrigeration system and component parts shall be completely installed and connected to make a fully automatic self-contained mortuary refrigerator. The refrigeration system shall consist of an electric motor driven air-cooled condensing unit, evaporator, and necessary accessories including controls, motor starters, and motor overload protectors. The refrigeration system shall be designed to operate on a 120 volt, 60 Hz, single phase electrical source. The refrigerating equipment shall be enclosed in the top section of the refrigerator with adequate ventilating grills or louvers. Provisions shall be made for uniform air distribution within the refrigerated space. The refrigeration system shall automatically maintain 32°F to 34°F in the refrigerator in ambient up to 110°F. A remote indicating dial thermometer shall be mounted on the outside front surface with the temperature sensing element located near the center of the refrigerated space but not in the direct path of air flow.

The overall dimensions of the mortuary refregerator shall not exceed 73 inches in width, 96 inches in depth, and 88 inches in height.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:38Z
Check the source to verify that this is the current version before use.

Standards compliance. The mortuary refrigerator shall comply with Underwriters Laboratories, Inc. Standard No. 471.

Marking. The unit shall be legibly marked with the manufacturer's name or trademark and model or part number plus the contract number and National Stock Number.

Certification. The contractor shall certify that the product offered meets the salient characteristics of this description, conforms to the producer's own drawings, specifications, standards, and quality assurance proctices, and is the same as the product sold in the commercial marketplace. The Government reserves the right to require proof of such conformance prior to first delivery and thereafter as may be otherwise provided for under provisions of the contract.

Packaging.

A. Commercial packaging. Each mortuary refrigerator shall be packaged in accordance with commercial practice.

B. Commercial packing. Each mortuary refrigerator shall be packed in a manner to insure carrier acceptance and safe delivery at destination at the lowest transportation rate for such supplies. Containers shall comply with the Uniform Freight Classification or National Motor Freight Classification, as applicable.

C. Export packaging. Each mortuary refrigerator shall be disassembled to the extent determined by the supplier to protect parts susceptible to damage during shipment and storage and for reduction of cubage. Components of the refrigeraator shall be cleaned, preserved and cushioned to afford protectin against corrosion, deterioration, and physical damage during shipment and storage. Hardware and tools shall be packaged in a class weather-resistant fiberboard box conforming to PPP-B-636. The box shall be closed in accordance with Method IV as specified in the appendix of PPP-B-636. The technical manual shall be placed in a paper envelope or plastic bag.

Source: https://assist.dla.mil -- Downloaded: 202610-26T08:38Z
Check the source to verify that this is the currenversion before use.

containers

D. Export packing. Each mortuary efrigerator, consisting of disassembled components and accessories, shall be packed as a set in three or more shipping containers as hereinafter specified. The shipping container shall be a snug-fitting wood-cleated plywood box conforming to domestic type, style A or J, grade B, type 2 load of PPP-B-601 or nailed wood box conforming to class 1, style 2 or 4, grade B, type 2 load of PPP-B-621. The contents of each box shall be cushioned, blocked and braced to prevent movement while the box is in transit. Each shipping container shall be closed and strapped in accordance with the appendix of PPP-B-601 or PPP-B-621, as applicable.

E. Marking of interior boxes and shipping containers (commercial and export). Commercial marking for interior boxes and shipping containers is acceptable provided the following information is included:

National Stock Number
Date of Packaging (Month/Year)
Item Description
Contract Number
Quantity, Unit of Issue
Name, Address and Zip Code of Contractor 1/

1/ Interior boxes do not require this information.

In addition, each shipping container shall be set marked in accordance with MIL-STD-129.

Sources of information for nongovernmental association documents:

Underwriters Laboratories, Inc.
333 Pfingsten Road
Northbrook, IL 60062

National Motor Freight Traffic Association, Inc., Agent
National Motor Freight Classification
American Trucking Associations, Inc., Traffic Department
1616 P Street, N.W., Washington, DC 20036

Uniform Classification Committee, Agent
Uniform Freight Classification
Uniform Classification Committee, Suite 1106
222 South Riverside Plaza, Chicago, IL 60606

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:38Z
Check the source to verify that this is the current version before use.

MILITARY INTERESTS:

Custodians

Army - GL
Air Force - 99

Review Activities

Army - MD
Air Force - 34

CIVIL AGENCY COORDINATING ACTIVITY:

GSA - FSS

PREPARING ACTIVITY:

Army - GL

Project No. 4110-0370

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:38Z
Check the source to verify that this is the current version before use.