NOTICE—When Government drawings, specifications, or other data are used for any purpose other than in connection with a definitely related Government procurement operation, the United States Government thereby incurs no responsibility, nor any obligation whatsoever; and the fact that the Government may have formulated, furnished, or in any way supplied the said drawings, specifications, or other data is not to be regarded by implication or otherwise as in any manner licensing the holder or any other person or corporation, or conveying any rights or permission to manufacture, use, or sell any patented invention that may in any way be related thereto.

This military standard is approved by the Department of Defense and is mandatory on all activities. Selection for all new engineering and design applications and for repetitive use shall be made from this document.

FED. SUP CLASS
4210



MS Part Number	Rated Capacity	Pump	TANK DATA			
			Material	Maximum Dimensions		
				Height	Width	Short Dimension
				Inches	Inches	Inches
MS-39082-1	5 Gal	Brass	Steel Galvanized Finish	15	15	7
MS-39082-2	5 Gal	Brass	Fabric*			

Pumps shall be of the manually operable, trombone type.

(B) Extinguishing Agent discharged by pumping action.
Pumps shall be of the manually operable, trombone type.

* When the requirement dictates non-corrosive construction, material for the tank shall be a collapsible bag constructed from synthetic cloth fabric and shall be furnished in accordance with Type II, Specification MIL-E-212.

(B) NOTES:
1. Material, dimensions, tolerances, inherent characteristics, and test for extinguishers shall be in accordance with Type I, Class 2 of Specification MIL-E-212.
2. This Document takes precedence over documents referenced herein.
3. Referenced documents shall be the issue in effect on the date of invitation for bids.
4. Illustration applies to M.S. 39082-1 (Type I) only and is for identification and is not intended to restrict designs which will otherwise conform to specification requirements.

This document has been promulgated by the Department of Defense as the Military Standard to limit the selection of the item, product, or design covered herein in engineering, design and procurement. This standard shall become effective not later than 90 days after the latest date of approval shown.

CANCELLED AFTER 2 MAY 1968. NO SUPERSEDING STANDARD. FOR FUTURE REQUIREMENTS USE PROCUREMENT SPECIFICATION MIL-E-212.

APPROVED 16 APRIL 1959 REVISED (A) 10 MARCH 1960 (B) 30 DECEMBER 1960

P.A. CE Other Cust DOCKS USAF	TITLE EXTINGUISHER, FIRE, WATER BACK PACK, PUMP TYPE, HAND; 5 GAL.	MILITARY STANDARD MS 39082
PROCUREMENT SPECIFICATION MIL-E-212	SUPERSEDES:	SHEET 1 OF 1

Source: https://assist.dla.mil -- Downloaded: 202640-23T17:45Z
Check the source to verify that this is the current version before use.