MILITARY SPECIFICATION

EXTINGUISHER, FIRE, AQUEOUS FILM FORMING FOAM, (AFFF), 2-1/2 GALLON

This specification is approved for use by the Naval Sea Systems Command, Department of the Navy, and is available for use by all Departments and Agencies of the Department of Defense.

1. SCOPE

1.1 Scope. This specification covers the requirements for a 2-1/2 gallon fire extinguisher of the stored-pressure type. It is capable of generating a low expansion foam using AFFF concentrate and fresh water.

2. APPLICABLE DOCUMENTS

2.1 Government documents.

2.1.1 Specifications and standards. Unless otherwise specified, the following specifications and standards of the issue listed in that issue of the Department of Defense Index of Specifications and Standards (DoDISS) specified in the solicitation form a part of this specification to the extent specified herein.

SPECIFICATIONS

FEDERAL

PPP-B-601 - Boxes, Wood, Cleated Plywood.
PPP-B-621 - Box, Wood, Nailed and Lock-Corner.
PPP-B-636 - Boxes, Shipping, Fiberboard.
PPP-B-640 - Boxes, Fiberboard, Corrugated, Triple-Wall.

MILITARY

MIL-P-116 - Preservation, Methods of.
MIL-S-901 - Shock Tests H.I. (High Impact) Shipboard Machinery, Equipment, and Systems Requirements for.
MIL-L-10547 - Liner, Case, and Sheet, Overwrap, Water Vaporproof or Waterproof, Flexible.
MIL-F-24385 - Fire Extinguishing Agent, Aqueous Film Forming Foam (AFFF) Liquid Concentrate for Fresh and Sea Water.

Beneficial comments (recommendations, additions, deletions) and any pertinent data which may be of use in improving this document should be addressed to: Commander, Naval Sea Systems Command, SEA 55Z3, Department of the Navy, Washington, DC 20362-5101 by using the self-addressed Standardization Document Improvement Proposal (DD Form 1426) appearing at the end of this document or by letter.

Source: https://assist.dla.mil -- Downloaded: 20261O-20T00:41Z
Check the source to verify that this is the current version before use.

STANDARDS

FEDERAL

FED-STD-H28 - Screw Thread Standards for Federal Services.
FED-STD-H28/2 - Unified Thread Form and Thread Series for Bolts, Screws, Nuts, Tapped Holes and General Application.

MILITARY

MIL-STD-105 - Sampling Procedures and Tables for Inspection by Attributes.
MIL-STD-129 - Marking for Shipment and Storage.
MIL-STD-167-1 - Mechanical Vibrations of Shipboard Equipment (Type I - Environmental and Type II - Internally Excited).

2.1.2 Other Government publications. The following Government publication forms a part of this specification to the extent specified herein.

PUBLICATION

DEPARTMENT OF TRANSPORTATION
Code of Federal Regulations, Title 49
Part 173.306(c)

(Application for copies should be addressed to the Superintendent of Documents, Government Printing Office, Washington, DC 20402.)

(Copies of specifications, standards, and publications required by contractors in connection with specific acquisition functions should be obtained from the contracting activity or as directed by the contracting officer.)

2.2 Other publications. The following documents form a part of this specification to the extent specified herein. The issues of the documents which are indicated as DoD adopted shall be the issue listed in the current DoDISS and the supplement thereto, if applicable.

UNDERWRITERS LABORATORIES, INC. (UL)
Standard Number 8 - Foam Fire Extinguisher.

(Application for copies should be addressed to the Underwriters Laboratories, Inc., 207 East Ohio Street, Chicago, IL 60611.)

UNIFORM CLASSIFICATION COMMITTEE AGENT
Uniform Freight Classification Ratings, Rules, and Regulations.

(Application for copies should be addressed to the Uniform Classification Committee Agent, Tariff Publication Officer, Room 1106, 222 South Riverside Plaza, Chicago, IL 60606.)

Source: https://assist.dla.mil -- Downloaded: 20261O-20T00:41Z
Check the source to verify that this is the current version before use.

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)
Pamphlet 11 - Standard for Low Expansion Foam and Combined Agent Systems.

(Application for copies should be addressed to the National Fire Protection Association, Battery March Park, Quincy, MA 02269.)

(Industry association specifications and standards are generally available for reference from libraries. They are also distributed among technical groups and using Federal agencies.)

2.3 Order of precedence. In the event of a conflict between the text of this specification and the references cited herein, the text of this specification shall take precedence.

3. REQUIREMENTS

3.1 First article. When specified (see 6.2.1), a sample shall be subjected to first article inspection (see 4.2 and 6.3).

3.2 Materials.

3.2.1 Finish. The shell shall be finished with a red enamel protective coating for identification and enhanced corrosion resistance.

3.2.2 Threads. Threads shall be in accordance with FED-STD-H28 and FED-STD-H28/2.

3.2.3 Recovered materials. Unless otherwise specified herein, all equipment, materials, and articles incorporated in the products covered by this specification shall be new and shall be fabricated using materials produced from recovered materials to the maximum extent practicable without jeopardizing the intended use. The term "recovered materials" means materials which have been collected or recovered from solid waste and reprocessed to become a source of raw materials, as opposed to virgin raw materials. None of the above shall be interpreted to mean that the use of used or rebuilt products is allowed under this specification unless otherwise specifically specified.

3.3 Fire extinguishing agent. The fire extinguishing agent tested for listing by Underwriters Laboratories shall be a solution of liquid AFFF concentrate and fresh water. The fire extinguisher shall be compatible with the use of AFFF in accordance with MIL-F-24385.

3.4 Weight. The weight of the empty charged extinguisher, excluding the mounting bracket, shall not exceed 10 pounds.

3.5 Overall dimensions. The extinguisher and bracket shall be as small as possible consistent with good design and performance. The extinguisher height shall be not greater than 25 inches.

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T00:41Z
Check the source to verify that this is the current version before use.

3.6 Design and construction.

3.6.1 Extinguisher. The extinguisher shall be a stored-pressure type with a rated capacity of 2.5 gallons of AFFF solution and a service pressure of 100 pounds per square inch (lb/in^2). The extinguisher shall be easily rechargeable without the use of special tools or special equipment. (Special tools are defined as those not listed in the Federal Supply catalog, copies of which may be consulted in the office of the Defense Contract Administration Service.) The flow shall be controlled by a shut off valve at the extinguisher end of the discharge hose. The extinguisher shall be listed by Underwriters Laboratories Inc., (UL) in accordance with UL Standard No. 8, and shall have a minimum fire extinguishing rating of 3-A:20-B.

3.6.2 Extinguisher components. The extinguisher shall contain the following major components:

(a) Discharge valve assembly.
(b) Discharge hose and nozzle assembly.
(c) Shell.
(d) Siphon tube assembly.
(e) Antioverfill tube.
(f) Charging kit.

3.6.2.1 Discharge valve assembly. The discharge valve assembly shall consist of a discharge valve, air valve assembly, pull pin and retainer chain, and pressure gauge.

3.6.2.1.1 Discharge valve. A self-closing discharge valve shall be located on the top of the extinguisher. The valve body and operating parts (levers, handle, valve stem, plunger pin, springs, bushings, and so forth) shall be made of nonferrous metal, or austenitic stainless steel.

3.6.2.1.1.1 Gaskets and O-rings. A gasket or O-ring shall be retained in a recess or the equivalent, in the valve or collar, to provide a leak-tight seal. A gasket or O-ring shall be provided at the valve and hose connection to provide a leak-tight joint. O-rings or gaskets shall be used to prevent leaking of the poppet valve at the seat and along the shaft.

3.6.2.1.1.2 Threads. The discharge valve connection to the shell shall have 1.5-16 UN-2B (internal) threads. The discharge valve connection to the discharge hose shall have 0.625-18 UNF-2B (internal) threads.

3.6.2.1.2 Air valve assembly. A Schraeder type (or equivalent) air valve assembly and cap shall be provided as an integral part of the discharge valve assembly for pressurizing the extinguisher. Pressure charging through the discharge hose is not acceptable.

3.6.2.1.3 Pull-pin and retainer chain. A pull-pin shall be provided to prevent inadvertent operation. The pin shall pass through the valve operating lever in such a way that the valve will not operate with the pin in place. The pin shall be held captive to the extinguisher by a short retainer chain (or

Source: https://assist.dla.mil -- Downloaded: 20261O-20T00:41Z
Check the source to verify that this is the current version before use.

equivalent), so that it will not be lost during operation of the unit. A visual mechanical tamper seal shall be used to hold the pull-pin in the safe position. Use of or tampering with the extinguisher will break the seal. The seal is to be field-replaceable and shall be provided as a part of the recharge kit (see 3.6.2.6).

3.6.2.1.4 Gauge. A pressure gauge shall be provided as an integral part of the discharge valve. The gauge face shall indicate the pressure in units of lb/in^2 or a combination of lb/in^2 and additional units, such as kilopascals (kPa). The minimum indicated gauge pressure shall be zero lb/in^2. The maximum indicated gauge pressure shall be not less than 150 lb/in^2 and not greater than 250 lb/in^2. The diameter of the gauge shall be not less than 1.5 inches.

3.6.2.2 Discharge hose and nozzle assembly. The extinguisher shall have a flexible discharge hose with a permanently affixed nozzle. The inlet side of the discharge hose shall contain a fitting with 0.625-18 UNF-2A (external) threads, for attachment to the discharge valve. The nozzle shall be of the air-aspirating type and shall aerate the extinguishing agent to achieve the expansion ratio specified in 3.7.1.

3.6.2.3 Shell. The shell (body) of the extinguisher shall be of sufficient volume to hold 2.5 gallons of the extinguishing agent plus enough compressed air to propel the agent at velocities sufficient to aerate the agent and produce the discharge characteristics specified in 3.7.1. The shell outside diameter shall be seven inches (plus or minus 0.125 inches). The design service pressure shall be not less than 100 lb/in^2.

3.6.2.3.1 Material. The shell shall be fabricated of austenitic stainless steel, American Iron and Steel Institute (AISI) type 304L.

3.6.2.3.2 Joints. Joints shall be butt welded. Repair welds are not acceptable.

3.6.2.3.3 Fill opening. The collar or fill opening of the shell shall have 1.5-16 UN-2A (external) threads.

3.6.2.3.4 Footstand. If the shell has a domed end at the base, a footstand shall be permanently affixed to the shell to enable the extinguisher to stand upright.

3.6.2.4 Siphon tube and strainer assembly. A siphon tube with strainer shall be attached to the discharge valve and shall carry agent from the bottom of the shell to the discharge valve.

3.6.2.5 Antioverfill tube. An antioverfill tube shall be provided. It shall be capable of ensuring adequate air space above the liquid in the extinguisher so that the propellent air will expell the liquid at sufficient pressure to empty the extinguisher and discharge foam with the desired characteristics (see 3.7.1) throughout the duration of extinguisher operation.

Source: https://assist.dla.mil -- Downloaded: 202610-20T00:41Z
Check the source to verify that this is the current version before use.

3.6.2.6 Charging kit. Extinguishers shipped uncharged shall contain the following items packed as a charging kit:

(a) Complete instructions for charging.
(b) Premeasured container containing 1 charge of AFFF concentrate.
(c) Tamper seal.
(d) Extinguisher inspection record tag with suitable attachment.
(e) Cover cap for Schraeder valve (or equal).

3.6.3 Mounting bracket. A mounting bracket shall be provided to hold the extinguisher in a vertical orientation and shall be capable of floor and wall mounting. It shall have a bottom plate which extends beyond the base of the extinguisher.

3.7 Performance requirements. The fire extinguisher shall exhibit the performance requirements specified herein during the inspection of 4.5 and 4.6.

3.7.1 Discharge characteristics. The effective discharge time of the extinguisher shall be 45 to 65 seconds when tested as specified in 4.6.2.1. The foam shall have a minimum expansion ratio of 6.5:1 and a minimum quarter drainage time of 90 seconds when tested as specified in 4.6.2.2.

3.7.2 Fire extinguishment.

3.7.2.1 UL rating. The extinguisher shall have a fire extinguishing capability so as to obtain a 3A:20B fire extinguishing rating from UL and shall be so labeled.

3.7.2.2 Fire extinguishing. The extinguisher shall extinguish the fire when tested as specified in 4.6.4.

3.7.2.2.1 Equivalency. The requirement of 3.7.2.2 shall be considered to have been met if the foam tested by UL to obtain the fire extinguishing rating (see 3.7.2.1) is qualified under MIL-F-24385.

3.7.3 Repeated operation of the valve. When tested as specified in 4.6.3.1, repeated operation of the valve shall not cause undue wear or adversely affect the operation of the extinguisher.

3.7.4 Repeated operation of the extinguisher bracket. The mounting bracket shall be operable after the tests specified in 4.6.3.2 and 4.6.5.1.

3.7.5 High-impact and shock resistance. The extinguisher and mounting bracket shall meet the high-impact shock tests specified in 4.6.5.1.

3.7.6 Vibration resistance. The extinguisher and mounting bracket shall be operable after being subjected to the vibrational conditions specified in 4.6.5.2.

Source: https://assist.dla.mil -- Downloaded: 202610-20T00:41Z
Check the source to verify that this is the current version before use.

3.8 Identification.

3.8.1 Nameplate. A nameplate and other extinguisher marking shall be provided as specified in UL Standard No. 8.

3.8.2 Military label plate. A label plate shall be securely attached to the body of each extinguisher on the rear side (opposite to the nameplate). The label shall be an aluminum foil type with pressure sensitive adhesive backing. The label plate shall be legibly printed with black lettering at least 0.25 inches high and shall contain the following information:

(a) MIL-E-24652.
(b) National stock number (NSN) if provided (see 6.2.1).
(c) Allowance parts list (APL) number if provided (see 6.2.1).

3.9 Workmanship. The extinguishers shall be uniform in quality and shall be free from irregularities, defects, or foreign matter which could affect safety, performance, reliability, or durability.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the contractor is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract or purchase order, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure that supplies and services conform to prescribed requirements.

4.2 Classification of inspections. The inspections specified herein are classified as follows:

(a) First article inspection (see 4.3).
(b) Quality conformance inspection (see 4.4.).

4.3 First article inspection. First article inspection shall consist of the examination and tests specified in table I.

TABLE I. First article inspection.

Test	Requirement paragraph	Test paragraph
Visual examination	3.2.1 - 3.6.3	4.5
Discharge duration	3.7.1	4.6.2.1
Foam quality	3.7.1	4.6.2.2
Discharge valve operation	3.7.3	4.6.3.1
Mounting bracket operation	3.7.4	4.6.3.2
Shock	3.7.5	4.6.5.1
Vibration	3.7.6	4.6.5.2

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T00:41Z
Check the source to verify that this is the current version before use.

4.3.1 First article test report. The contractor shall prepare a first article test report in accordance with the data ordering document (see 6.2.2).

4.4 Quality conformance inspection. Quality conformance inspection shall consist of the examination of 4.5 and a certification of compliance that each lot of extinguishers meets the requirements specified herein (see 6.2.2).

4.4.1 Inspection lot. All extinguishers offered for delivery at one time shall be considered a lot for the purpose of quality conformance inspection.

4.4.2 Sampling for examination. Sample extinguishers shall be selected at random from each lot in accordance with MIL-STD-105, at inspection level II, with an acceptance quality level (AQL) of 0.10 percent defective.

4.5 Examination. Each of the sample extinguishers selected in accordance with 4.4.2 shall be examined to verify conformance to this specification. Examination shall be conducted as specified in table II.

TABLE II. Classification of defects.

Categories	Defects	Requirements paragraphs
Critical	None determined.	
Major		
101	Material not as specified.	3.6.2.1, 3.6.2.3.1
102	Component missing, damaged, defective foreign matter present, irregularities or malfunctioning.	3.6.1 - 3.6.3
103	Assembly of parts not as specified.	3.6.1 - 3.6.3
104	Threading not as specified.	3.6.2.1.1.2, 3.6.2.2, 3.6.2.3.3
105	Finish of exterior surfaces not as specified	3.2.1
106	Dimensions not as specified.	3.5, 3.6.2.1.4, 3.6.2.3
Minor		
201	Weight not as specified.	3.4
202	Marking for identification not as specified.	3.8

4.6 Test procedures.

4.6.1 General. The tests of 4.6.2.1, 4.6.2.2 and 4.6.4 shall be conducted with the extinguisher charged as by the manufacturer's instructions with aqueous film forming foam in accordance with type 6 of MIL-F-24385.

4.6.2 Discharge. Discharge and foam quality tests shall be conducted in accordance with NFPA-11 and as specified in 4.6.2.1 and 4.6.2.2. The tests are conducted at 70°F.

Source: https://assist.dla.mil -- Downloaded: 202610-20T00:41Z
Check the source to verify that this is the current version before use.

4.6.2.1 Discharge duration. An extinguisher charged to its rated capacity (see 4.6.1) and conditioned at 70°F (21.1°C) for 16 hours shall be held in a vertical position. The extinguisher shall be discharged in a continuous stream for a minimum of 45 seconds. Maximum reach at the beginning and end of this time span shall be recorded. The extinguisher shall continue to be discharged until the "gas point" is reached. The total duration of this discharge shall be recorded. The "gas point" occurs when the discharged foam abruptly changes quality, indicating that air is being drawn from the tank along with the liquid. Fialure to meet the discharge time criteria of 3.7.1 shall constitute failure of this test.

4.6.2.2 Foam quality. The foam quality test specified in NFPA-11 shall be conducted twice (see 4.6.1) for each extinguisher, with a full charge and once after expelling half the liquid from the unit. The averaged results of the two tests shall be reported as expansion ratio and quarter drainage time (in seconds) as shown in NFPA-11, Appendix A-6-1.1.2. Failure to meet the expansion ratio and quarter drainage time criteria of 3.7.1 shall constitute failure of this test.

4.6.3 Operational tests.

4.6.3.1 Discharge valve operation. The valve shall be operated 100 times with the valve pressurized to 100 lb/in^2 ($\pm$ 20 lb/in^2). Operation shall be normal at the completion of the test.

4.6.3.2 Mounting bracket operation. The extinguisher shall be locked in the mounting bracket, and the bracket shall be opened and relocked. This procedure will be repeated 100 times. Operation of the bracket will be normal at the completion of this test.

4.6.4 Fire extinguishing.

4.6.4.1 General. The test fire shall be made in a 50 square foot pan, not less than 8 inches deep, square in shape, open topped, and positioned indoors or outdoors at ground level. If outdoors, the test shall be conducted under the condition of essentially still air (steady wind not greater than 8 miles per hour with gusts not greater than 10 miles per hour) and no precipitation. The pan shall be fueled with 65 gallons of commercial grade n-heptane, floated on water of the depth necessary for a 6 inch freeboard.

4.6.4.2 AFFF agent. The extinguisher shall be filled to its rated capacity with 3 $\pm$ 0.05 percent of type 3 or 6 $\pm$ 0.1 percent of type 6 AFFF/freshwater solutions using AFFF qualified under MIL-F-24385.

4.6.4.3 Ignition and attack. After ignition, the test fuel is to be allowed to burn for 60 seconds before attacking the fire with the extinguisher. As the fire is attacked and extinguished, the following times are to be recorded (from time of ignition):

(a) Application of the extinguisher.
(b) Fire in pan extinguished.
(c) End of effective discharge.

Source: https://assist.dla.mil -- Downloaded: 202610-20T00:41Z
Check the source to verify that this is the current version before use.

4.6.4.4 Observations after test. After the fire has been extinguished, observations are to be made of occurrences during the test, including method of attack. Wind velocities and weather conditions are to be described for outdoor fires.

4.6.5 Environmental tests.

4.6.5.1 Shock. The charged extinguisher shall be locked in the mounting bracket (that has been mounted to a vertical wall) and then subjected to shock testing for grade A, class I, type A lightweight equipment, as specified in MIL-S-901. At the end of the shock test, the extinguisher shall stand for a minimum of 10 minutes. It shall then be held in a vertical orientation and discharged completely into a container, as evidenced by cessation of flow from the nozzle. Not less than 80 percent (by weight) of the rated agent capacity shall have been discharged.

4.6.5.2 Vibration. The charged extinguisher shall be locked in the mounting bracket and then subjected to the type I vibration test specified in MIL-STD-167-1 for shipboard equipment. At the end of the vibration test, the extinguisher shall be tested for percent discharge as done in 4.6.5.1. Not less than 80 percent (by weight) of the rated agent capacity shall have been discharged.

4.8 Inspection of packaging. Packaging, packing and marking shall be inspected to assure conformance with section 5 of this specification.

5. PACKAGING

(The preparation for delivery requirements specified herein apply only for direct Government acquisition. For the extent of applicability of the preparation for delivery requirements of referenced documents listed in section 2, see 6.4.)

5.1 Extinguisher condition. Fire extinguishers shall be shipped empty (uncharged).

5.2 Preservation. Preservation shall be level A or C as specified (see 6.2.1).

5.2.1 Level A. Fire extinguishers shall be individually unit protected in accordance with method III of MIL-P-116. Unit containers shall conform to PPP-B-636 class weather resistant type CF or SF with style selection optional to the supplier. Containers shall be closed in accordance with method V of the appendix to the container specification.

5.2.2 Level C. Fire extinguishers shall be individually unit protected as specified for level A except that unit containers may be of the domestic class and closure may conform to method I in accordance with the appendix to the container specification.

5.3 Packing. Packing shall be level A, B, C, or commercial, as specified (see 6.2.1).

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T00:41Z
Check the source to verify that this is the current version before use.

5.3.1 Level A. Fire extinguishers preserved as specified in 5.2 shall be packed in wood cleated plywood or nailed wood boxes conforming to PPP-B-601 overseas type or PPP-B-621 class 2 respectively. Boxes shall be closed and strapped in accordance with the applicable box specification or appendix thereto. The gross weight of the boxes shall not exceed the weight limitations of the applicable box specification.

5.3.1.1 Case liners. Unless otherwise specified (see 6.2.1), case liners conforming to and sealed in accordance with MIL-L-10547 shall be required for fire extinguishers preserved level C (see 5.2.2).

5.3.2 Level B. Fire extinguishers preserved as specified in 5.2 shall be packed in wood cleated plywood, nailed wood, or fiberboard boxes conforming to PPP-B-601 domestic type, PPP-B-636 class weather resistant, or PPP-B-640 class weather resistant respectively, with box style selection at the option of the contractor. Boxes shall be closed, reinforced, and strapped in accordance with the applicable box specification or appendix thereto with method V closure applicable to PPP-B-636 boxes. The gross weight of boxes shall not exceed the weight limitations of the applicable box specification.

5.3.3 Level C. Fire extinguishers preserved as specified in 5.2 shall be packed in boxes specified for level B except that containers may be of the domestic non-weather resistant type or class and box closure for fiberboard boxes shall conform to method I of the appendix to PPP-B-636.

5.4 Marking. Interior packages and exterior shipping containers shall be marked in accordance with MIL-STD-129 (see 6.2.1). Shipments offered for transportation by air shall be labeled in accordance with DOT regulation 49 CFR part 173.306(c).

5.4.1 Caution tag. The fire extinguishers covered by this specification shall not be charged when shipped. A caution tag shall be attached to each fire extinguisher prior to packaging in the unit container with the following information:

CAUTION

This fire extinguisher is not charged. Follow instructions on the nameplate for charging.

5.5 Use of loose-fill material.

5.5.1 For domestic shipment and early equipment installation and level C packaging and packing. Unless otherwise approved by the contracting activity (see 6.2.1), use of loose-fill material for domestic shipment and early equipment installation and level C packaging and packing applications such as cushioning, filler, and dunnage is prohibited. When approved, unit packages and containers (interior and exterior) shall be marked and labeled as follows:

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T00:41Z
Check the source to verify that this is the current version before use.

"CAUTION

Contents cushioned with loose-fill material.
Not to be taken aboard ship.
Remove and discharge loose-fill material before shipboard storage.
If required, recushion with cellulosic material bound fiber, fiberboard or transparent flexible cellular material."

5.5.2 For level A packaging and level A and B packing. Use of loose-fill material is prohibited for level A packaging and levels A and B packing applications such as cushioning, filler, and dunnage.

6. NOTES

6.1 Intended use. The fire extinguishers covered by this specification are intended for use on class A (common solid combustible) and class B (flammable liquid and grease) fires. They are not intended for use on class C (electrical) or class D (combustible metal) fires.

6.1.1 Extinguishing media. The extinguishers are intended to be used with a solution of aqueous film forming foam (conforming to type 3 or type 6 of MIL-F-24385) and fresh water. The contractor's authorized liquid AFFF charge, as is shipped with the unit, can be used at the contracting activity's discretion.

6.2 Ordering data.

6.2.1 Acquisition requirements. Acquisition documents should specify the following:

(a) Title, number and date of this specification.
(b) Sample for first article inspection (see 3.1 and 6.3).
(c) National Stock Number (NSN) and Allowance Parts List (APL) number (see 3.8.2).
(d) Preservation, packaging, packing or marking requirements other than those required by section 5.
(e) Level of preservation and packing (see 5.2 and 5.3).
(f) Approval for use of loose-fill material (see 5.5.1), if desired.

6.2.2 Data requirements. When this specification is used in an acquisition which incorporates a DD Form 1423, Contract Data Requirements List (CDRL), the data requirements identified below shall be developed as specified by an approved Data Item Description (DD Form 1664) and delivered in accordance with the approved CDRL incorporated into the contract. When the provisions of FAR 52.227-7031 are invoked and the DD Form 1423 is not used, the data specified below shall be delivered by the contractor in accordance with the contract or purchase order requirements. Deliverable data required by this specification is cited in the following paragraphs.

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T00:41Z
Check the source to verify that this is the current version before use.

Paragraph no.	Data requirement title	Applicable DID no.	Option
4.3.1	First article test report	UDI-T-23790	----
4.4	Certificate of compliance	DI-E-2121	----

(Data item descriptions related to this specification, and identified in section 6 will be approved and listed as such in DoD 5000.19L., Vol. II, AMSDL. Copies of data item descriptions required by the contractors in connection with specific acquisition functions should be obtained from the Naval Publications and Forms Center or as directed by the contracting officer.)

6.2.2.1 The data requirements of 6.2.2 and any task in sections 3, 4, or 5 of this specification required to be performed to meet a data requirement may be waived by the contracting/acquisition activity upon certification by the offeror that identical data were submitted by the offeror and accepted by the Government under a previous contract for identical item acquired to this specification. This does not apply to specific data which may be required for each contract regardless of whether an identical item has been supplied previously (for example, test report).

6.3 First article inspection. Invitations for bids should provide that the Government reserves the right to waive the requirement for samples for first article inspection as to those bidders offering a product which has been previously acquired or tested by the Government, and that bidders offering such products, who wish to rely on such production or test, must furnish evidence with the bid that prior Government approval is presently appropriate for the pending contract.

6.4 Sub-contracted material and parts. The preparation for delivery requirements of referenced documents listed in section 2 do not apply when material and parts are acquired by the contractor for incorporation into the equipment and lose their separate identity when the equipment is shipped.

Preparing activity:
Navy - SH
(Project 4210-N190)

U.S. GOVERNMENT PRINTING OFFICE: 1985 - 505-038/22559

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T00:41Z
Check the source to verify that this is the current version before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

(See Instructions – Reverse Side)

1. DOCUMENT NUMBER	2. DOCUMENT TITLE
MIL-E-24652(SH)	EXTINGUISHER, FIRE, AQUEOUS FILM FORMING FOAM, (AFFF), 2-1/2 GALLON

3a. NAME OF SUBMITTING ORGANIZATION	4. TYPE OF ORGANIZATION *(Mark one)*
	☐ VENDOR
b. ADDRESS *(Street, City, State, ZIP Code)*	☐ USER
	☐ MANUFACTURER
	☐ OTHER *(Specify)*: _____

5. PROBLEM AREAS

a. Paragraph Number and Wording:

b. Recommended Wording:

c. Reason/Rationale for Recommendation:

6. REMARKS

7a. NAME OF SUBMITTER *(Last, First, MI)* – Optional	b. WORK TELEPHONE NUMBER *(Include Area Code)* – Optional
c. MAILING ADDRESS *(Street, City, State, ZIP Code)* – Optional	8. DATE OF SUBMISSION *(YYMMDD)*

(TO DETACH THIS FORM, CUT ALONG THIS LINE.)

DD FORM 82 MAR 1426 PREVIOUS EDITION IS OBSOLETE.

Source: https://assist.dla.mil – Downloaded: 2026-10-20T00:41Z
Check the source to verify that this is the current version before use.