A-A-54160
5 June 1990

COMMERCIAL ITEM DESCRIPTION

RETRACTOR, VAGINAL (Sims)

The General Services Administration has authorized the use of this commercial item description as a replacement for Military Specification MIL-R-36052A which is cancelled.

This commercial item description covers a medium-sized vaginal retractor of the Sims design suitable for use in gynecological examinations and operator procedures.

Salient characteristics:

General. The retractors shall be of either one or two-piece construction The handle of the two-piece retractor may be either hollow or solid construction.

Material. Material of the retractor shall be Class 4 corrosion resistant steel in accordance with ASTM Designation F899. The handle on the two-piece retractor may be fabricated from either Class 3 austenitic stainless steel in accordance with ASTM Designation F899 or Class 4 steel.

Hardness. The retractor shall have a Rockwell Hardness C scale (HRC) of 40 to 47 for Class 4 steel and Rockwell Hardness B Scale (HRB) 75 minimum for Class 3 steel when tested in accordance with ASTM Designation E18 or E92 whichever is applicable. Conversion of hardness values shall be in accordance with ASTM Designation E140.

Style, design and dimensions. The retractor shall be in accordance with Defense Personnel Support Center (DPSC) Drawing No. 20362 for style, design and dimensions.

Finish. The retractor shall have a mirror, satin or matte finish. The matte finish shall exhibit a uniform nondirectional surface texture equivalent to that produced by lightly blasting the prepared surface with fine abrasives under pressure.

Passivation. The retractor shall be properly passivated.

AMSC N/A FSC 6515
DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:29Z
Check the source to verify that this is the current version before use.

Corrosion resistance. The retractor shall show no evidence of corrosion or plating of copper when tested in accordance with ASTM Designation F1089.

Performance The handle of the two-piece retractor shall be securely attached to the retractor blade and shank.

Identification marking and labeling. Retractors shall be legibly marked with the contractor's name or trademark and the word 'stainless' Foreign manufactured retractors shall bear the name of the country of origin.

Workmanship. The retractor shall be free from burrs, cracks, sharp edges, and other defects which detract from its appearance or impair its serviceability.

Visual and dimensional examination. Retractors shall be examined to verify that design, construction and workmanship are in accordance with applicable requirements.

Materials The supplier shall be responsible for performing tests to assure that materials are in accordance with requirements.

Unit. Each (EA). One retractor, as specified, constitutes one unit.

QUALITY ASSURANCE PROVISIONS.

Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the contractor is responsible for the performance of all inspection requirements as specified herein. Except otherwise specified in the contract or purchase order, the contractor may use his own or any facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:29Z
Check the source to verify that this is the current version before use.

Records. Records of examinations and tests performed by or for the contractor shall be maintained by the contractor and made available to the Government upon request, at any time, or from time to time, during the performance of the contract and for a period of three years after delivery of the supplies to which such records relate.

Inspection. Inspection, as used herein, is defined as both examination (such as visual or auditory investigation without the use of special laboratory appliances or procedures) and testing (determination by technical means and chemical properties) of the item.

Sampling for examination. Sampling for examination shall be conducted in accordance with MIL-STD-105, and as specified herein. Unit of product for examination purposes shall be one retractor. Sampling shall be Inspection level II with an acceptable quality level (AQL) of 1.0.

Examination. Examination shall be conducted to determine compliance with specification requirements.

Sampling for tests. Sampling for tests shall be conducted in accordance with MIL-STD-105 and as specified herein. Unit of product for test purposes shall be one retractor. Sampling shall be Inspection Level S-2 with an AQL of 1.0.

Tests. Tests shall be conducted to determine compliance with specification requirements. Where feasible, the same sample shall be used for the determination of two or more test characteristics.

Contractor certification. The contractor shall certify that the product offered meets the salient characteristics of this description and conforms to the producers' own drawings specifications, standards, and quality assurance practices. The Government reserves the right to require proof of such conformance prior to first delivery and thereafter as may be otherwise provided for under the provisions of the contract.

Metric products. Products manufactured to metric dimensions will be considered on an equal basis with those manufactured using inch-pound units, providing they fall within the tolerances specified using conversion tables contained in the lastest revision of Federal Standard No. 376, and all other requirements of this document are met.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:29Z
Check the source to verify that this is the current version before use.

If a product is manufactured to metric dimensions and those dimensions exceed the tolerances specified in the inch/pound units, a request should be made to the contracting officer to determine if the products is acceptable.

The contracting officer has the option of accepting or rejecting the product.

Regulatory requirements.

Federal Food, Drug, and Cosmetic Act. If the product covered by this document has been determined by the U.S. Food and Drug Administration to be under its jurisdiction , the offeror/contractor shall comply , and be responsible for compliance by its subcontractors/suppliers, with the requirements of the Federal Food, Drug Cosmetic Act, as amended, and regulations promulgated thereunder. In addition, the offeror/contractor shall comply, and be responsible for compliance by its subcontractors/suppliers, with the requirements of all other applicable Federal State, and local statutes, ordinances, and regulations

Recovered materials. The offeror/contractor is encouraged to use recovered material in accordance with Public Law 94-580, as amended, and as implemented by Federal Acquisition Regulation Subpart 23.4 to the maximum extent practical.

Preservation, packaging, packing, labeling, and marking. Unless otherwise specified, preservation, packaging, and packing shall be to a degree of protection to preclude damage to containers and/or contents thereof under normal shipping conditions, handling, etc., involving shipment from the supply source to the receiving activity, plus reshipment from receiving activity, and shall conform to applicable carrier's rules and regulations. Intermediate and exterior package quantities and labeling and marking shall be as specified in the contract and /or order.

NOTE: The following National Stock Number is covered by this document:

NSN	Item Identification
6515-00-361-9800	Retractor, Vaginal, Sims, Medium

Ordering data (Intermediate/exterior package quantities and labeling and marking must be specified in the contract and/or order)

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:29Z
Check the source to verify that this is the current version before use.

MILITARY INTERESTS:

Custodians:

Army-MD
Navy-MS
Air Force-03

PREPARING ACTIVITY:

DoD-MB

Agent:

DLA-DM

CIVIL AGENCY COORDINATING ACTIVITIES:

VA-OSS
PHS
FDA-MPQAS

Project No. 6515-4788

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:29Z
Check the source to verify that this is the current version before use.

INSTRUCTIONS: In a continuing effort to make our standardization documents better, the DoD provides this form for use in submitting comments and suggestions for improvements. All users of military standardization documents are invited to provide suggestions. This form may be detached, folded along the lines indicated, taped along the loose edge *(DO NOT STAPLE)*, and mailed. In block 5, be as specific as possible about particular problem areas such as wording which required interpretation, was too rigid, restrictive, loose, ambiguous, or was incompatible, and give proposed wording changes which would alleviate the problems. Enter in block 6 any remarks not related to a specific paragraph of the document. If block 7 is filled out, an acknowledgement will be mailed to you within 30 days to let you know that your comments were received and are being considered.

NOTE: This form may not be used to request copies of documents, nor to request waivers, deviations, or clarification of specification requirements on current contracts. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document*(s)* or to amend contractual requirements.

(Fold along this line)

(Fold along this line)

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE $300

BUSINESS REPLY MAIL
FIRST CLASS PERMIT NO 4966 Alexandria, VA

POSTAGE WILL BE PAID BY

Commander
Defense Personnel Support Center
ATTN: DPSC-RSTS
2800 South 20th Street
Philadelphia, Pennsylvania 19101-8419

NO POSTAGE
NECESSARY
IF MAILED
IN THE
UNITED STATES

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:29Z
Check the source to verify that this is the current version before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

(See Instructions – Reverse Side)

1. DOCUMENT NUMBER	2. DOCUMENT TITLE
A-A-54160	RETRACTOR, VAGINAL (Sims)

3a. NAME OF SUBMITTING ORGANIZATION	4. TYPE OF ORGANIZATION (*Mark one*)
	☐ VENDOR
b. ADDRESS (*Street, City, State, ZIP Code*)	☐ USER
	☐ MANUFACTURER
	☐ OTHER (*Specify*) _____

5. PROBLEM AREAS

a. Paragraph Number and Wording

b. Recommended Wording

c. Reason/Rationale for Recommendation

6. REMARKS

7a. NAME OF SUBMITTER (*Last, First, MI*) – Optional	b. WORK TELEPHONE NUMBER (*Include Area Code*) – Optional
c. MAILING ADDRESS (*Street, City, State, ZIP Code*) – Optional	8. DATE OF SUBMISSION (*YYMMDD*)

DD FORM 1426 PREVIOUS EDITION IS OBSOLETE

Source: https://assist.dla.mil - Downloaded: 2026-10-26T09:29Z
Check the source to verify that this is the current version before use.