INCH-POUND

MIL-P-26795C (USAF)
02 Nov 90
SUPERSEDING
MIL-P-26795B (USAF)
11 September 1963

MILITARY SPECIFICATION

PUMP, ROTARY, POWER DRIVEN, 40 GPM CAP., TWO WHEELED HAND CART, TYPE MC-1

This specification is approved for use within the Department of the Air Force and is available for use by all Departments and Agencies of the Department of Defense

1. SCOPE

1.1 This Specification covers one type of two-wheeled hand cart, 40 gpm capacity, power driven, extinguishing agent transfer rotary pump, designated type MC-1.

2. APPLICABLE DOCUMENTS

2.1 Government Document

2.1.1 Specifications standards and handbooks. The following specification, standards, and handbooks form a part of this specification to the extent specified herein. Unless otherwise specified, the issues of these documents shall be those listed in the issue of the Department of Defense Index of Specifications and Standards (DODISS) and supplement thereto, cited in the solicitation (see 6.2).

SPECIFICATIONS

FEDERAL

PPP-B-585	Boxes, Wood, Wirebound
PPP-B-591	Boxes, Fiberboard, Wood-Cleated
PPP-B-601	Boxes, Wood, Cleated-Plywood
PPP-B-621	Boxes, Wood Nailed and Lock-Corner.
PPP-B-636	Boxes, Fiberboard
PPP-T-60	Tape, Pressure Sensitive, Waterproof for Packaging and Sealing
ZZ-H-500	Hose, Rubber and Hose Assemblies, Rubber: Pneumatic (yarn or fabric reinforced)

Beneficial comments (recommendations, additions, deletions) and any pertinent data which may be of use in improving this document should be addressed to: WR-ALC/MMDETB,Robins AFB,GA. 31098-5609, by using the self-addressed Standardization Document Improvement Proposal (DD Form 1426) appearing at the end of this document or by letter.

AMSC N/A FSC 4320

DISTRIBUTION STATEMENT A: Approved for public release; distribution is unlimited

Source: https://assist.dla.mil -- Downloaded: 202610-20T10:22Z
Check the source to verify that this is the current version before use.

MILITARY

MIL-T-152	Treatment, Moisture and Fungus Resistant, of Communications, Electronics, and Associated Electrical Equipment
MIL-P-160	Preservation, Methods of
MIL-L-1054	Liners, Case, and Sheet Overwrap, Water/Vaporproof or Waterproof, Flexible
MIL-C-3432	Cable and Wires, Electrical (Power and Control, Flexible and Extra Flexible, 300 and 600 volts)
MIL-W-8005	Wheels and Hubs for Industrial Pneumatic Tires
MIL-F-24385	Fire Extinguishing, Agent, Aqueous Film Forming Foam (AFFF) Liquid Concentrate, Six Percent, for Fresh and Seawater
MIL-H-52544	Hose, Rubber; Oil Suction, Wire reinforced

STANDARDS

MILITARY

MIL-STD-129	Marking For Shipment and Storage
MIL-STD-130	Identification Marking of U.S. Military Property
MIL-STD-461	Electromagnetic Interference Characteristics, Requirements for Equip ment
MIL-STD-808	Finishes, Protective and Codes for Finishing Schemes for Ground and Ground Support Equipment
MIL-STD-810	Environmental Test Methods for Aerospace and Ground Equipment
MIL-STD-831	Test Reports, Preparation of
MIL-STD-882	System Safety Program, for Systems and Associated Subsystems and Equipment, Requirements for
MIL-STD-889	Metals, Definitions of Dissimilar
MIL-STD-970	Specifications and Standards, Order of Precedence for the Selection of
MS 24217	Cable Assembly - Power, Electrical, 28 Volt DC Power
MS 51336	Lunette-Coupler, Drawbar, Ring

(Unless otherwise indicated, copies of the federal and military specifications, standards, and handbooks are available from the Standardization Documents Order Desk, Building 4D, 700 Robbins Ave., Philadelphia, PA 19111-5094.)

2.1.2 Other Government documents, drawings, and publications. The following other Government documents, drawings, and publications form a part of this document to the extent specified herein. Unless otherwise specified, the issues are those cited in the solicitation.

DRAWINGS

US AIR FORCE

8838302	Fastener Quality Assurance Requirements for WR-ALC/MMV Vehicle and Support Equipment

(Application for copies should be addressed to WR-ALC/MMDEC, Robins AFB, GA 31098-5609 .)

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T10:22Z
Check the source to verify that this is the current version before use.

NATIONAL BUREAU OF STANDARDS

Handbook H28 Screw Thread Standards for Federal Services

(Application for copies should be addressed to the Defense Industrial Supply Center, Attn: DISC-ES, 700 Robbins Ave., Phila., PA. 19111)

DEPARTMENT OF LABOR, OCCUPATIONAL SAFETY AND HEALTH ADMINISTRATION

Occupational Safety and Health Act (OSHA) with Supplemental Revisions

(Application for copies should be addressed to the Superintendent of Documents, U.S. Government Printing Office, Washington, D.C. 20402).

2.2 Order of precedence. In the event of a conflict between the text of this document and the references cited herein the text of this document shall take precedence. Nothing in this document, however, supersedes applicable laws and regulations unless a specific exemption has been obtained.

3. REQUIREMENTS

3 1 First Article. This specification makes provisions for first article testing.

3.2 Components. The pumping unit (see 6.3) shall consist of the following:

Item No.	Quantity	Item Name	See Requirement
1	1	Pump	3 7
2	2	Hose	3.8
3	1	Pump Relief Valve	3.9
4	1	Motor	3.10
5	1	Hand Cart	3.11

3.3 Selection of specifications and standards. Specifications and standards for necessary commodities and services not specified herein shall be selected in accordance with MIL-STD-970.

3.4 MATERIALS

3.4.1 Protective treatment. When materials are used in the construction of the pumping unit that are subject to deterioration when exposed to climatic and environmental conditions likely to occur during service usage, they shall be protected against such deterioration in a manner that will in no way prevent compliance with the performance requirements of this purchase description. The use of any protective coating that will crack, chip, or scale with age or extremes of climatic and environmental conditions shall be avoided.

3.4.2 Dissimilar metals. Unless suitably protected against electrolytic corrosion, dissimilar metals shall not be used in intimate contact with each other (particularly brass, copper, or steel in contact with aluminum or aluminum alloy). However, metal plating or metal spraying will be permitted. The use of dissimilar metals separated by suitable insulating material will also be permitted. Dissimilar metals are as defined in MS33586.

3.4.3 Materials of construction. The pump shall be constructed of bronze with stainless steel fittings throughout. All couplings shall be of bronze and the sight glass (see 3.8.2) shall be of bronze.

3.4.3.1 Fasteners. All fasteners of Grade 5 or higher (as defined by SAE J-429) shall meet the quality assurance requirements of US Air Force Drawing No. 8838302.

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T10:22Z
Check the source to verify that this is the current version before use.

3.5 Design and construction. The pumping unit shall be so designed and constructed that no parts will work loose in service. It shall be built to withstand the strains, jars, vibrations, and other conditions incident to shipping, storage, and service.

3.5.1 Components. All components shall be waterproofed and so designed that their normal functioning will not be impaired by entrance of casual water during heavy rains, as formed by condensation or resulting from spillage of extinguishing agents. The components shall also be designed to effectively resist any harmful effects of dust and fungi.

3.5.2 Reliability. The pumping unit shall have a minimum MTBF of 250 hours.

3.5.3 Maintainability. The pumping unit shall be designed and constructed as specified herein and to provide the following:

a. Minimum number of parts consistent with reliability and performance specified herein.

b. Minimum amount of training and time necessary for assembly, disassembly, location of trouble sources, and maintenance including servicing. Where practical, parts and components shall be located or positioned for rapid and simple inspection and recognition of excessive wear or potential failure.

c. Permit adjustments, servicing, replacement of parts and components, and other maintenance with minimum disturbance to other equipment parts or components. Parts and components shall be located for ample and rapid access unless performance or reliability will be appreciably degraded by the accessible location. In performing maintenance, if engineering reasoning or data determines that physical and visual interference between items cannot be avoided, the item predicted to require the most maintenance shall be located for best accessibility.

d. Permit maintenance with general-purpose tools and equipment normally available commercially. Use of special-purpose tools and equipment shall be subject to approval by the procuring activity.

e. Minimum number of tools required for maintenance by design practices such as reducing the variety of bolt head sizes to the practicable minimum.

f. Where improper installation of an item could cause malfunction of the item or the equipment in which it is installed, an unsymmetrical mounting means shall be provided where practical. That mounting shall allow the item to be installed only in its proper operating position. If an unsymmetrical mounting means is not practical, the item shall be so mounted that its proper operating position can be readily and visibly determined by service maintenance personnel.

3.5.4 Lubrication. Where practicable, permanently lubricated (lubricated-for-life) components, or units not requiring lubrication, shall be utilized. Design of grease and oil seals shall provide maximum accessibility for replacement. Where feasible, all components subject to wear shall be properly lubricated and renewable. All lubrication fittings shall be readily accessible for servicing.

3.5.5 Guards and cover plates. Dangerously exposed moving parts shall be protected with guards. Protective covers shall be placed over all parts of the pumping unit where the need exists for protection against weather, dirt, or agent corrosive action.

3.5.6 Safety. Provisions for the safety of personnel shall be incorporated to the maximum extent possible with regard to anticipated operating conditions and the capability of operating personnel. The unit shall be free of Category III and Category IV hazards as determined in accordance with MIL-STD-882. Equipment must be consistent with applicable "OSHA" standards.

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T10:22Z
Check the source to verify that this is the current version before use.

3.6 Performance. The pumping unit shall be capable of operating satisfactorily in either a vertical or horizontal position under the following conditions:

a. Storage temperature ranging from -50°F to +160°F.

b. Operating temperatures ranging from +32°F to +125°F, pumping foam liquid (MIL-F-24385) at a rate of not less than 40 gpm.

c. Dry operation for a period of one hour under suction lift of ten inches Hg.

d. Relative humidity up to 100 percent including conditions wherein condensation takes place in the form of both water and frost.

e. Exposure to salt sea atmosphere.

3. 6. 1 Mobility. The pumping unit shall be towable at speeds up to 15 MPH over a level, paved surface.

3.7 Pumps. The pump shall be of the positive displacement or self-priming centrifugal type, and shall be directly coupled with or without gear reduction to the motor. The pump shall be of adequate capacity to meet the performance requirements specified herein and shall be designed to withstand a static test case pressure of 30 psi. The intake and discharge parts of the pump shall be provided with fittings for attaching the intake and discharge hoses.

3.8 Hose. All hoses shall be 1-1/2 inch diameter and shall conform to MIL-H-52544 for suction hose and ZZ-H-500 for discharge hose.

3.8.1 Intake hose. The intake hose shall be 15 feet in length and shall be provided with the appropriate couplings on either end. One end of the intake hose shall be fitted to a pickup tube to be inserted through the 1-1/2 inch diameter bunghole of either a 5 or 55 gallon shipping drum. A 10 mesh screen shall be provided in the pickup tube to prevent foreign matter from being drawn through the pump. The screen shall not interfere with normal operation of the pump. The pickup tube and screen shall be long enough to reach the bottom of a 55 gallon drum. The near end of the pickup tube shall be attached to a 90 degrees bronze elbow, which in turn is fitted to the suction hose.

3.8.2 Discharge hose. The discharge hose shall be 25 feet in length and shall be used to connect to the fill line of agent tanks on aircraft fire-fighting trucks; or, if so desired, top fill through the truck manhole. The pump end of the hose shall be provided with a sight glass to assist in determining when flow of agent is obtained. The sight glass shall be equipped with a petcock for elimination of air from the system. When specified, (see 6.2) a coupling, 1-1/2 inch NH external thread, in accordance with Handbook H28, shall be provided and fitted on the delivery end of the hose.

3.9 Pump relief valve. A bypass pressure-relief valve shall be provided on the pump to assure against damage to the system in the event of valve failure in the agent system. Relief valve setting shall be 25 PSI -10, +0.

3.10 Motor. A 28-V d-c compound wound, totally enclosed, weatherproof motor shall be coupled to the pump. The motor shall be of the ball bearing type and shall be provided with A-J tropical insulation treatment in accordance with MIL-T-152. The temperature rise of the motor shall not exceed 130 degrees F on continuous operation under rated load conditions.

3.10.1 Power cable. The pumping unit shall be provided with a 20-foot, 2 No. 10 AWG electric cable conforming to MIL-C-3432, class HD or commercial type SO, and having an MS25488 connector head molded to one end of the cable and the end connected to the motor equipped with terminals per MS25036.

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T10:22Z
Check the source to verify that this is the current version before use.

3.10.2 Motor control cable. The motor shall be controlled by a doublepole, single-throw momentary contact, normally off switch mounted at the end of a 15-foot, No. 10 AWG conductor, electric cable conforming to MIL-C-3432, class HD or commercial type SO. The switch shall be totally weatherproof and shall be of such design that it may be operated by personnel wearing heavy arctic mittens.

3.11 Hand cart. A two-wheel hand cart shall be provided for easy transportation of the pumping unit which shall be permanently bolted to the cart. The cart shall have pneumatic tires, wheels, hubs of at least 4.00-8 size conforming to MIL-W-8005. The handle of the cart shall be provided with a lunette coupler conforming to MS51336 to facilitate transportation when connected to the pintle hook of a vehicle.

3.11.1 Hose and electric cord storage. Racks shall be provided on the hand cart for the storage of all hose and electrical cord. The storage racks shall be so located and designed that the hoses and cords are easily removed and interference is avoided between the ground and components when the cart is in either a vertical or horizontal position.

3.12 Part numbering of interchangeable parts. All parts having the same manufacturer's part number shall be functionally and dimensionally interchangeable.

3.13 Electromagnetic interference. The pumping unit shall comply with the requirements of MIL-STD-461, Class C3.

3.14 Dimensions.

3.14.1 Height. With the cart in the horizontal position (lunette coupler on the ground), the overall height of the pumping unit shall not exceed 27 inches.

3.14.2 Length. The overall length of the cart shall not exceed 50 inches.

3.14.3 Width. The width of the pumping unit shall not exceed 27 inches.

3.15 Weight. The entire assembly, including all required hoses, electric cables and connections, pump, motor hand cart, and the pickup tube, shall not exceed 310 pounds. The weight of the unit shall be so distributed that 85 +5 -0 percent will be on the main wheels and the eighth remaining weight will be on the lunette coupler while the unit is in a towing position with the lunette coupler 20 +10 -0 inches above the ground.

3.16 Finishes and protective coatings. Cleaning, painting, plating, anodic films, and chemical treatments shall be in accordance with MIL-STD-808. When used, aluminum alloys shall have exterior and interior surfaces anodically treated, and steel parts that come into direct contact with the agent, with the exception of the stainless steel, shall have exterior and interior surfaces cadmium plated. Insignia red paint, film designation BG, shall be used on all parts of equipment normally painted in good commercial practice .

3.17 Identification of product. Equipment, assemblies, and parts shall be marked for identification in accordance with MIL-STD-130.

3.18 Workmanship. The pumping unit, including all parts and accessories, shall be fabricated an finished in a thoroughly workmanlike manner. Particular attention shall be given to freedom from blemishes, defects, burrs and sharp edges; marking of parts and assemblies; thoroughness of soldering, welding, brazing, plating, wiring, and riveting; alignment of parts and tightness of assembly screws and bolts; et cetera .

3.18.1 Casting. Castings shall be of high-grade quality, clean, sound, and free from blow holes, porosity, cracks, and any other defects.

Source: https://assist.dla.mil -- Downloaded: 202610-20T10:22Z
Check the source to verify that this is the current version before use.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the contractor is responsible for the performance of all inspection requirements (examinations and tests) as specified herein. Except as otherwise specified in the contract or purchase order, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in this specification where such inspections are deemed necessary to ensure supplies and services conform to prescribed requirements.

4.1.1 Responsibility for compliance. All items must meet all requirements of sections 3 and 5. The inspection set forth in this specification shall become a part of the contractor's overall inspection system or quality program. The absence of any inspection requirements in the specification shall not relieve the contractor of the responsibility of assuring that all products or supplies submitted to the Government for acceptance comply with all requirements of the contract. Sampling in quality conformance does not authorize submission of known defective material, either indicated or actual, nor does it commit the Government to acceptance of defective material.

4.2 Classification of inspections. The inspection requirements specified herein are classified as follows:

a. First article inspection (see 4.4).

b. Quality conformance inspection (see 4.5).

4.3 Inspection conditions. Unless otherwise specified, all inspections shall be performed in accordance with the test conditions specified herein.

4.3.1 Agent. Agent conforming to MIL-F-24385 shall be used during the tests.

4.3.2 Preparation for tests. The pumping unit submitted for test shall be properly prepared for operation. The pumping unit shall be in correct adjustment, lubricated, and serviced for immediate operation.

4.3.3 Data. During the testing specified herein, at least the following data shall be recorded on log sheets at 1/4 hour intervals, except where shorter intervals are a test requirement. This data shall be included in the test report.

Date_____

Time_____ hours

Ambient Temperature_____ F

Head_____feet of foam liquid or_____ psi

Agent delivery rate_____ gpm

Agent temperature_____

Potential_____ volts

Current_____ amperes

Source: https://assist.dla.mil -- Downloaded: 202610-20T10:22Z
Check the source to verify that this is the current version before use.

4.3.3.1 Notes. Notes shall be placed on the log sheets of all incidents of the tests, such as adjustments made, servicing performed, leaks, vibrations, electrical shorts, and any other irregular functioning of the pumping unit or its components and the corrective measures taken.

4.3.4 Test time. Intervals of endurance test time less than one hour terminated by a parts failure shall not be credited to the endurance test. Endurance test time shall be credited in 1/2 hour intervals.

4.4 First Article Inspection. The pumping unit shall be subjected to the tests specified herein.

4.4.1 Test sample. One pumping unit shall be subjected to the tests specified in 4.4.3.

4.4.2 Reliability and maintainability information. The following information shall be submitted as an attachment accompanying the first article test report (same quantity and type of copies) or shall be included as part of that report:

a. All failures, maintenance, and other events recorded shall be identified by operating time, miles, cycles or position in the test procedure as appropriate. Test conditions during the failures or irregular operations identified shall be recorded.

b. Description of the engineering reasoning and of any tests conducted to determine assignable causes for all failures and irregular operations identified.

c. Description of the engineering reasoning verifying corrections made, to be made on production items, or proposed to be made that substantiate the predicted effectiveness of those corrections.

d. Test activity or contractor comments on item features or requirements that, if modified, should improve the items.

e. Test activity or contractor comments on field conditions or procedure to be avoided or cultivated to increase the reliability and useful life of the item.

f. Estimates (+ or -5 percent of actual experienced) of man-hours required for each maintenance and servicing action during the tests. A brief description of the qualifications and experience of the personnel involved shall be included and shall be adequate to permit comparison to the personnel anticipated in similar fieldwork.

4.4.3 First Article tests. The first article tests shall consist of all the tests described under 4.6.

4.5 Quality Conformance Inspection. The Quality Conformance Inspection shall include the tests of 4.5.1 and the sampling of 4.5.2.

4.5.1 Test. Each pumping unit shall be subjected to an examination of product test as described under 4.6.1.

4.5.2 Sampling.

4.5.2.1 Lot. A lot shall consist of pumping units manufactured under essentially the same conditions, or the same material, and submitted for inspection at substantially the same time.

4.5.2.2 Sampling plan. One pumping unit shall be selected at random from each lot of 25 or fraction thereof, produced and subjected to the following tests:

a. Performance demonstration_____ (See 4.6.2.)

b. Static pressure_____ (See 4.6.3.)

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T10:22Z
Check the source to verify that this is the current version before use.

4.5.2.2.1 Rejection and retest. When one or more items from a lot fail to meet the specification, acceptance of all items in the lot will be withheld until the extent and cause of failure are determined. After corrections have been made, all necessary tests shall be repeated.

4.5.2.2.2 Individual tests may continue. For production reasons, individual tests may be continued pending the investigation of a sampling test failure. Final acceptance of the entire lot shall not be made until it is determined that the lot meets all the requirements of the specification.

4.5.3 Defects in items already accepted. The investigation of a test failure could indicate that defects may exist in items already accepted. If so, the contractor shall fully advise the procuring activity of all defects likely to be found and methods of correcting them.

4.6 Methods of inspection.

4.6.1 Examination of product. The pumping unit shall be inspected to determine compliance with the requirements specified herein with respect to materials, workmanship, dimensions and marking. The dimensions, weight, and weight distribution shall be recorded and shall comply with the requirements specified in 3.14 and 3.15.

4.6.2 Performance demonstration. The performance of the pump shall be demonstrated by pumping foam liquid (MIL-F-24385) within the temperature range of 32° to 125° until 200 gallons of the foam liquid has been delivered. The pump head shall be maintained at 12 feet of agent. Under these conditions, the pumping unit shall demonstrate ability to deliver foam liquid as specified in 3.6. Equivalent pressure of 5.25 psi, for feet of foam liquid.

4.6.3 Static pressure. The pump shall be removed from the assembly. The outlet of the pump shall be plugged and air, at a pressure of 30 psi, shall be applied to the pump inlet. With the pump submerged in water, no appreciable air leakage shall be exhibited over a 15 minute period.

4.6.4 Initial disassembly examination. The pumping unit shall be disassembled to the maximum practical extent, and the condition of its parts shall be recorded. Measurements shall be; made and recorded with regard to those parts that are subject to wear or distortion during testing.

4.6.5 Dry operation. The pump shall be dry operated for a period of one hour. A dry suction lift of ten inches of Hg shall be maintained during this period.

4.6.6 Road test. The pumping units shall be towed behind a vehicle at speeds up to 15 mph for a total distance of 50 miles. A record shall be kept of any signs of instabilities. Any sign of material failure at the completion of this test shall be cause for rejection.

4.6.7 Environmental tests. The following environmental tests shall be conducted in accordance with the specified methods of MIL-STD-810. While the specified operating temperature is maintained, the tests specified in 4.6.2 shall be conducted.

a. High Temperature	Method 501
b. Low Temperature	Method 502
c. Humidity	Method 507
d. Salt Fog	Method 509

4.6.8 Endurance. The pumping unit shall be operated for a period of 250 hours pumping foam liquid. The head shall be maintained at 12 feet of foam liquid. The operation shall be interrupted a minimum of

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T10:22Z
Check the source to verify that this is the current version before use.

four times with a minimum period of 50 hours between each interruption. The pump shall be drained or pumped dry and allowed to dry out. After pumping foam liquid, the pump may be flushed with water prior to allowing it to dry out. The operation shall begin again, and the pump shall demonstrate its self-priming ability. Upon completion of the test specified in 4.6.8, the pump shall successfully complete the test specified in 4.6.3. The pump shall be capable of maintaining a dry suction lift of 10 inches Hg.

4.6.9 Final disassembly inspection. Upon completion of all testing, the pumping unit shall be disassembled to the maximum practical extent and examined. Parts subject to wear or distortion shall be measured or otherwise dimensionally inspected, and the measurements shall be compared with similar data, compiled prior to the start of the prescribed testing, for determination of wear or distortion. All parts shall be in acceptable condition.

4.6.10 Electromagnetic interference. The pumping unit shall be tested in accordance with the interference control requirements specified in MIL-STD-461, Class C3.

4.6.11 Reliability demonstration and test. Satisfactory completion without a failure of all tests specified herein demonstrates compliance with the quantitative reliability requirements of this specification.

4.6.12 Maintainability evaluation. The pumping unit shall be inspected and evaluated from the standpoint of ease of maintenance, servicing, and operation. Particular attention shall be given maintenance with a minimum number of common tools, servicing, and operation by personnel wearing heavy gloves, and provisions made to prevent accumulation of dirt, snow, ice, et cetera, that may hinder servicing and operation.

4.7 Inspection of packaging. The inspection of the preservation, packaging, packing and marking shall be in accordance with the instructions of section 5 herein.

5. PACKAGING

5.1 Preservation and packaging.

5.1.1 Level A. The pumping unit shall be preserved in accordance with MIL-P-116, Method 1. The electric motor and controls shall be preserved in accordance with MIL-P-116, Method 11.

5.1.2 Level C. The pumping unit shall be preserved and packaged in accordance with manufacturer's commercial practice.

5.2 Packing.

5.2.1 Level A. The pumping unit, preserved and packaged as specified in 5.1.1, shall be packed in exterior-type shipping containers conforming to PPP-B-585, PPP-B-591, PPP-B-601, PPP-B-621 and PPP-B-636. As far as practical, exterior containers shall be of uniform shape and size, or minimum cube and tare consistent with the protection required, and contain identical quantities. The gross weight of each pack shall be limited to approximately 200 pounds. Containers shall be closed and strapped in accordance with the applicable container specification or the appendix thereto. Containers shall be provided with a case liner conforming to MIL-L-10547 and shall be sealed in accordance with the appendix thereto. As an alternate method, containers conforming to PPP-B-636 may be sealed at all joints and seams with tape conforming to PPP-T-60.

5.2.2 Level B. The pumping unit, preserved and package as specified in 5.1.1 or 5.1.2, shall be packed in domestic-type exterior containers conforming to PPP-B-585, PPP-B-591 or PPP-B-601. Exterior containers shall be of minimum cube and tare consistent with the protection required. As far as practical,

Source: https://assist.dla.mil Downloaded: 2026-10-20T10:22Z
Check the source to verify that this is the current version before use.

exterior container shall be of uniform shape and size and shall contain identical quantities. The gross weight of each pack shall be limited to approximately 500 pounds. Containers shall be closed and strapped in accordance with the applicable container specification or the appendix thereto. Containers shall be provided with a case liner conforming to MIL-L-10547 and shall be sealed in accordance with the appendix thereto. As an alternate method, containers conforming to PPP-B-636 may be sealed at all joints and seams with tape conforming to PPP-T-60.

5.2.3 Level C. Packages which require overpacking for acceptance by the carrier shall be packed in exterior-type shipping containers in a manner that will insure safe transportation, at the lowest rate, to the point of delivery. Containers shall meet Consolidated Freight Classification Rules or regulations of other common carriers as applicable to the mode of transportation.

5.3 Marking. Interior and exterior containers shall be marked in accordance with MIL-STD-129. The nomenclature shall be as follows:

Pump, Rotary, Power Drive, 40 GPM Cap, Two Wheeled Hand Cart, Type MC-1.

6. NOTES

(This section contains information of a general or explanatory nature that may be helpful, but is not mandatory.)

6.1 Intended use. The type MC-1 pumping unit is intended for use in the field for transferring foam liquid from drums to crash fire fighting trucks.

6.2 Acquisition requirements. Acquisition documents must specify the following:

a. Title, number, and date of the specification.

b. Issue of DODISS to be cited in the solicitation, and if required, the specific issue of individual documents referenced (see 2.1).

c. Applicable levels of preservation, packaging and packing.

6.3 Definitions.

6.3.1 Since the official nomenclature designates the end items as a pump and one of the components is called a pump, the term "pumping unit" will be used herein where reference is made to the complete end item, and the term "pump" will be used only when referring to the component.

6.3.2 Mean-time-between-failures. The mean life or mean-time-between-failures is the arithmetical mean (average) of the operating time between failures.

6.3.3 Mission time. Mission time is the time the pumping unit is operated in transferring foam liquid from drum to crash fire-fighting trucks.

6.4 First Article. When first article inspection is required, the contracting officer should provide guidance to offerors whether the item(s) should be a preproduction sample, a first article sample, a first production item, a sample selected from the first production items, a standard production item from the contractors current inventory (see 3.1), and the number of items to be tested as specified in 4.4.1. The contracting officer should also included specific instructions in acquisition documents regarding arrangements for examinations, approval of first article test results, and disposition of first articles. Invitations for bids should provide that the Government reserves the right to waive the requirement for samples for first article inspection to those bidders offering a product which has been previously acquired or tested by the Government, and that bidders offering such products, who wish to rely on such production or test, must

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T10:22Z
Check the source to verify that this is the current version before use.

furnish evidence with the bid that prior Government approval is presently appropriate for the pending contract. Bidders should not submit alternate bids unless specifically requested to do so in the solicitation.

6.5 Test report. A test report will be required as specified in the contract or purchase order.

6.6 Consideration of data requirements. The following data requirements should be considered when this specification is applied on a contract. The applicable Data Item Descriptions (DID's) should be reviewed in conjunction with the specific acquisition to ensure that only essential data are requested/ provided and that the DID's are tailored to reflect the requirements of the specific acquisition. To ensure correct contractual application of the data requirements, a Contract Data Requirements List (DD Form 1423) must be prepared to obtain the data, except where DOD FAR Supplement 27.475.-1 exempts the requirement for a DD Form 1423.

Reference Paragraph	DID Number	DID Title
6.5	UDI-T-23790	First article inspection report

6 .7 Subject term (key word) listing.

Pump, power driven,
Pump, 40 GPM
Pump, extinguishing agent transfer
Pump, type MC-1
Pump, two-wheeled hand cart
Pump, 28 volt electric

6 .8 Change from previous issue. Marginal notations are not used in this revision to identify changes with respect to the previous issue due to the extensiveness of the changes.

Custodian:
Air Force - 99

Preparing activity
Air Force - 84

(Project 4320-F274)

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T10:22Z
Check the source to verify that this is the current version before use.

INSTRUCTIONS: In a continuing effort to make our standardization documents better, the DoD provides this form for use in submitting comments and suggestions for improvements. All users of military standardization documents are invited to provide suggestions. This form may be detached, folded along the lines indicated, taped along the loose edge *(DO NOT STAPLE)*, and mailed. In block 5, be as specific as possible about particular problem areas such as wording which required interpretation, was too rigid, restrictive, loose, ambiguous, or was incompatible, and give proposed wording changes which would alleviate the problems. Enter in block 6 any remarks not related to a specific paragraph of the document. If block 7 is filled out, an acknowledgement will be mailed to you within 30 days to let you know that your comments were received and are being considered.

NOTE: This form may not be used to request copies of documents, nor to request waivers, deviations, or clarification of specification requirements on current contracts. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document*(s)* or to amend contractual requirements.

(Fold along this line)

(Fold along this line)

FICIAL BUSINESS
NALTY FOR PRIVATE USE $300

NO POSTAGE
NECESSARY
IF MAILED
IN THE
UNITED STATES

BUSINESS REPLY MAIL
FIRST CLASS PERMIT NO. 4966 Alexandria, VA

POSTAGE WILL BE PAID BY

WR-ALC/MMDEIB
ROBINS AFB, GA 31098-5609

Source: https://assist.dla.mil -- Downloaded: 202640-20T10:22Z
Check the source to verify that this is the current version before use.

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T10:22Z
Check the source to verify that this is the current version before use.