A-A-54220
20 July 1990

COMMERCIAL ITEM DESCRIPTION

CLAMP, ARTERY, DeBakey, Angular Jaws, 7 Inch

The General Services Administration has authorized the use of this commercial item description.

This commercial item description covers a 7 inch (overall length) angular jaws peripheral artery clamp of the DeBakey design suitable for temporary occlusion of the femoral, popliteal, subclavian and carotid arteries during performance of thromboendorterectomy or application of a by-pass graft

Salient characteristics:

General Shall be a peripheral vascular clamp, of the Debakey design with angled, serrated jaws.

Material Material of the clamp shall be Class 4 corrosion-resistant steel in accordance with ASTM Designation F899

Style, design and dimensions The clamp shall be shall be in accordance with Defense Personnel Support Center (DPSC) Drawing No 20903 for style, design and dimensions

Hardness Clamps shall have a Rockwell Hardness C scale (HRC) of 38 to 47 when tested in accordance with ASTM Designation E18 or E92 whichever is applicable Conversion of hardness values shall be in accordance with ASTM Designation E140

Finish Clamps shall have a satin or matte finish The matte finish shall exhibit a uniform nondirectional surface texture equivalent to that produced by lightly blasting the prepared surface with fine abrasives under pressure.

Passivation Clamps shall be properly passivated.

Corrosion resistance Clamps shall show no evidence of corrosion or plating of copper when tested in accordance with ASTM Designation F1089

AMSC N/A FSC 6515

DISTRIBUTION STATEMENT A Approved for public release, distribution is unlimited

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:31Z
Check the source to verify that this is the current version before use.

Identification marking and labeling Clamps shall be legibly marked with the contractor's name or trademark and the word "stainless" Foreign manufactured clamps shall bear the name of the country of origin

Workmanship. Clamps shall be processed in such a manner as to be uniform and free from cracks, pits, burrs, sharp edges, scale, rough areas, corrosion

Visual and dimensional examination Clamps shall be examined to verify that design, construction and workmanship are in accordance with applicable requirements.

Materials The supplier shall be responsible for performing tests to assure that materials are in accordance with requirements

Unit Each (EA) One clamp, as specified, constitutes one unit

QUALITY ASSURANCE PROVISIONS.

Responsibility for inspection Unless otherwise specified in the contract or purchase order, the contractor is responsible for the performance of all inspection requirements as specified herein. Except otherwise specified in the contract or purchase order, the contractor may use his own or any facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements

Records Records of examinations and tests performed by or for the contractor shall be maintained by the contractor and made available to the Government upon request, at any time, or from time to time, during the performance of the contract and for a period of three years after delivery of the supplies to which such records relate

Inspection Inspection, as used herein, is defined as both examination (such as visual or auditory investigation without the use of special laboratory appliances or procedures) and testing (determination by technical means of physical and chemical properties) of the item

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:31Z
Check the source to verify that this is the current version before use.

Sampling for examination Sampling for examination shall be conducted in accordance with MIL-STD-105, and as specified herein Unit of product for examination purposes shall be one clamp Sampling shall be inspection level II with an acceptable quality level (AQL) of 1 0

Examination Examination shall be conducted to determine compliance with specification requirements

Sampling for tests Sampling for tests shall be conducted in accordance with MIL-STD-105 and as specified herein Unit of product for test purposes shall be one clamp. Sampling shall be inspection level S-2 with an AQL of 1.0

Tests Tests shall be conducted to determine compliance with specification requirements Where feasible, the same sample shall be used for the determination of two or more test characteristics

Contract certification. The contractor shall certify that the product offered meets the salient characteristics of this description and conforms to the producers' own drawings, specifications, standards, and quality assurance practices The Government reserves the right to require proof of such conformance prior to first delivery and thereafter as may be otherwise provided for under the provisions of the contract

Metric products Products manufactured to metric dimensions will be considered on an equal basis with those manufactured using inch-pound units, providing they fall within the tolerances specified using conversion tables contained in the lastest revision of Federal Standard No 376, and all other requirements of this document are met

If a product is manufactured to metric dimensions and those dimensions exceed the tolerances specified in the inch/pound units, a request should be made to the contracting officer to determine if the product is acceptable

The contracting officer has the option of accepting or rejecting the product

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:31Z
Check the source to verify that this is the current version before use.

Regulatory requirements

Federal Food, Drug, and Cosmetic Act If the product covered by this document has been determined by the U S Food and Drug Administration to be under its jurisdiction, the offeror/contractor shall comply, and be responsible for compliance by its subcontractors/suppliers, with the requirements of the Federal Food, Drug Cosmetic Act, as amended, and regulations promulgated thereunder In addition, the offeror/contractor shall comply, and be responsible for compliance by its subcontractors/suppliers, with the requirements of all other applicable Federal State, and local statutes ordinances, and regulations

Recovered materials The offeror/contractor is encouraged to use recovered material in accordance with Federal Acquisition Regulation Subpart 23 4 to the maximum extent practical

Preservation, packaging, packing, labeling, and marking Unless otherwise specified, preservation, packaging, and packing shall be to a degree of protection to preclude damage to containers and/or contents thereof under normal shipping conditions, handling, etc , involving shipment from the supply source to the receiving activity, plus reshipment from receiving activity, and shall conform to applicable carrier's rules and regulations Intermediate and exterior package quantities and labeling and marking shall be as specified in the contract and /or order

NOTE The following National Stock Number is covered by this document

NSN	ITEM IDENTIFICATION
6515-00-690-3213	CLAMP, ARTERY, Debakey, Angular Jaws, 7 inch

Ordering data (Intermediate/exterior package quantities and labeling and marking must be specified in the contract and/or order)

MILITARY INTERESTS	PREPARING ACTIVITY
Custodians	DoD-MB
Army-MD	Agent
Navy-MS	
Air Force-03	DLA-DM

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:31Z
Check the source to verify that this is the current version before use.

CIVIL AGENCY COORDINATING ACTIVITIES

VA-OSS
PHS
FDA-MPQAS

Project No 6515-4829

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:31Z
Check the source to verify that this is the current version before use.

INSTRUCTIONS In a continuing effort to make our standardization documents better, the DoD provides this form for use in submitting comments and suggestions for improvements All users of military standardization documents are invited to provide ggestions This form may be detached, folded along the lines indicated, taped along the loose edge *(DO NOT STAPLE)*, and ailed In block 5, be as specific as possible about particular problem areas such as wording which required interpretation, was too rigid, restrictive, loose, ambiguous, or was incompatible, and give proposed wording changes which would alleviate the problems Enter in block 6 any remarks not related to a specific paragraph of the document If block 7 is filled out, an acknowledgement will be mailed to you within 30 days to let you know that your comments were received and are being considered

NOTE This form may not be used to request copies of documents, nor to request waivers, deviations, or clarification of specification requirements on current contracts Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document*(s)* or to amend contractual requirements

(Fold along this line)

(Fold along this line)

NO POSTAGE NECESSARY IF MAILED IN THE UNITED STATES

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE $300

BUSINESS REPLY MAIL
FIRST CLASS PERMIT NO 4966 Alexandria, VA

POSTAGE WILL BE PAID BY

Commander
Defense Personnel Support Center
ATTN: DPSC-RSTS
2800 South 20th Street
Philadelphia, Pennsylvania 19101-8419

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:31Z
Check the source to verify that this is the current version before use.

(TO DETACH THIS FORM, CUT ALONG THIS LINE.)

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

(See Instructions – Reverse Side)

1 DOCUMENT NUMBER	2 DOCUMENT TITLE
A-A-54220	CLAMP, ARTERY, DeBakey, Angular Jaws, 7 Inch

3a NAME OF SUBMITTING ORGANIZATION	4 TYPE OF ORGANIZATION *(Mark one)*
	☐ VENDOR
b ADDRESS *(Street, City, State ZIP Code)*	☐ USER
	☐ MANUFACTURER
	☐ OTHER *(Specify)* _____

5 PROBLEM AREAS

a Paragraph Number and Wording

b Recommended Wording

c Reason/Rationale for Recommendation

6 REMARKS

7a NAME OF SUBMITTER *(Last, First, MI — Optional)*	8 WORK TELEPHONE NUMBER *(Include Area Code — Optional)*
b MAILING ADDRESS *(Street, City, State, ZIP Code)*	d DATE OF SUBMISSION *(YYMMDD)*

DD FORM 1426 PREVIOUS EDITION IS OBSOLETE.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:31Z
Check the source to verify that this is the current version before use.