MILITARY SPECIFICATION

NOZZLES, FUEL AND OIL SERVICING, NONAUTOMATIC SHUTOFF

AND NOZZLES, FUEL SERVICING, AUTOMATIC SHUTOFF

This amendment forms a part of Military Specification MIL-N-52110F, dated 25 February 1982, and is approved for use by all Departments and Agencies of the Department of Defence.

PAGE 5

3.3.2: Delete and substitute:

"3.3.2 Valve springs. The valve springs shall be copper wire conforming to ASTM B 159, alloy UNS C51000, corrosion-resisting steel wire conforming to ASTM A 313, alloys UNS S30200, S30400, or S31600, or spring steel plated in accordance with QQ-P-416, class 1, type II. In addition the spring steel can be coated according to MIL-STD-870, class 1, type I, or aluminum coated in accordance with MIL-C-81740, class 1, type II, or equivalent, or coated in accordance with MIL-C-81562, class 1, type I; or a metallic ceramic coating (0.001 inch thickness) in accordance with MIL-C-81797."

PAGE 9

3.5.6 and table I: Delete entirely and substitute:

"3.5.6 Nozzle capacity. The type I and type II nozzles shall have capacities of not less than the flows specified in table I and shall be tested as specified herein."

FSC 4930



Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:07Z
Check the source to verify that this is the current version before use.

TABLE I. Capacity (gasoline).

| Size | Nozzle inlet pressure (max) (psi) | Capacity (gpm) |
|---|---|---|
| 1 | 15 | 12 |
| 2 | 15 | 40 |
| 3 | 10.2 | 136 |

Custodians:
Army - ME
Navy - YD

Review activities:
Army - AV
DLA - CS

User activities:
Army - CE
Navy - CG, MC

Preparing activity:
Army - ME

Project 4930-0307



Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:07Z
Check the source to verify that this is the current version before use.