MIL-D-82134B(MC)
AMENDMENT 1
17 March 1986

MILITARY SPECIFICATION

DUMMY LOADS, ELECTRICAL: 60/100 KW, 55/90 KVAR,
3 PHASE, 60/400 HERTZ, AC

This amendment forms a part of Military Specification MIL-D-82134B (MC), dated 12 June 1973, and is approved for use within the U.S. Marine Corps, Department of the Navy, and is available for use by all Departments and Agencies of the Department of Defense.

PAGE 1

1.2:

After line 7, add the following:

"Type III - 100 kW, 3 phase, 60/400 Hz, ac."

Last line: Delete "both types" and substitute "all types".

2.1: After "SPECIFICATIONS", delete "FEDERAL TT-E-485 - Enamel, Semi-gloss, Rust-inhibiting".

PAGE 4

3.3:

Line 4: Delete "load and a" and substitute "load, a".

Line 5: At end of sentence, add "and a 100 kW resistive load for type III dummy load."

PAGE 6

3.3.7:

Line 5: After "dummy load.", add new sentence as follows: "Those controls associated with reactive load testing shall be eliminated for the type III dummy load".

Line 10: At end of paragraph, add new sentence as follows: "The design of the control panel shall be approved by the contracting officer's technical representative prior to production release."

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-23T06:44Z
Check the source to verify that this is the current version before use.

PAGE 8

3.3.8:

Second sentence: Delete in its entirety and substitute: "The metering and indicator panel shall be completely removable for the purpose of calibration. Meters shall be of the digital or analog variety. The panel design and layout shall be essentially in accordance with Figure 2 and shall be approved by the contracting officer's technical representative prior to production release."

Line 14: Delete sentence "Test jacks ..... be provided" in its entirety.

Line 20: Delete "kVA" and substitute "kilovoltampere (kVA)."

3.3.10: At end of paragraph, add new sentence as follows: "This paragraph is not applicable to the type III dummy load".

PAGE 12

3.7(e): At end of paragraph, add new sentence as follows: "This paragraph is not applicable to the type III dummy load".

3.9: Add the following:

"Type III - 26 inches wide by 42 inches high by 48 inches long."

PAGE 13

3.10: Add the following:

"Type III - 600 pounds".

3.13: At end of paragraph, add new sentence as follows: "This paragraph is not applicable to the type III dummy load".

3.11: Delete in its entirety and substitute the following:

"3.11 Color and finish. All external metal surfaces shall be treated and painted in accordance with MIL-T-704, type F or G, as applicable, color green 383."

PAGE 17

4.4.3.1: At end of paragraph, add new sentence as follows: The paragraph is not applicable to the Type III dummy load".

Source: https://assist.dla.mil -- Downloaded: 2026-10-23T06:44Z
Check the source to verify that this is the current version before use.

PAGE 19

4.4.8: At end of paragraph, add new sentence as follows: "This paragraph is not applicable to the type III dummy load."

PAGE 22

6.3: Delete in its entirety.

Preparing activity:
Navy - MC
Project No. 6115-N504

Source: https://assist.dla.mil -- Downloaded: 2026-10-23T06:44Z
Check the source to verify that this is the current version before use.