| INCH-POUND |

MIL-B-17452E
AMENDMENT 1
14 July 1995

MILITARY SPECIFICATION

BOILERS, STEAM AND HOT WATER, FIRETUBE - SCOTCH PACKAGED TYPE
(320,001 TO 35,000,000 BTU/HR THERMAL OUTPUT CAPACITY)

This amendment forms a part of MIL-B-17452E, dated 28 August 1990, and is approved for use by all Departments and Agencies of the Department of Defense.

PAGE 6

3.7.3: Delete the last sentence and substitute: "The volume heat input rate shall not be more than 200,000 btu/hr per cubic foot of furnaces volume."

3.7.3: Add the following at end of paragraph: "The heat transfer rate shall be determined on the basis of the furnace input btu/hr times the thermal efficiency divided by the total generator heating surface."

Preparing activity:
Navy - YD1

(Project 4410-0090)

AMSC N/A

FSC 4410

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:10Z
Check the source to verify that this is the current version before use.