MIL-G-17489B(SHIPS)
AMENDMENT - 1
21 September 1961

MILITARY SPECIFICATION

GAGES, PRESSURE (AIR), BOILER

This amendment forms a part of Military Specification MIL-G-17489B(SHIPS), 15 March 1961.

Page 2, paragraph 3.7: Delete.

Page 2, paragraph 3.9, line 6: Delete "links of" and substitute "links or".

Page 3, paragraph 3.14.3: Delete and substitute:

"3.14.3 Accuracy. - Type A pressure gages shall be of such design and construction as to insure maintenance of accuracy to within plus or minus 2/10 inches of water for the 90 degree portion of the scale range, and for the remainder of the scale range, within plus or minus 2 percent of the top scale value (see 4.5.3)."

Page 3, paragraph 3.15.1: Delete and substitute:

"3.15.1 Pressure gage scales. - Scales shall be as shown on figure 4 in respect to character and design except for ranges and number of units. Pressure gages shall be accurately and correctly graduated up to and including the last division of the scale. Scales shall be secured to the pressure gage mechanisms by at least 4 screws. The scales shall be of materials as specified in 3.11. The scales shall be graduated to read the pressure effective on the diaphragm in inches of water above atmosphere (barometric) unless other graduations are specified in the contract or order. The height of figures on the scale shall be 1/2 inch. As a minimum, scales with a range of up to and including 10 inches of water shall have numerals at each inch of water, 10 graduations per inch. The 1 inch, 1/2 inch and 1/10 inch graduations shall be easily distinguished from each other. As a minimum, scales with limiting range between 10 and 15 inches of water shall have numerals every 2 inches of water, graduations every 2/10 inches. As a minimum, scales with a range up to and including 60 inches shall have numerals every 5 inches of water, graduations every 1/2 inch. As a minimum, scales having limiting ranges between 60 and 100 inches of water shall

FSC 6685

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:12Z
Check the source to verify that this is the current version before use.

have numerals every 10 inches, graduations every inch of water. Scales with a range above 100 inches of water shall be marked with sufficient graduations for good and accurate readability, with maximum spacing of numerals at 15 inch intervals, maximum spacing of graduations every 5 inches. Minimum size of scale shall be 2 inches wide by 10 inches vertical length, except that for gages intended for control panel installation, scales may be a minimum of 2 inches wide by 6 inches vertical length."

Page 3, paragraph 3.15.3: Delete and substitute:

"3.15.3 Accuracy. - The gages shall be of such design and construction as will assure maintenance of accuracy to within plus or minus 2 percent of the top scale value (see 4.5.3)."

Page 4, paragraph 3.16.3, lines 3 and 4: Delete "of total scale range (see 4.5.3)" and substitute "of the top scale value (see 4.5.3)."

Page 5, paragraph 4.5.2, first sentence: Delete and substitute "Upon completion of the temperature test, a pressure equal to 1-3/10 times the top scale value of the highest pressure scale shall be applied for 1 hour."

Page 6, paragraph 4.5.3.1: Delete.

Preparing activity:
Navy - Ships
(Project 6685-N041Sh)

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:12Z
Check the source to verify that this is the current version before use.