MIL-P-52407A(ME)
5 May 1976
SUPERSEDING
MIL-P-52407(MO)
16 February 1965

MILITARY SPECIFICATION

PUMP, CENTRIFUGAL: ELECTRIC-MOTOR-DRIVEN, SHALLOW WELL (FOR WATER)

This specification is approved for use by the U.S. Army Mobility Equipment Research and Development Command, Department of the Army, and is available for use by all Departments and Agencies of the Department of Defense.

1. SCOPE

1.1 Scope. This specification covers a shallow well, close-coupled, electric-motor-driven, horizontally mounted, self-priming, centrifugal, water pump complete with connections for water pumping operations.

2. APPLICABLE DOCUMENTS

2.1 Issues of documents. The following documents of the issue in effect on date of invitation for bids or request for proposal form a part of this specification to the extent specified herein.

SPECIFICATIONS

FEDERAL

FF-B-171	- Bearings, Ball, Annualar (General Purpose).

MILITARY

MIL-T-704	- Treatment and Painting of Materiel.
MIL-P-10603	- Pumps and Pumping Units, Centrifugal, Power Driven, For Water; Packaging of.
MIL-G-10924	- Grease, Automotive and Artillery.
MIL-G-23827	- Grease, Aircraft and Instrument, Gear and Actuator Screw.

FSC 4320

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T04:08Z
Check the source to verify that this is the current version before use.

STANDARDS

FEDERAL

FED. STD. No. 356	- Commercial Packaging of Supplies and Equipment.

MILITARY

MIL-STD-105	- Sampling Procedures and Tables for Inspection by Attributes.
MIL-STD-129	- Marking for Shipment and Storage.
MIL-STD-130	- Identification Marking of US Military Property.

(Copies of specifications and standards required by contractors in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

2.2 Other publications. The following documents form a part of this specification to the extent specified herein. Unless otherwise indicated, the issue in effect on date of invitation for bids or request for proposal shall apply.

AMERICAN NATIONAL STANDARDS INSTITUTE (ANSI)

B16.14 - Ferrous Pipe Plugs, Bushings, and Locknuts, with Pipe Threads.
B40.1 - Gages, Pressure and Vacuum, Indicating Dial Type, Elastic Element.

(Application for copies should be addressed to the American National Standards Institute, 1430 Broadway, New York, NY 10018.)

AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME)

Boiler and Pressure Vessel Code, Section IX, Welding Qualifications.

(Application for copies should be addressed to the American Society of Mechanical Engineers, 345 East 47th Street, New York, NY 10017.)

AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)

A 48 - Gray Iron Castings.
A 276 - Stainless and Heat-Resisting Steel Bars and Shapes.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T04:08Z
Check the source to verify that this is the current version before use.

A 434 - Quenched and Tempered Alloy Steel Bars, Hot-Rolled or Cold-Finished.
B 584 - Copper Alloy Sand Castings for General Applications.

(Application for copies should be addressed to the American Society for Testing and Materials, 1916 Race Street, Philadelphia, PA 19103.)

AMERICAN WELDING SOCIETY, INC. (AWS)

D1.1 - Structural Welding Code, Section 5, Qualification.

(Application for copies should be addressed to the American Welding Society, 2501 North West Seventh Street, Miami, FL 33125.)

HYDRAULIC INSTITUTE

Rating Standards and Test Code Standards.

(Application for copies should be addressed to the Hydraulic Institute, 2130 Keith Building, Cleveland, OH 44115.)

NATIONAL BUREAU OF STANDARDS (NBS)

Handbook H28 - Screw-Thread Standards for Federal Services.

(Application for copies should be addressed to the Superintendent of Documents, Government Printing Office, Washington, DC 20402.)

NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION (NEMA)

MG1 - Motors and Generators.

(Application for copies should be addressed to the National Electrical Manufacturers Association, 815 15th Street, Suite 438, Washington, DC 20005.)

OCCUPATIONAL SAFETY AND HEALTH ACT OF 1970 (OSHA)

Title 29, CFR, Chapter XVII, Part 1910, Subpart S - Electrical.

(The Code of Federal Regulations (CFR) and the Federal Register (FR) are for sale on a subscription basis by the Superintendent of Documents,

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T04:08Z
Check the source to verify that this is the current version before use.

U.S. Government Printing Office, Washington, DC 20402. When indicated, reprints of certain regulations may be obtained from the Federal agency responsible for issuance thereof.)

SOCIETY OF AUTOMOTIVE ENGINEERS (SAE)

SAE Handbook.

(Application for copies should be addressed to the Society of Automotive Engineers, 400 Commonwealth Drive, Warrendale, PA 15096.)

(Technical society and technical association specifications and standards are generally available for reference from libraries. They are also distributed among technical groups and using Federal agencies.)

3. REQUIREMENTS

3.1 Description. The pumping unit shall consist of a pump, an electric motor, and connections for water pumping operations.

3.2 First article (first-produced pumping unit). The contractor shall furnish one pumping unit as specified for examination and testing within the time frame specified (see 6.2) to prove that his production methods and choice of design detail will produce pumping units that comply with the requirements of this specification. Examination and tests shall be as specified in Section 4 and shall be subject to surveillance and approval by the Government (see 6.3).

3.3 Material. Material shall be as specified herein. Materials not specified shall be selected by the contractor and shall be subject to all provisions of this specification.

3.4 Screw threads. Screw threads shall conform to NBS Handbook H28.

3.5 Safety. All rotating, reciprocating, exposed, and electrically energized parts that are of such nature or located so as to become a hazard to operating personnel shall be fully guarded or enclosed in accordance with OSHA 29CFR1910.309. Protective devices shall not impair the operating functions of the pumping unit.

3.6 Ease of maintenance. All assemblies, parts, and attachments shall be accessible for maintenance, repair, and replacement without

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T04:08Z
Check the source to verify that this is the current version before use.

the removal of other major assemblies and installed attachments not normally removed. Drain outlets shall be located for accessibility.

3.7 Pump. The pump shall be of the close-coupled, single-stage, single-suction, jet, shallow-well, centrifugal type. The pump shall prime itself repeatedly after the pump case has been initially filled. Each pump shall be provided with a mechanical seal, enclosed impeller, built-in or attached check valve on suction inlet, built-in or attached ejector, and a pump case drain port and plug. The suction inlet of the pump or check valve shall be internally threaded 1-inch NPT and the discharge outlet or ejector shall be internally threaded 3/4-inch NPT.

3.7.1 Hydrostatic pressure. The pump and check valve shall withstand an internal hydrostatic pressure of not less than 95 pounds per square inch (psi) for a period of not less than 3 minutes without leakage or permanent deformation.

3.7.2 Pump case. The pump case shall be an iron casting conforming to ASTM A 48, class optional.

3.7.2.1 Drain port and plug. The drain port shall be internally threaded NPT and shall be of such size and so located as to completely drain the pump case in not more than 2 minutes. The drainplug shall be a square-head pipe plug conforming to ANSI B16.14. When installed, the plug shall not protrude beyond the inner surface of the pump case.

3.7.3 Pump impeller shaft. The pump impeller shall be mounted on the extended motor shaft or on its own shaft connected to the motor shaft by means of an adaptor fabricated of corrosion-resisting steel conforming to ASTM A 276, Type 420.

3.7.4 Shaft sleeve. When the pump impeller is mounted directly to the motor shaft (see 3.9.4), a sleeve shall be provided. The sleeve shall be corrosion-resisting steel conforming to ASTM A 276, Type 420.

3.7.5 Pump-shaft seal. The pump shall be provided with a mechanical-type, self-lubricating seal. The seal shall be lubricated by the pumped liquid. The seal shall be self-alining, and the sealing surface shall be independent of the impeller adjustment. All components of the mechanical-type seal shall be resistant to corrosion.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T04:08Z
Check the source to verify that this is the current version before use.

3.7.6 Pump impeller. The pump impeller shall be an iron casting conforming to ASTM A 48, class optional, or bronze conforming to ASTM B 584, Alloy 836, and shall be the single-suction, fully enclosed type. The impeller shall be screwed on the pump shaft in the opposite direction of rotation from the motor shaft.

3.7.6.1 Impeller balancing. The impeller shall be statically balanced. The static out-of-balance condition shall be not more than 0.025 ounce-inch (oz-in).

3.7.7 Check valve. When subjected to the shut-off head of the pump, the valve shall prevent reverse flow of water from the pump case and shall not show permanent deformation of any of its components.

3.8 Pressure gage. A pressure gage conforming to ANSI B40.1, Grade A, shall be installed on the pump case. The gage shall have an enclosed 2-inch-diameter dial. The range of the gage shall be from 0 to 100 psi. The gage connection shall have 1/4-inch NPT external threads.

3.9 Electric motor. The electric motor shall be a fractional-horsepower, jet-pump motor conforming to NEMA MG1, single-phase, squirrel-cage, capacitor-start, fan-cooled, open-type, ball-bearing, solid-shaft, 40° C temperature rise, continuous-duty, Class A insulation, horizontally mounted type.

3.9.1 Power rating. The continuous-duty power rating of the motor shall be not less than the required pump brake horsepower at rated performance conditions (see 3.11.2).

3.9.2 Synchronous and full-load speeds. The synchronous speed of the motor shall be 3600 revolutions per minute (rpm). The full-load speed shall be not less than 3450 rpm.

3.9.3 Voltage and frequency. The motor shall operate on a 115-volt, single-phase, 60 hertz (Hz) power supply.

3.9.4 Motor shaft. The motor shaft shall be steel conforming to ASTM A 434, Class BB, Composition AISI 4140, conditioned cold-finished, or corrosion-resisting steel conforming to ASTM A 276, Type 420.

3.9.5 Motor bearings. The motor shall be provided with anti-friction, lubricated-for-life, sealed bearings conforming to FF-B-171. The bearings shall function on a continuous-duty basis while supporting

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T04:08Z
Check the source to verify that this is the current version before use.

the maximum combined radial and thrust loads imposed by the elements and hydraulic action of the pumping unit.

3.10 Pressure switch. The motor shall be provided with an automatic pressure switch. The switch shall be furnished with a 1/4-inch NPT externally threaded stub for connection to the pump pressure line. The switch shall be capable of energizing the motor at a minimum pressure of 15 psi and deenergizing the motor at a maximum pressure of 65 psi; also, the switch shall be capable of energizing and deenergizing the motor at any pressure setting between the minimum and maximum limits. The pressure differential of the switch shall be 15 psi minimum and 30 psi maximum. The switch shall be set to energize the motor at 20 psi and deenergize the motor at 40 psi.

3.11 Performance.

3.11.1 Priming. When operating in a closed system and at conditions equivalent to standard sea level atmospheric conditions of 29.92 inches of mercury and the specific weight of water (62.3 pounds per cubic foot) at a temperature of 68° F, the pumping unit shall perform as follows:

(a) Prime in not more than 2 minutes under a 10-foot static suction lift and against a discharge head of not less than 20 psi.
(b) Prime in not more than 4 minutes under a 20-foot static suction lift and against a discharge head of not less than 20 psi. After priming, the pumping unit shall operate at a speed of not less than 3450 rpm for a period of not less than 2 hours without damage to or permanent deformation of any component.

3.11.2 Capacity. The pumping unit shall deliver not less than 6.7 gallons per minute (gpm) at a 94-foot total head when operated at a speed of not less than 3450 rpm against a 10-foot static suction lift.

3.12 Grease lubrication. All grease lubrication, including lubrication of sealed bearings, shall be with greases as follows:

(a) MIL-G-23827 - For ball, roller, and needle bearings, gears, and on sliding and rolling surfaces of such equipment as instruments, cameras, electronic gear, and mechanical control systems; for use on gears,

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T04:08Z
Check the source to verify that this is the current version before use.

actuator screws, and other equipment requiring a lubricant with high load-carrying capacity over a temperature range of minus 100° F to plus 250° F.

(b) MIL-G-10924 - For lubrication and surface corrosion protection of all automotive and artillery equipment operated over the temperature range of minus 65° F to plus 225° F.

The pumping unit shall be assembled, run-in (broken-in), tested, and delivered with these greases. The bearings shall be cleaned before lubrication, because military greases are not always compatible with other greases. A tag shall be attached in a conspicuous place to indicate which military grease has been used when the unit requires additional lubrication services.

3.13 Identification marking. The pumping unit shall be identified in accordance with MIL-STD-130.

3.14 Treatment and painting. The portions of the pumping unit normally painted shall be cleaned, treated, and painted in accordance with MIL-T-704, Type A, color forest green.

3.15 Workmanship.

3.15.1 Castings and forgings. All parts, components, and assemblies of the pumping unit which include castings and forgings shall be clean of harmful extraneous material such as sand, dirt, sprues, scale, and flux. Rework shall be limited to procedures which do not reduce mechanical properties or affect function.

3.15.2 Metal fabrication. Metal used in fabrication shall be free from kinks and sharp bends. The straightening of material shall be done by methods that will not cause injury to the material. Corners shall be square and true. Flame-cutting, using tips suitable for the thickness of the steel, may be employed instead of shearing and sawing. All bends shall be made with controlled means to insure uniformity of size and shape. Precaution shall be taken to avoid overheating. Heated steel shall be allowed to cool slowly. External surfaces shall be free of burrs, sharp edges, and corners, except when sharp edges or corners are required or where they are not detrimental to safety.

3.15.3 Welding. The surfaces of parts to be welded shall be free from rust, scale, paint, grease, mill scale that can be removed by

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T04:08Z
Check the source to verify that this is the current version before use.

chipping and wire brushing, and other foreign matter. Welds shall transmit stress without permanent deformation or failure when the parts connected by the welds are subjected to proof and service loading. Parts to be joined by fillet welds shall be brought into as close contact as possible and in no event shall be separated by more than 3/16 inch unless appropriate bridging techniques are used. Unless otherwise specified (see 6.2), the welding process used in fabrication of the pumping unit shall be at the option of the contractor.

3.15.4 Welders. Before assigning any welder to manual welding work covered by this specification, the contractor shall provide the contracting officer with certification that the welder has passed qualification tests as prescribed by either of the following listed codes for the type of welding operations to be performed and that such qualification is effective as defined by the particular code:

AWS D1.1, Structural Welding Code, Section 5, Qualification.
ASME Boiler and Pressure Vessel Code, Section IX, Welding Qualifications.

Contractors who make horizontal welds need not qualify welders for "all position welding". Subject to approval by the Government, the contractor's standard welder qualification may be substituted in lieu of the above codes provided that the contractor's procedure is equivalent to the above codes. The contractor shall be responsible for determining that automatic welding equipment operators are capable of producing quality welds in accordance with AWS or ASME codes.

3.15.5 Bolted connections. Boltholes shall be accurately formed and shall have the burrs removed. Washers or lockwashers shall be provided where necessary. Matching thread areas securing bolts conforming to SAE J429 or capscrews shall be of sufficient strength to withstand the tensile strength of the bolt. All fasteners shall be correctly torqued and shall have full thread engagement. Bolts shall protrude not more than two full threads.

3.15.6 Machine work. Tolerances and gages for metal fits shall conform to the limits specified herein.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract, the contractor is responsible for the performance of all

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T04:08Z
Check the source to verify that this is the current version before use.

inspection requirements as specified herein. Except as otherwise specified in the contract, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

4.1.1 Component and material inspection. The contractor is responsible for insuring that components and materials used are manufactured, examined, and tested in accordance with referenced specifications and standards, as applicable.

4.2 Classification of inspections. The inspection requirements specified herein are classified as follows:

(a) First-produced pumping unit inspection (see 4.3).
(b) Quality conformance inspection (see 4.4).
(c) Inspection of packaging (see 4.6).

4.3 First-produced pumping unit inspection.

4.3.1 Examination. The pumping unit shall be examined as specified in 4.5.1. Presence of one or more defects shall be cause for rejection.

4.3.2 Tests. The pumping unit shall be tested as specified in 4.5.2 through 4.5.2.9. Failure to pass any test shall be cause for rejection.

4.4 Quality conformance inspection.

4.4.1 Sampling. Sampling for examination and tests shall be in accordance with MIL-STD-105.

4.4.2 Examination. Samples selected in accordance with 4.4.1 shall be examined as specified in 4.5.1. AQL shall be 2.5 percent defective for major defects and 6.5 percent defective for minor defects.

4.4.3 Tests.

4.4.3.1 Individual. Each pump casing, including check valve, and each pump impeller shall be tested as specified in 4.5.2.2 or 4.5.2.4, as applicable.

Source: https://assist.dla.mil -- Downloaded: 202610-26T04:08Z
Check the source to verify that this is the current version before use.

4.4.3.2 Samples. Samples selected in accordance with 4.4.1 shall be tested as specified in 4.5.2.6.1, 4.5.2.7.2, and 4.5.2.8. AQL shall be 2.5 percent defective.

4.5 Inspection procedure.

4.5.1 Examination. The pumping unit shall be examined as specified herein for the following defects:

Major

101. Materials not as specified.
102. Safety requirements not as specified.
103. Ease of maintenance provisions not as specified.
104. Pump case not as specified.
105. Drain port and drainplug not as specified.
106. Impeller shaft not as specified.
107. Shaft sleeve not as specified.
108. Pump impeller not as specified.
109. Check valve missing or not as specified.
110. Pressure gage not as specified.
111. Motor shaft not as specified.
112. Motor bearings not as specified.
113. Lubrication not as specified.
114. Workmanship not as specified.

Minor

201. Identification marking missing, incorrect, or illegible.
202. Treatment and painting not as specified.

4.5.2 Tests.

4.5.2.1 Test conditions. Conduct the test in accordance with the applicable provisions of the test code for centrifugal pumps of the Hydraulic Institute. Correct all test data to standard sea level atmospheric conditions of 29.92 inches of mercury and the specific weight of water of 62.3 pounds per cubic foot at a temperature of 68° F. Prior to testing, lubricate the pump with greases specified in 3.12.

4.5.2.2 Hydrostatic pressure. Subject the pump, including check valve, to an internal hydrostatic pressure of not less than 95 psi for

Source: https://assist.dla.mil -- Downloaded: 202610-26T04:08Z
Check the source to verify that this is the current version before use.

a period of not less than 3 minutes. Leakage or permanent deformation of the pump or check valve shall constitute failure of this test.

4.5.2.3 Pump case drain. With the pump case filled with water and without any discharge piping or fittings, remove the drainplug. Determine the time required to drain the pump case. Inability of the pump case to completely drain in not more than 2 minutes shall constitute failure of this test.

4.5.2.4 Pump impeller balancing. During assembly of the pump, determine the out-of-balance of the impeller. Out-of-static balance of more than 0.025 oz-in shall constitute failure of this test.

4.5.2.5 Check valve. After the pumping unit has been completely primed and while utilizing only the check valve specified herein, subject the pumping unit to a pressure of not less than the shutoff head. Shut off the pumping unit and allow it to set for a period of not less than 30 minutes. Restart the pumping unit. Determine whether the pumping unit primes itself against a discharge head of not less than 20 psi. Inability of the pumping unit to prime itself, leakage, or permanent deformation of any component of the check valve shall constitute failure of this test.

4.5.2.6 Performance.

4.5.2.6.1 Priming. Prime and operate the pumping unit as follows:

(a) Utilizing not less than 15 feet of suction line and one elbow, prime the pumping unit against a 20 psi discharge pressure and a 10-foot static suction lift.

(b) Utilizing not less than 25 feet of suction line and one elbow, prime the pumping unit against a 20 psi discharge pressure and a 20-foot static suction lift. After priming, operate the pumping unit at a speed of not less than 3450 rpm for a period of not less than 2 hours.

4.5.2.6.2 Failure criteria. Nonconformance to 3.11.1 shall constitute failure of this test.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T04:08Z
Check the source to verify that this is the current version before use.

4.5.2.7 Automatic pressure switch.

4.5.2.7.1 Operating range. Operate the pumping unit to determine the operating range of the pressure switch. Nonconformance to 3.10 shall constitute failure of this test.

4.5.2.7.2 Pressure setting. Operate the pumping unit at a pressure setting of 20 to 40 psi. Inability of the pressure switch to energize the motor when the pressure drops below 19 psi and to deenergize the motor when the pressure rises above 41 psi shall constitute failure of this test.

4.5.2.8 Head capacity. Operate the pumping unit to determine the head capacity. The operating time shall be that required to obtain the performance characteristics of the pumping unit. Nonconformance to 3.11.2 shall constitute failure of this test.

4.5.2.9 Horsepower requirements. Operate the pumping unit at rated conditions to determine the brake horsepower. Nonconformance to 3.9.1 shall constitute failure of this test.

4.6 Inspection of packaging. The preservation, packing, and marking of the pumping units shall be examined and tested to determine compliance with the quality assurance provisions of MIL-P-10603.

5. PACKAGING

5.1 Preservation. Preservation shall be Level A, Level B, or Commercial, as specified (see 6.2).

5.1.1 Level A. The pumping units and associated equipment shall be preserved in accordance with the requirements of MIL-P-10603, Level A.

5.1.2 Level B. The pumping units and associated equipment shall be preserved in accordance with the requirements of MIL-P-10603, Level B.

5.1.3 Commercial. The pumping units and associated equipment shall be preserved in accordance with the requirements of FED. STD. No. 356.

5.2 Packing. Packing shall be Level A, Level B, or Commercial, as specified (see 6.2).

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T04:08Z
Check the source to verify that this is the current version before use.

5.2.1 Level A. The pumping units shall be packed in accordance with MIL-P-10603, Level A.

5.2.2 Level B. The pumping units shall be packed in accordance with the requirements of MIL-P-10603, Level B.

5.2.3 Commercial. Commercial packing of the pumping units shall be in accordance with FED. STD. No. 356.

5.3 Marking.

5.3.1 Military. Marking for military levels of protection shall be in accordance with MIL-STD-129.

5.3.2 Commercial. Marking for commercial packaging shall be in accordance with FED. STD. No. 356.

6. NOTES

6.1 Intended use. The pumping unit is intended for use in units of the photomapping train and for use in general-purpose, shallow-well, water-pumping operations.

6.2 Ordering data. Procurement documents should specify the following:

(a) Title, number, and date of this specification.
(b) Time frame required for submission of first-produced pumping unit (see 3.2).
(c) When the welding process will not be at the option of the contractor (see 3.15.3).
(d) Degree of preservation and packing required (see 5.1 and 5.2).

6.3 First-produced pumping unit. Any changes or deviations of production pumping units from the approved first-produced pumping unit during production will be subject to the approval of the contracting officer. Approval of the first-produced pumping unit will not relieve the contractor of his obligation to furnish pumping units conforming to this specification.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T04:08Z
Check the source to verify that this is the current version before use.

6.4 Data requirements. The contracting officer should include requirements for such data as technical publications, instructional materials, illustrated parts lists, and contractor's maintenance and operation manual to be furnished with each pumping unit.

6.5 Provisioning. The contracting officer should include provisioning requirements for repair parts and maintenance tools as necessary (including any special tools), and instructions regarding shipment of pumping units.

Custodian:
Army - ME

Preparing activity:
Army - ME

Review activity:
Army - MD

User activity:
Army - GL

Project 4320-A163

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T04:08Z
Check the source to verify that this is the current version before use.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T04:08Z
Check the source to verify that this is the current version before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

OMB Approval
No. 22-R255

INSTRUCTIONS: The purpose of this form is to solicit beneficial comments which will help achieve procurement of suitable products at reasonable cost and minimum delay, or will otherwise enhance use of the document. DoD contractors, government activities, or manufacturers/vendors who are prospective suppliers of the product are invited to submit comments to the government. Fold on lines on reverse side, staple in corner, and send to preparing activity. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document(s) or to amend contractual requirements. Attach any pertinent data which may be of use in improving this document. If there are additional papers, attach to form and place both in an envelope addressed to preparing activity.

DOCUMENT IDENTIFIER AND TITLE MIL-P-52407A(ME) Pump, Centrifugal: Electric-Motor-Driven, Shallow Well (for Water)

NAME OF ORGANIZATION AND ADDRESS

CONTRACT NUMBER

MATERIAL PROCURED UNDER A

☐ DIRECT GOVERNMENT CONTRACT ☐ SUBCONTRACT

1. HAS ANY PART OF THE DOCUMENT CREATED PROBLEMS OR REQUIRED INTERPRETATION IN PROCUREMENT USE?

A. GIVE PARAGRAPH NUMBER AND WORDING.

B. RECOMMENDATIONS FOR CORRECTING THE DEFICIENCIES

2. COMMENTS ON ANY DOCUMENT REQUIREMENT CONSIDERED TOO RIGID

3. IS THE DOCUMENT RESTRICTIVE?

☐ YES ☐ NO *(If "Yes", in what way?)*

4. REMARKS

SUBMITTED BY *(Printed or typed name and address - Optional)*

TELEPHONE NO.

DATE

DD FORM 1 JAN 72 1426

REPLACES EDITION OF 1 JAN 66 WHICH MAY BE USED

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T04:08Z
Check the source to verify that this is the current version before use.

FOLD

POSTAGE AND FEES PAID
DEPARTMENT OF THE ARMY
DOD – 314

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE $300

Commander
US Army Mobility Equipment Research
and Development Command
ATTN: DRXFB-DS
Ft. Belvoir, VA 22060

FOLD

Source: https://assist.dla.mil -- Downloaded: 202640-26T04:08Z
Check the source to verify that this is the currentversion before use.