MILITARY SPECIFICATION SHEET

GENERATOR SET, GASOLINE ENGINE DRIVEN,

0.5 KW, 60 HERTZ

TYPE I (TACTICAL), CLASS 2 (UTILITY)

This specification is mandatory for use by all Departments and Agencies of the Department of Defense.

The complete requirements for procuring the generator set described herein shall consist of this document and the issue in effect of specification MIL-G-52734.

1. SCOPE

1.1 Scope. This specification covers the detail requirements for mode III, size 0.5 sets, Model MEP-014A.

1.2 Classification.

1.2.1 Set rating. The mode III set shall be rated 1.0 power factor (PF), 1 phase, 2 wire, 120 volts.

2. APPLICABLE DOCUMENTS

2.1 The following documents of the issue in effect on the date of invitation for bids or request for proposal form a part of this specification to the extent specified herein:

SPECIFICATIONS

Military

MIL-G-52732	- Generator Sets, Gasoline Engine Driven, 0.5 KW thru 10 KW, 60 Hertz, 400 Hertz and 28 Volt Direct Current, Type I (Tactical), Class 2 (Utility) General Specification For.

FSC 6115

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:31Z
Check the source to verify that this is the current version before use.

STANDARDS

Military

MS39297 - Engine, Gasoline, Air-Cooled, Industrial-Type, 4 Cycle, 1-1/2 Net Continuous HP.

DRAWINGS

ME

TA13217E1790 - Generator Set. Gasoline Engine Driven, 0.5 KW, AC, 120 Volts, 60 Hz, 1 Phase.

(Copies of specifications, standards, and drawings required by suppliers in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

3. REQUIREMENTS

3.1 Requirements shall be in accordance with MIL-G-52732 and as specified herein.

3.2 Description. The set shall be in accordance with Top Assembly TA13217E1790 and as specified herein.

3.3 Starting and operating. Servicing, adjustment, and replacement shall be as specified in table I.

3.3.1 With winterization. Not applicable for the mode III, size 0.5 set.

3.4 Maximum power. The maximum power (corrected) in kilowatts of the set shall be not less than 0.65 kw when operated at rated speed, voltage and at unity power factor.

3.5 Engine.

3.5.1 Engine design. The Government furnished engine will conform to MS39297.

3.5.2 Engine temperature. Engine temperatures shall not exceed the following:

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:31Z
Check the source to verify that this is the current version before use.

Location	Maximum Temperature	
	First 10 hours of engine operation	After 10 hours of engine operation
Sump oil	300° F. (148.9° C.)	250° F. (121° C.)
Cylinder head	500° F. (260° C.)	475° F. (246.1° C.)

Table I. Schedule of Servicing and Adjusting

All Items May Be Serviced Before Test

Item No.	Hours between service periods	Item
1	8	Any minor maintenance such as retightening and retorquing nuts, bolts, and screws that can be performed without disturbing or removing adjacent components, accessories, or shrouding (except fan shroud, pump, intake manifold, and exhaust system).
2	Not allowed	Any major maintenance that requires removal of other components, accessories or shrouding such as oil pans, cylinder heads and connecting rods.
3	As required	Cleaning and regapping or replacing spark plug.
4	As required	Servicing fuel filter.
5	100	Checking compression pressure.
6	8	Checking and adding lubricating oil, as necessary.
7	8	Adjusting carburetor.
8	As required	Cleaning carburetor.
9	8	Adjusting governor (normal speed adjustment).
10	50	Changing lubricating oil.
11	100	Servicing air cleaner.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:31Z
Check the source to verify that this is the current version before use.

Table I. Schedule of Servicing and Adjusting (cont'd)

All Items May Be Serviced Before Test

Item No.	Hours between service periods	Item
12	50	Adjusting and dressing breaker points.
13	50	Adjusting ignition timing.
14	250	Valve adjustment.
15	1500	Cleaning and inspection of combustion chamber, manifolds, and valves.
16	250	Replacing breaker points.
17	As required	Replacing condenser.
18	*	Gasket replacement.

* Not allowed except where component is removed for servicing.

3.5.3 Governing system.

3.5.3.1 Short term, steady-state stability (30 seconds), mode II and III sets. The short term steady-state stability bandwidth percentage shall not exceed 4 percent.

3.5.3.2 Long term, steady-state stability (4 hours), mode II and III sets. The long term steady-state stability bandwidth shall not exceed 4 percent.

3.6 Generator.

3.6.1 Voltage unbalance, mode II and III sets. Not applicable for the mode III, size 0.5 set.

3.6.2 Phase balance (voltage), mode II and III sets. Not applicable for the mode III, size 0.5 set.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:31Z
Check the source to verify that this is the current version before use.

3.6.3 Voltage waveform, mode II and III sets. The deviation factor at rated load and no load shall not exceed 8.0 percent. Single frequency harmonics shall not exceed 5.0 percent.

3.6.4 Output voltage ripple, mode IV sets. Not applicable for the mode III, size 0.5 set.

3.6.5 Saturation curves. With the generator temperature stabilized at normal ambient conditions, the exciter field current for rated voltage shall not exceed 0.08 ampere at no load and 0.13 ampere at rated load.

3.6.6 Voltage adjustment range. The minimum acceptable voltage adjustment range shall be 5 percent above and below rated voltage.

3.6.7 Voltage regulation. The voltage regulation percentage shall not exceed 4 percent.

3.6.8 Voltage steady-state performance. The voltage steady-state stability bandwidth percentage shall not exceed 2 percent.

3.6.9 Voltage transient performance. The voltage dip or rise percentage shall not exceed 35 percent.

3.6.10 Phase-sequence (rotation), mode II and III sets. Not applicable for the mode III, size 0.5 set.

3.6.11 Generator efficiency. The generator efficiency shall not be less than 64 percent.

3.7 Circuit interrupter. The circuit interrupter requirements are not applicable for the mode III, size 0.5 set.

3.8 Instruments. The inaccuracy of the voltmeter system shall not exceed 5 percent.

4. QUALITY ASSURANCE PROVISIONS

4.1 Quality assurance provisions. The quality assurance provisions shall be in accordance with MIL-G-[illegible] and as specified herein.

4.2 Engine preventative maintenance services. The engine preventative maintenance services shall be performed as specified in table I.

4.3 Proof test (type 2.1). The helium of the dry shall be 15 inches for the mode III, size 0.5 set.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:31Z
Check the source to verify that this is the current version before use.

4.4 Vibration test. The accelerometer used to compute transmissibility shall be located at the top of the engine adapter plate on the mode III, size 0.5 set. The resonant dwell portion of the test is not required on the mode III, size 0.5 set.

4.5 Railroad impact test. The railroad impact test shall be performed with the mode III, size 0.5 set, packaged level A.

5. PREPARATION FOR DELIVERY

5.1 Preparation for delivery. Preparation for delivery shall be in accordance with MIL-G-52732.

6. NOTES

6.1 Notes. The notes specified in MIL-G-52732 are applicable to this specification and as specified herein.

6.2 Stable operation (voltage). Stable operation is operation within a bandwidth of 2 percent of the rated voltage.

6.3 International standardization. Not applicable for the mode III, size 0.5 set.

Custodians:

Army - ME
Air Force - 80
Navy - YD

Preparing activity:

Army - ME

Project No. 6115-01ML-1

Review activities:

Army - EL, MI, MU

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:31Z
Check the source to verify that this is the current version before use.

SPECIFICATION ANALYSIS SHEET

Form Approved
Budget Bureau No. 22-R255

INSTRUCTIONS: This sheet is to be filled out by personnel, either Government or contractor, involved in the use of the specification in procurement of products for ultimate use by the Department of Defense. This sheet is provided for obtaining information on the use of this specification which will insure that suitable products can be procured with a minimum amount of delay and at the least cost. Comments and the return of this form will be appreciated. Fold on lines on reverse side, staple in corner, and send to preparing activity. Comments and suggestions submitted on this form do not constitute or imply authorization to waive any portion of the referenced document(s) or serve to amend contractual requirements.

SPECIFICATION: MIL-G-[illegible]1 - Generator Set, Gasoline Engine Driven, 0.5 KW, 60 HZ Type I (Tactical), Class 2 (Utility)

ORGANIZATION

CITY AND STATE | CONTRACT NUMBER

MATERIAL PROCURED UNDER A

☐ DIRECT GOVERNMENT CONTRACT ☐ SUBCONTRACT

1. HAS ANY PART OF THE SPECIFICATION CREATED PROBLEMS OR REQUIRED INTERPRETATION IN PROCUREMENT USE?

A. GIVE PARAGRAPH NUMBER AND WORDING.

B. RECOMMENDATIONS FOR CORRECTING THE DEFICIENCIES

2. COMMENTS ON ANY SPECIFICATION REQUIREMENT CONSIDERED TOO RIGID

3. IS THE SPECIFICATION RESTRICTIVE?

☐ YES ☐ NO (If "yes", in what way?)

4. REMARKS (Attach any pertinent data which may be of use in improving this specification. If there are additional papers attach to form and place both in an envelope addressed to preparing activity.)

SUBMITTED BY (Printed or typed name and activity - Optional) | DATE

DD FORM 1426 REPLACES [illegible] OBSOLETE WHICH MAY BE USED

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:31Z
Check the source to verify that this is the current version before use.

FOLD

DEPARTMENT OF THE ARMY
U. A. ARMY MOBILITY EQUIPMENT COMMAND
RESEARCH, DEVELOPMENT AND ENGINEERING DIRECTORATE
ATTN: AMSME-RZD
FORT BELVOIR, VIRGINIA 22060

OFFICIAL BUSINESS

POSTAGE AND FEES PAID

DEPARTMENT OF THE ARMY
U. S. ARMY MOBILITY EQUIPMENT COMMAND
RESEARCH, DEVELOPMENT AND ENGINEERING DIRECTORATE
ATTN: AMSME-RZD
FORT BELVOIR, VIRGINIA 22060

FOLD

D—36,485—Ft Belvoir

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:31Z
Check the source to verify that this is the current version before use.