INCH-POUND

MIL-PRF-52849D
13 August 1998
SUPERSEDING
MIL-T-52849C
27 October 1993

PERFORMANCE SPECIFICATION

TEST KIT, PETROLEUM: AVIATION FUEL CONTAMINATION (PORTABLE)

This specification is approved for use by all Departments and Agencies of the Department of Defense.

1 SCOPE

1.1 Scope. This specification covers a portable aviation fuel contamination test kit that is used to perform American Society Testing and Materials (ASTM) procedures to determine fuel quality.

2 APPLICABLE DOCUMENTS

2.1 General. The documents listed in this section are specified in sections 3 and 4 of this specification. This section does not include documents cited in other sections of this specification or recommended for additional information as examples. While every effort has been made to ensure the completeness of this list, document users are cautioned that they must meet all specified requirements documents cited in sections 3 and 4 of this specification, whether or not they are listed.

2.2 Government documents.

2.2.1 Specifications, standards, and handbooks. The following documents, specifications, standards, and handbooks form a part of this document to the extent specified herein. Unless otherwise specified, the issues of these documents are those listed in the issue of the Department of Defense Index of Specifications and Standards (DoDISS) and supplement thereto, cited in the solicitation (see 6.2).

Beneficial comments (recommendations, additions, deletions) and any pertinent data which may be of use in improving this document should be addressed to: U.S. Army Tank-Automotive and Armaments Command, ATTN:AMSTA-TR-D/210, Warren, MI 48397-5000 by using the Standardization Document Improvement Proposal (DD Form 1426) appearing at the end of this document or by letter.

AMSC N/A FSC 6630

Distribution Statement A. Approved for public release, distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:35Z
Check the source to verify that this is the current version before use.

SPECIFICATIONS

DEPARTMENT OF DEFENSE

MIL-STD-130 – Identification Marking of US Military Property
MIL-C-46168 – Coating, Aliphatic Polyurethane, Chemical Agent Resistant
MIL-HDBK-759C(2) – Human Engineering Design Guidelines

FEDERAL

A-A-2344A – Wrenches, Adjustable
A-A-58092 – Tape, Antiseize, Polytetrafluorethylene
A-A-53608 – Hydrometers, graduated scale
O-E-751 – Ether, Petroleum: Technical-Grade
FED-STD-595 – Colors Used in Government Procurement

(Unless otherwise indicated, copies of federal and military specifications, standards, and handbooks are available from the Standardization Documents Order Desk, Building 4D, 700 Robbins Avenue, Philadelphia, PA 19111-5094.)

2.3 Non-Government publications. The following documents form a part of this document to the extent specified herein. Unless otherwise specified, the issues of the documents which are DoD adopted are those listed in the issue of the DoDISS cited in the solicitation. Unless otherwise specified, the issues of documents not listed in the DoDISS are the issues of the documents cited in the solicitation (see 6.2).

NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION (NEMA)

NEMA Z535.2 – Environmental and Facility Safety Signs

(Application for copies should be addressed to the National Electrical Manufacturers Association 1300 N 17th St., Suite 1847, Rosslyn, VA 22209.)

NATIONAL FIRE PROTECTION ASSOCIATION (NFPA)

NFPA 70 – National Electrical Code

(Application for copies should be addressed to the National Fire Protection Association, One Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.)

AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)

ASTM D 1298 – Standard Practice for Density, Relative Density (Specific Gravity), or API Gravity of Crude Petroleum and Liquid Petroleum Products by Hydrometer Method
ASTM D 2276 – Standard Test for Particulate Contaminant in Aviation Fuel by Line Sampling
ASTM D 3240 – Standard Test Method for Undissolved Water in Aviation Turbine Fuels

(Application for copies should be addressed to the American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959.)

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:35Z
Check the source to verify that this is the current version before use.

2.4 Order of precedence. In the event of a conflict between the text of this document and the references cited herein, the text of this document takes precedence. Nothing in this document, however, supersedes applicable laws and regulations unless a specific exemption has been obtained.

3 REQUIREMENTS

3.1 Description. The one person-portable test kit is intended for use in the field to perform the following tests on petroleum products used for aviation:

a. API gravity.
b. Particulate contaminants.
c. Undissolved water.

The kit shall consist of the components and instructions necessary to perform not less than 10 (each) of the above tests, on individual samples, without replenishment of supplies.

3.2 First article. When specified (see 6.2), a sample kit shall be subjected to first article inspection in accordance with 4.2.

3.3 Performance characteristics.

3.3.1 Density. The test kit shall provide all components and materials necessary to determine density by the hydrometer method as specified in ASTM D 1298.

3.3.1.1 API gravity correction. The kit shall include a durable, weather-resistant, computing device with all inputs and data necessary to convert API gravity readings, at any temperature between 0 °F (-17.8 °C) and 200 °F (93.3 °C) to API gravity at 60 °F (15.6 °C). It shall also provide a tabulation of the corresponding specific gravities, to the nearest 0.001, for any API gravity in the range of 29 through 81. The accuracy and specifics shall be as specified by ASTM D 1298.

3.3.1.2 Hydrometers and hydrometer cylinder. The test kit hydrometers shall be API gravity thermo-hydrometers (thermometer scale in body), with a thermometer range of 20 °F (-6.7 °C) to 130 °F (54.4 °C), in accordance with A-A-53608. The hydrometers shall cover the nominal API gravity ranges from 29 to 81 degrees. The test kit hydrometer cylinder shall be in accordance with ASTM D 1298.

3.3.1.3 Spares. Each nominal API gravity range 29 to 81 degrees shall have a minimum of one spare hydrometer per range. For the nominal API gravity range between 35 to 50 degrees, an additional spare hydrometer per range shall be provided. Each kit shall also contain one spare hydrometer cylinder.

3.3.2 Particulate contaminants. The test kit shall provide all components and materials necessary to determine variations in the level of particulate contaminants in aviation turbine fuels by the filter membrane color rating method in accordance with ASTM D 2276. It shall also provide five (each) additional field monitors with two preweighed filter membranes per monitor for use in determining particulate contamination gravimetrically.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:35Z
Check the source to verify that this is the current version before use.

3.3.2.1 Sample bottle. The sample bottle shall have a minimum capacity of 1,000 milliliters (ml) (0.264 gallon (gal)) with graduated subdivisions not greater than 50 ml (0.0132 gal). The graduations shall be permanently marked on the bottle by silk-screening or other permanent method of marking.

3.3.2.2 Solvent dispenser bottle. The solvent dispenser bottle shall have a minimum capacity of 250 ml (0.066 gal) and shall dispense a fine, steady stream when squeezed. The spout cap for the tip shall be red and captive, and the closure shall be linerless, non-contaminating, and leak-proof. Materials used shall be capable of prolonged storage of petroleum ether.

3.3.2.3 Solvent. The solvent shall be a prefiltered petroleum ether in accordance with O-E-751.

3.3.2.4 Sampling valve connection. The sampling valve connection (actuator nipple) shall be ¼ inch (in.) MNPT. The kit shall also include a ¼ in. MNPT quick release coupler. Flexible pressure hose, as described in ASTM D 2276, shall be provided in the kit.

3.3.2.5 Antiseize tape. The antiseize tape shall be ½ in. (1.27 cm) wide, contained on a spool, and conform to A-A-58092.

3.3.2.6 Wrench. The wrench shall be an adjustable type, 8 in. (20 cm) in length, conforming to A-A-2344A.

3.3.3 Undissolved water content. The test kit shall provide the components necessary to determine the free-water content of fuel, using the Aqua-Glo method, in accordance with ASTM D 3240 (see 4.5.1.3). The detector shall be an Aqua-Glo– series III, with a battery recharger.

3.3.3.1 Spare parts. The kit shall also include one spare Aqua-Glo light bulb, one spare external rechargeable battery for the detector, and two spare calibration standards.

3.4 Carrying case. A carrying case, capable of containing all items needed to perform the required tests, shall be supplied. The carrying case shall be sufficiently waterproof and water vapor-proof to protect all kit items when sprayed continuously with water (see 4.5.3.1). A valve or other suitable means of pressure relief shall be installed for aircraft transportability. The valve or other pressure relief mechanism shall be placed such that carrying of the case or use of the kit shall not be hindered. The carrying case shall be fabricated so that all items are securely restrained and adequately cushioned to prevent damage during transit. The carrying case shall not be greater than 16.63 in. (42.2 cm) (H) x 20.00 in. (50.8 cm) (W) x 15.00 in. (38.1 cm) (D). The carrying case shall be provided with handles or grasp areas, and catches or latches designed to allow transport and operation by personnel wearing arctic mittens.

3.4.1 Weight. The weight of the kit, the carrying case fully supplied with its items, shall not exceed 42 lbs. (19.1 kg).

3.5 Kit loading diagram. A diagram or equivalent means of identifying equipment placement in the kit shall be supplied. The loading diagrams shall be shown on a durable plate, affixed to

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:35Z
Check the source to verify that this is the current version before use.

the inside of the unit's cover, or by other suitable means to easily identify storage locations and be legible for the life of the unit.

3.6 Environmental requirements.

3.6.1 Climatic. With the exception of the free-water detector, the kit shall be capable of performing in any ambient temperature from -25 ± 2 °F to 120 ± 2 °F (-32 ± 1 °C to 49 ± 1 °C) (see 4.5.3.3 and 4.5.3.5). The free-water detector shall be capable of performing in any ambient temperature from 33 ± 2 °F to 120 ± 2 °F (0.6 ± 1 °C to 49 ± 1 °C) (see 4.5.3.3 and 4.5.3.5). When placed in storage, the test kit shall not be damaged in any ambient temperature from -28 ± 2 °F to 145 ± 2 °F (-33 ± 1 °C to 63 ± 1 °C) (see 4.5.3.2 and 4.5.3.4).

3.6.2 Fungus resistance. Where possible, moisture and fungus-resistant materials shall be used. Where this is not possible, materials shall be coated for protection.

3.6.3 Transportability. With exception of the free-water detector, the kit shall be capable of withstanding the vibration stress and shock encountered when transported by all standard modes of transportation (see 4.5.4).

3.7 Human factors. The construction shall foster effective performance of operating procedures, an effective personnel safety and health environment, and minimize factors that contribute to increased operator error. The unit shall incorporate protection from electrical, thermal, mechanical, and other potential hazards. The construction shall also reflect efficient arrangement of equipment and components, and feature characteristics that ensure safety and ease of use. The equipment shall represent the simplest design consistent with functional requirements.

3.7.1 Accessibility. Compartment access and grasp areas shall reflect compatibility with the Clothing and Personal Equipment (C/PE) of personnel using and maintaining equipment, under the environmental conditions specified herein. Grasp areas shall also be located to provide clearance from obstructions, and shall not interfere with operation or maintenance of the unit. The proper orientation of ancillary items and components for stowage on the unit shall be made obvious, either through compartment or fixture design or by means of appropriate labels (see 4.5.2).

3.7.2 Safety. The construction shall incorporate methods to protect personnel from shock hazards, to include consideration of ground currents and voltage limits (possible arcing) according to NFPA 70. Adequate safe-guards shall be incorporated into the kit and its components so that personnel shall not be exposed to concentrations of toxic or corrosive substances. Equipment that, in normal operation, exposes personnel to surface temperatures greater than 130 ± 2 °F (54 ± 1 °C) for prolonged contact or handling, or 140 ± 2 °F (60 ± 1 °C) for momentary contact, shall be appropriately guarded. Except where functionally required, exposed surfaces shall be free from burrs, sharp edges and corners, or other features that present a personnel safety hazard; or shall be shielded against contact. Danger or caution signs, labels, and markings shall be used to warn of potential or specific hazards according to NEMA Z535.2.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:35Z
Check the source to verify that this is the current version before use.

3.7.3 Labeling. To avoid hazardous or unsafe operation labels, legends, instruction placards, signs, markings, or combinations of all shall be provided for personnel to identify, interpret and follow procedures. Instructions for test methods shall be clearly visible, and shall not be damaged, or made illegible, by frequent use, extended storage, or cited environmental conditions. Label characteristics shall be consistent with the accuracy of identification required, the time available for recognition, and the appropriate response, the distance at which the labels must be read, and in accordance with the requirements of NEMA Z535.2. Labels shall be permanent and have a high contrast, foreground to background.

3.8 Markings. The kit shall be identified in accordance with MIL-STD-130 to include item nomenclature, NSN (National Stock Number), manufacturer's part number, CAGE (Commercial and Government Entity), contract number and serial number.

3.9 Materials. The manufacturer shall select materials capable of meeting all the operational and environmental requirements specified herein. Kit components shall not incorporate readily breakable material except where no alternative is available such as glass for optical lenses. Test kit components shall be resistant to fuel and fuel esters, ultraviolet radiation, and ozone deterioration.

3.9.1 Material deterioration and control. The kit and its components shall be fabricated from compatible materials, inherently corrosion and deterioration resistant, or treated to provide protection against the various forms of corrosion and deterioration to which they are susceptible.

3.9.2 Dissimilar metals. Dissimilar materials shall be isolated from one another to prevent or minimize galvanic corrosion.

3.9.3 Recycled, recovered, or environmentally preferable materials. Recycled, recovered, or environmentally preferable materials should be used to the maximum extent possible provided that the material meets or exceeds the operational and maintenance requirements, and promotes economically advantageous life cycle costs. Used, rebuilt, or remanufactured components, pieces and parts shall not be incorporated into the kits.

3.10 Treatment and painting. Unless otherwise specified (see 6.2), the cabinet shall be cleaned, treated, and painted in accordance with the manufacturer's standard commercial practice. The exterior of the kit shall be finished with a Chemical Agent Resistant Coating (CARC) according to MIL-C-46168. The color shall be Army green #383, color #34094 of FED-STD-595.

4 VERIFICATION

4.1 Classification of inspections. The inspection requirements specified herein are classified as follows:

a. First article inspection (see 4.2).
b. Conformance inspection (see 4.3).

4.2 First article inspection. The first article inspection shall be performed on one complete test kit. The inspection shall include the examinations of 4.4 and the testing of 4.5.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:35Z
Check the source to verify that this is the current version before use.

4.3 Conformance inspection. The conformance inspection shall include examinations of 4.4.

4.4 Examination. Each test kit shall be examined physically for compliance with the requirements specified in table I. This element of inspection shall encompass all examinations of performance, safety, human engineering, and dimensional requirements. Noncompliance with any specified requirement, or the presence of any defect(s) preventing performance of specified tests, shall constitute cause for rejection.

TABLE I Examination.

Number	Examination Description	Reqt Para	Method of Exam.
101	Density test components and materials not as specified	3.3.1	Visual/Doc.
102	Particulate contaminant test components and materials not as specified	3.3.2	Visual/Doc.
103	Undissolved water test components and materials not as specified	3.3.3	Visual/Doc.
104	Carrying case not as specified	3.4	Visual/Doc./SIE
105	Kit loading diagram not as specified	3.5	Visual/Doc.
106	Environmental factors not as specified	3.6	Visual/Doc./SIE
107	Human factors not as specified	3.7	Visual/Doc.
108	Marking not as specified	3.8	Visual/Doc.
109	Materials not as specified	3.9	Visual/Doc./SIE
110	Treatment and painting not as specified	3.10	Visual/Doc.

Doc. = Document, SIE = Standard Inspection Equipment

4.5 Tests.

4.5.1 Performance. Performance testing shall be conducted at room temperature (68 ± 2 °F or 20 ± 1 °C) unless otherwise specified.

4.5.1.1 API gravity (hydrometer method). The test shall be conducted in accordance with ASTM D 1298 with a known fuel sample. Five readings shall be taken. Missing components or supplies, failure to complete all procedures, or deviation of a test value from any other test value greater than that cited in the repeatability section of ASTM D 1298, shall constitute failure of this test.

4.5.1.2 Particulate contamination test. The test shall be conducted in accordance with the filter membrane color rating method of ASTM D 2276, using a range of contaminated fuel samples, sufficient to demonstrate workability of the test and associated color standards. A minimum of five different samples shall be used. Missing components or supplies required for the test, failure to complete procedures, or to demonstrate procedure workability, shall constitute failure of this test.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:35Z
Check the source to verify that this is the current version before use.

4.5.1.3 Undissolved water content. The test shall be conducted in accordance with ASTM D 3240 using a known fuel sample. Concentration of undissolved water of five individual aliquots of the sample shall be measured. Missing components or supplies, failure to complete all procedures, or deviation of a test value from any other value greater than that cited in the repeatability section of ASTM D 3240 shall constitute failure of this test.

4.5.2 Loading. The components of the kit shall be completely removed and placed on a work surface in random order. An adult (i.e., a man or woman 21 years of age or older) who has never seen the components assembled in the kit shall be tasked to do so, utilizing only the kit loading diagram as reference. Failure to install all components, any undue force required to assemble any component or close the case, deformation of components or case, or failure to complete within five minutes shall constitute failure of the test.

4.5.3 Environmental.

4.5.3.1 Waterproof and water vapor-proof. For the waterproof and water vapor-proof test close and latch the test kit case, direct a water spray through nozzles to cover the parting line between the sections of the case, hinge(s), and the carrying handle(s). The spray nozzle shall give uniform water distribution and shall have a flow capacity of not less than 1 ± 0.1 gallon per minute (gpm) (3.8 ± 0.4 liter/minute) per nozzle at 40 pounds per square inch (psi) (275 kiloPascals (kPa)) water pressure. Fogging nozzles shall not be used. Angle the spray to each of the surfaces so water strikes at an angle of between 40 and 90 degrees to the surfaces. Spray time on each case surface shall not be less than 3 minutes continuous at 30 to 40 psi (207 to 275 kPa) water-line pressure and water temperature between 40 ± 2 °F to 75 ± 2 °F (4 ± 1 °C to 24 ± 1 °C). At the conclusion of the spray period the case shall be opened and examined for water leakage to the case interior. Water leakage shall constitute failure of the test.

4.5.3.2 High temperature-storage. The test kit shall be subjected to a high temperature environment of 145 ± 2 °F (63 ± 1 °C) for 4 hours, after an initial period of 6 hours at 120 ± 2 °F (49 ± 1 °C). Raising and lowering of the temperature shall be accomplished within a period of 1 hour, for a total cycle time of 12 hours. A minimum of seven cycles (84 hours) is required. At completion of the last cycle, adjust chamber air temperature to 68 ± 2 °F (20 ± 1 °C) and maintain until temperature stabilization of test kit has been achieved. Conduct the test procedures outlined in 4.5.1.1 through 4.5.1.3. In addition to the conformance criteria cited therein, the kit case and packing material shall be examined for deterioration, brittleness, or cracking. Functional failure of the kit components, case, or packing material, or inability to perform tests, or satisfy test precision criteria shall constitute failure of this test.

4.5.3.3 High temperature-operational. The test kit, with the case open, shall be subjected to a high temperature of 120 ± 2 °F (49 ± 1 °C) for a period of 4 hours. Conduct the test procedures outlined in 4.5.1.1 through 4.5.1.3, while the temperature is maintained at 120 ± 2 °F (49 ± 1 °C). In addition to the conformance criteria cited therein, functional failure of the kit components, inability to perform the tests or satisfy test precision criteria shall constitute failure of this test.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:35Z
Check the source to verify that this is the current version before use.

4.5.3.4 Low temperature-storage. The test kit shall be subjected to a low temperature environment of -28 ± 2 °F (-33 ± 1 °C) for a period of 48 hours. At the end of this exposure, adjust the chamber air temperature to 68 ± 5 °F (20 ± 1 °C) and maintain until temperature stabilization of test kit has been achieved. Conduct the test procedures cited in 4.5.1.1 through 4.5.1.3. In addition to the conformance criteria cited therein, the kit case and packing material shall be examined for deterioration, brittleness, or cracking. Functional failure of the kit components, case, or packing material, or inability to perform tests, or satisfy test precision criteria shall constitute failure of this test.

4.5.3.5 Low temperature-operational. The test kit shall be subjected to a low temperature environment of -25 ± 2 °F (-32 ± 1 °C) for a period of 4 hours. At the end of this exposure, while still at -25 ± 2 °F (-32 ± 1 °C), conduct the test procedures cited in 4.5.1.1 and 4.5.1.2. Upon completion of these tests, raise the temperature to 1 (+0 –1) °C, maintain until temperature stabilization of test kit has been achieved, and conduct the test cited in 4.5.1.3. In addition to the conformance criteria cited therein, functional failure of the kit components, inability to perform the tests or satisfy test precision criteria shall constitute failure of this test.

4.5.4 Transportability.

4.5.4.1 Vibration. The test kit packaged in its carrying case shall endure 40 minutes of vibration in each of 3 axes. The test bed shall produce a 1 inch (2.54 cm), double amplitude, orbital path, at 5 Hz. Damage or breakage of the case or any component of the kit, shall constitute failure of this test.

4.5.4.2 Shock. Each case and its components shall withstand a drop test performed on an 8 in. (20 cm) thick bed of dry sand from a height of 48 in. (122 cm). Drop tests shall be conducted at -25 ± 5 °F (-32 ± 2 °C) and at 140 ± 5 °F and at 60 ± 2 °C). Cases and components shall be subjected to one cornerwise drop on each of diagonally opposite corners. Each shall then be subjected to one flat drop on the bottom, the top, and two adjacent sides, then one edgewise drop on each edge of the case. For edgewise drops, the striking edge shall be parallel with the dropping surface at the instant of release. For edgewise and cornerwise drops, the case center of gravity shall be directly above the striking edge or corner of case at instant of release. All drops shall be made so that the test kit falls freely through the distance of 48 inches (122 cm). Upon completion of this test, each sample kit shall be examined for damage to the case and each component and accessory. Any evidence of permanent deformation, cracks, or damaged items shall constitute failure of this test.

5 PACKAGING

5.1 Packaging. For acquisition purposes, the packaging requirements shall be as specified in the contract or order (see 6.2). When actual packaging of materiel is to be performed by DoD personnel, these personnel need to contact the responsible packaging activity to ascertain requisite packaging requirements. Packaging requirements are maintained by the Inventory Control Point's packaging activity within the Military Department or Defense Agency, or within the Military Department's System Command. Packaging data retrieval is available from the managing Military Department's or Defense Agency's automated packaging files, CD-ROM products, or by contacting the responsible packaging activity.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:35Z
Check the source to verify that this is the current version before use.

6 NOTES

(This section contains information of a general nature which may be helpful, but is not mandatory.)

6.1 Intended use. The test kit is intended for use in the field to perform quality control tests on petroleum products used for aviation. Because of the extreme climatic conditions under which this item must perform (see 3.6.1), this item is military unique.

6.2 Acquisition requirements. Acquisition documents must specify the following:

a. Title, number, and date of this publication.
b. Issue of DoDISS to be cited in the solicitation, and if required, the specific issue of individual documents referenced (see 2.2.1 and 2.3).
c. When a first article is required (see 3.2).
d. When color other than army green is required (see 3.10).
e. Packaging requirements (see 5.1).

6.3 First article inspection. When a first article inspection is required the item should be a first article production unit(s). The contracting officer should include specific instructions in acquisition documents regarding the number of units required, arrangements for examination and testing, approval of the first article test results and disposition of the first article.

6.4 Data Requirements. The contracting officer should include requirements for such data as parts lists, consumable items lists, etc., to be furnished with each test kit.

6.5 Definitions.

6.5.1 Dissimilar metals. For the purposes of this specification, metals are dissimilar when two metal specimens in contact with each other promote accelerated galvanic corrosion.

6.5.2 Recycled material. For the purpose of this requirement, recycled materials are those that have been collected from solid waste and reprocessed to become a source of raw materials, as distinguished from virgin raw materials.

Subject term (key word) listing.

Aqua-Glo®
Contaminants
Gravity
Hydrometer

Custodians:
Army – AT
Air Force - 68

Preparing activity:
Army - AT
(Project 6630-0569)

Review Activity:
DLA – DM

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:35Z
Check the source to verify that this is the current version before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

INSTRUCTIONS

1. The preparing activity must complete blocks 1, 2, 3, and 8. In block 1, both the document number and revision letter should be given.
2. The submitter of this form must complete blocks 4, 5, and 7.
3. The preparing activity must provide a reply within 30 days from receipt of the form.

NOTE: This form may not be used to request copies of documents, nor to request waivers, or clarification of requirements on current contracts. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document(s) or to amend contractual requirements.

I RECOMMEND A CHANGE:	1. DOCUMENT NUMBER	2. DOCUMENT DATE *(YYMMDD)*
	MIL-PRF-52849D	980813

3. DOCUMENT TITLE

Test Kit, Petroleum: Aviation Fuel Contamination (Portable)

4. NATURE OF CHANGE ***(Identify paragraph number and include proposed rewrite, if possible. Attach extra sheets as needed.)***

5. REASON FOR RECOMMENDATION

6. SUBMITTER

a. NAME *(Last, First, Middle Initial)*	b. ORGANIZATION	
c. ADDRESS *(Include Zip Code)*	d. TELEPHONE *(Include Area Code)* (1) Commercial (2) AUTOVON *(If applicable)*	7. DATE SUBMITTED *(YYMMDD)*

8. PREPARING ACTIVITY

a. NAME	b. TELEPHONE *(Include Area Code)* (1) Commercial (2) AUTOVON
c. ADDRESS *(Include Zip Code)* Commander U.S. Army Tank-automotive and Armaments Command ATTN: AMSTA-TR-E/BLUE Warren, MI 48397-5000	(810) 574-8745 786-8745 IF YOU DO NOT RECEIVE A REPLY WITHIN 45 DAYS, CONTACT: Defense Quality and Standardization Office 5203 Leesburg Pike, Suite 1403 Falls Church, VA 22041-3466 Telephone (703) 756-2340 AUTOVON 289-2340

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:35Z
Check the source to verify that this is the current version before use.