INCH-POUND

A-A-59573
April 05, 2004

COMMERCIAL ITEM DESCRIPTION

LIGHT, EXTENSION- (PORTABLE, FLUORESCENT, HAZARDOUS LOCATION USE)

1. SCOPE

1.1 Scope. This commercial item description covers a 120VAC powered, handheld, 26 watt fluorescent work light that is Factory Mutual (FM) or Underwriter Laboratories (UL) labeled to be safe for use in, Class I, Division 1, Group C & D, hazardous locations as defined by National Electric Code (NEC). The Light will meet the form, fit, and function of the following description.

2. SALIENT CHARACTERISTICS.

2.1 Capacity. The light shall have 1800 lumen output when operated with 26 watt fluorescent lamp at 120 VAC 60Hz input power.

2.2 Design. The light shall have a closed end guard with hook to support light in hanging position while in hazardous location and hand size handle to hold with single hand on power cord end.

2.3 Physical Characteristics (Nominal).

Length	23 inches
Diameter	4 inches
Weight	4 lbs.

Beneficial comments, recommendations, additions, deletions, clarification, etc. and any other data that may improve this document should be sent to: FSC6230 ENGR WR-ALCLEEG, 295 Bryon Street, Robins AFB,GA 31098-1611

AMSC N/A FSC 6230

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:18Z
Check the source to verify that this is the current version before use.

2.4 Power Cord. The power cord shall have exterior cover compatible with Hazardous location materials and shall be 75 foot length three conductor 16 AWG without the plug to allow use of either hazardous location or standard plug.

2.5 Guard and Handle. The guard and handle shall be corrosion resistant and have non-magnetic exterior surfaces.

2.6 Hazardous Location Certification Tested. Approved/listed/labeled with testing certification number by UL or FM for use in following Hazardous Locations:
CLASS I DIVISION 1 GROUP C& D AND
CLASS II DIVISION 1 GROUP F & G

3. REGULATORY REQUIREMENTS.

3.1 Recycled recovered materials. The offeror/contractor is encouraged to use recovered materials to the maximum extent practicable, in accordance with paragraph 23.403 of the Federal Acquisition Regulation (FAR).

4. PRODUCT CONFORMANCE PROVISIONS.

4.1 Product Conformance. The products produced shall meet all salient characteristics of this specification, conform to the producer's own drawings, specifications, standards, and quality assurance practices, and be the same product offered for sale in the commercial market. The Government requires the manufacturer to submit with each unit a Certificate of Conformance stating that all salient characteristics of this specification are met. The Government reserves the right to return to the contractor any and all items that does not satisfactorily perform the necessary requirements.

4.2 Records. Records of examinations and tests performed by or for the contractor shall be maintained by the contractor and made available to the Government upon the Government's request, at any time, or from time to time, during the performance of the contract and for a period of three years after delivery of the supplies to which such records relate.

4.3 Hazardous Location Certification. All supplied items shall carry a UL or FM standard commercial certification label referencing Hazardous Locations certified for and testing document number. One copy of the certification information shall be shipped to the cognizant engineer at this location; FSC 6230 Engineer, WR-ALC/LEEG, 295 Byron Street, Robins AFB, GA 31098-1611.

5. PACKAGING.

5.1 Preservation, packing, and marking. Preservation, packing, and marking shall be as specified in the contract or order.

6. NOTES

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:18Z
Check the source to verify that this is the current version before use.

6.1 Alternative offers. Alternate Offers considered as dealers/distributors of above approved manufacturer suggested sources of supply are also considered approved vendor sources of supply provided they can certify they are proposing to supply one of the above approved CAGE/part numbers.

6.2 All other alternate offers,:

a.) Not listed as a suggested source of supply above,

b.) Having a product that meets above salient characteristics,

c.) Being UL or FM tested/approved/listed/labeled for Hazardous Location, CLASS I DIVISION 1 GROUP C& D and CLASS II DIVISION 1 GROUP F & G, and

d.) Desiring to receive a contract to furnish their product for USAF use shall first submit an item for technical evaluation/approval by the FSC 6230 cognizant engineer.

6.3 SUGGESTED SOURCES OF SUPPLY

The following table lists current sources:

MFG SOURCE(S) OF SUPPLY		
NAME & ADDRESS	**CAGE**	**PART NUMBER**
Stewart R. Browne Mfg. 1165 Hightower Trail Atlanta, GA 30350-2911 770-993-9600	83303	XP87B-75
K&H Industries Inc. 8656 Delamater Rd Angola, NY 14006-9691 716-549-0135	15664	EP326-16E-75C
Daniel Woodhead Company 3411 Woodhead Dr. Northbrook, IL 60062 847-272-7990	79409	1090-HZC163

Authorized dealers and distributors of above manufacturers are also considered approved sources of supply provided they certify that they are proposing to supply one of prior approved manufacturer items.

NSN 6230-01-463-4339

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:18Z
Check the source to verify that this is the current version before use.

Custodian:
Air Force - 99

Preparing Activity:
Air Force – 84

Agent Activity:
Air Force – 99

(Project No. 6230-1089)

NOTE: The activities listed above were interested in this document as of the date of this document. Since organizations and responsibilities can change, you should verify the currency of the information above using the ASSIST Online database at www.dodssp.daps.mil.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T10:18Z
Check the source to verify that this is the current version before use.