
W-F-1814/66A
February 20, 1987
SUPERSEDING
W-F-1814/66
October 21, 1982

FEDERAL SPECIFICATION SHEET

FUSES, CARTRIDGE, HIGH-INTERRUPTING CAPACITY, CLASSES RK1 AND RK5 (CURRENT-LIMITING) 600 VOLTS, 201-400 AMPERES

This specification is approved by the Commissioner, Federal Supply Service, General Services Administration, for the use of all Federal agencies.

The complete requirements for procuring the fuses described herein shall consist of this document and the latest issue in effect of specification W-F-1814/GEN.



Inches	mm
.005	0.13
.250	6.35
625	15 88
1 435	36 91
1.625	41.29
1.875	47.63
2 50	63 5
2 91	73.9
7.125	180.98
7.831	198.91
11.625	295.28

NOTES
1 Dimensions are in inches.
2 Metric equivalents are given for general information only
3 Use of screw, pin, or rivet is optional.
4 The dashed line represents the limit of the maximum projection of a screw, rivet head, or the like

FIGURE 1 Classes RK1 and RK5 fuses, 600 volts, 201-400 amperes.

DISTRIBUTION STATEMENT A Approved for public release, distribution is unlimited

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:37Z
Check the source to verify that this is the current version before use.

REQUIREMENTS

Design and construction See figure 1.

Physical Nonrenewable.

Terminals Knife blade type

Material Copper or copper alloy

Strength 5 inch-pound torque between body and blades.

Body

Insulating material. Fiber, ceramic, melamine-impregnated glass fiber, or other suitable material

Electrical

Voltage 600 volts or less

Frequency 48 to 60 hertz

Current See table I.

Current carrying capacity 110 percent indefinitely with temperature rise not to exceed 50°C (90°F) above ambient on the body and 65°C (117°F) on the blades.

Overload interrupt

Instantaneous Shall interrupt within 2 hours at 135 percent of rated current and within 6 minutes at 200 percent of rated current.

Time delay In addition to the above requirement, the fuse shall not interrupt 500 percent of rated current within 10 seconds.

Interrupting capacity rating 200,000 amperes rms symmetrical at 600 volts, 48 to 60 hertz and a power factor of 20 percent or less Closing angle shall be essentially at the zero of the voltage wave (maximum offset) or later, to produce start of arcing within 30 electrical degrees prior to system peak voltage

Threshold ratio 30 maximum for RK1, 65 maximum for RK5.

Peak let-thru current See table II

Maximum clearing I^2T See table II

Applicable fuseholder Part number W-F-870/8-07 of W-F-870/8

Government part number The Government part number shall consist of the prefix "WF1814/66-" followed by the part number designation shown in table I

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:37Z
Check the source to verify that this is the current version before use.

TABLE I. Current rating and part number designation

Current in amperes	Part number designation			
	RK5		RK1	
	Instantaneous	Time delay	Instanta-neous	Time delay
225	F5225	D5225	F1225	D1225
250	F5250	D5250	F1250	D1250
300	F5300	D5300	F1300	D1300
350	F5350	D5350	F1350	D1350
400	F5400	D5400	F1400	D1400

TABLE II. Peak let-thru and I^2T current.

	Between threshold and 50 kA		100 kA		200 kA	
	RK1	RK5	RK1	RK5	RK1	RK5
Maximum acceptable peak let-current ($I_p \times 10^3$)	33	50	35	60	50	75
Maximum clearing I^2T (amperes squared seconds) ($I^2T \times 10^3$)	1200	5000	1200	5000	1600	5000

MILITARY INTERESTS

Custodians

Army - ER
Navy - YD
Air Force - 85

Review Activities

Army - AL, AT, ME
Air Force - 99
DLA - ES
NS

User Activities

Army - AR
Navy - OS

CIVIL AGENCY COORDINATING ACTIVITIES

DOE - DOE
COMMERCE - NBS
DOT - ACO, APM
GPO - GPO
GSA - FSS
JUSTICE - FPI
NASA - JFK, LRC
USPS - POS
VA - OSS

PREPARING ACTIVITY

DLA - ES

(Project 5920-0434-11)

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:37Z
Check the source to verify that this is the current version before use.