A-A-2376
August 29, 1985

COMMERCIAL ITEM DESCRIPTION

NOZZLE, FIRE HOSE, WATER (PLASTIC)

The General Services Administration has authorized the use of this commercial item description.

This description covers plastic nozzles capable of producing either a solid fog or a straight stream for fire-fighting purposes. The nozzles shall be available in the following classes:

Class A - 1-1/2 inch diameter x 9NH
Class B - 1-1/2 inch diameter x 11.5 NPSH

Salient characteristics.

Red polycarbonate body with a brass stem.
Shall be capable of three positions: shut-off, fog spray, and straight stream.
Shall have a minimum flow of 60 gallons per minute at 100 psig in either straight stream or any fog position.
Shall be provided with rubber bumpers.
Shall be impervious to grease, oil, acids, and chemicals.
Shall be adjustable while in operating mode.

Proof pressure test. The nozzles shall be tested to 1000 psig in the shut-off position for five minutes. The nozzles shall then be examined for any distortion, mechanical damage, or leaks. Any evidence of failure shall be cause for rejection.

Workmanship. Nozzle shall be free of any defects which may affect the durability, appearance, or serviceability.

Conformance. Nozzles shall be Factory Mutual (FM) approved.

Regulatory requirements. In accordance with section 23.403 of the Federal Acquisition Regulations, the Government's policy is to acquire items composed of the highest percentage of recovered materials practicable, consistent with maintaining a satisfactory level of competition without adversely affecting performance requirements or exposing supplier's employees to undue hazards from the recovered materials.

Preservation, packaging, packing, labeling, and marking. The preservation, packaging, packing, labeling, and marking shall be as specified in the contract or order.

FSC 4210

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:22Z
Check the source to verify that this is the current version before use.

Note. When this commercial item description is used for procurement, the commercial item certification clause must appear in the solicitation.

Purchaser shall specify class of nozzle desired.

Copies of Factory Mutual standards are available from the Factory Mutual Engineering Corp., 1151 Providence Hwy., Norwood, MA 02062.

MILITARY INTERESTS:

Review Activity

Army - ME

CIVIL AGENCY COORDINATING ACTIVITY:

USDA - AFS

PREPARING ACTIVITY:

GSA -- FSS

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:22Z
Check the source to verify that this is the current version before use.