A-A-2402
February 19, 1986

# COMMERCIAL ITEM DESCRIPTION

## EXTINGUISHER, FIRE, VAPORIZING LIQUID (HEAT-ACTUATED, HALON 1301)

The General Services Administration has authorized the use of this commercial item description.

This commercial item description covers heat-actuated Halon 1301 fire extinguishers for use in small, confined areas, i.e., bank vaults, marine compartments, etc. The following types are available, as specified:

| Type | Maximum Volume Protected (Cu. Ft.) (At 5% Concentration) | Min. Quantity of Halon 1301 (lbs) | Actuation Temperature (°F) |
|---|---|---|---|
| A | 75 | 1.5 | 212 |
| B | 200 | 4.0 | 165 |
| C | 350 | 7.0 | 165 |
| D | 500 | 10.0 | 165 |
| E | 750 | 15.0 | 165 |
| F | 1000 | 20.0 | 165 |

Salient characteristics.

Charge. Monobromotrifluoromethane (Halon 1301).
Cylinder. Tempered aluminum, baked epoxy finish, disposable, per Department of Transportation Specification 39.
Brackets. Stainless steel or combination of aluminum and stainless steel.
Indicator Lamp. A visual charge/discharge indicator lamp for mounting shall be provided.
Pressure Gauge. Provided if specified.

Conformance. The extinguishers shall be Factory Mutual and US Coast Guard approved.

Workmanship. The extinguishers shall be free of defects which may affect the durability, appearance, or serviceability.

Regulatory requirements. In accordance with section 23.403 of the Federal Acquisition Regulations, the Government's policy is to acquire items composed of the highest percentage of recovered materials practicable, consistent with maintaining a satisfactory level of competition without adversely affecting performance requirements or exposing supplier's employees to undue hazards from the recovered materials.



Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:22Z
Check the source to verify that this is the current version before use.

Preservation, packaging, packing, labeling, and marking. The preservation, packaging, packing, labeling, and marking shall be as specified in the contract or order.

Note. When this commercial item description is used for procurement, the commercial item certification clause must appear in the solicitation.

Purchaser shall specify type of extinguisher and if pressure gauge is to be provided.

Copies of Factory Mutual standards are available from the Factory Mutual Engineering Corporation, 1151 Providence Hwy., Norwood, MA 02062.

Copies of Department of Transportation specifications are available from the Publications Office, Department of Transportation, 400 7th Street, SW, Washinton, DC 20590.

MILITARY INTERESTS:

User Activity

Army - ME

PREPARING ACTIVITY:

GSA - FSS



Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:22Z
Check the source to verify that this is the current version before use.