Fed. Std. No. 128a
October 18, 1961
(W–J–800, Issue in Effect)

SUPERSEDING
Int. Fed. Std. No. 128 (GSA–FSS)
December 9, 1958

FEDERAL STANDARD

JUNCTION BOX; EXTENSION, JUNCTION BOX; COVER, JUNCTION BOX, (STEEL, CADMIUM OR ZINC COATED) (FOR USE WITH METALLIC CONDUIT SYSTEMS)

Authority.—*This standard is issued pursuant to the Federal Property and Administrative Services Act of 1949, as amended, and its application to the purchase of commodities referred to herein is mandatory on all Federal agencies.*

S1. Purpose and scope. The purpose of this standard is the establishment of a standard list of junction boxes, junction box extensions and junction box covers for use with rigid steel conduit, electric metallic tubing, armored sheathed cable, and flexible metallic conduit, as required for ordinary maintenance and extension of circuit purposes as required by Government maintenance activities. This standard will keep the varieties of such boxes, extensions, and covers which are to be procured and stocked to the minimum consistent with such requirements. It does not cover nonmetallic junction boxes, cast-metal boxes, conduit bodies, boxes for use with nonmetallic sheathed cable or nonmetallic tubing, or hinged cover boxes.

S2. Application. Purchases from commercial sources under Federal Specification W–J–800, of the issue in effect on date of invitation for bids, shall be limited to items which have characteristics conforming to the standard items specified herein. Existing Government stocks of items with other characteristics shall continue to be utilized until exhausted. In those cases where this Federal Standard eliminates supply items and the items so eliminated are under contract, if the contract cannot be negotiated or amended to conform to the standard items, the Federal Standard becomes mandatory at the contract expiration date.

S3. Standard characteristics and item identification. The standard items with their applicable Federal Stock Numbers shall conform to the characteristics listed below:

	Fed. Stock No.
Type I—Octagon junction box	
Size A—3¼″ by 1½″	
Style No. (knock-out configuration):	
2—Bottom: One ½″; other: Four ½″	5975–153–6392
Style No. (knock-out configuration):	
3—Bottom: One ½″; other: Four ¾″	5975–194–8862
Size B—4″ by 1½″	
Style No. (knock-out configuration):	
4—Bottom: Two ½″, Four 21/32″; other: Two ½″, Four 21/32″	5975–194–8858
5—Bottom: Four 21/32″; other: Four 21/32″ w/armored cable clamps, Two ½″; ⅜″ fixture stud	5975–281–0663
Style No. (knock-out configuration):	
6—Bottom: Three ½″, Two ¾″; other: Four ¾″	5975–153–6396
7—Bottom: Five ½″, other: Four ½″	5975–153–6395

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:54Z
Check the source to verify that this is the current version before use.

Type I—Octagon Junction Box *(Cont'd)*

	Fed. Stock No.
Size C—4″ by 2⅛″	
Style No. (knock-out configuration):	
8—Bottom: Three ½″, Two ¾″; other: Four ¾″	5975–255–4483
9—Bottom: Five ½″; other: Four ½″	5975–153–6397

Type II—Square junction box

Size D—4″ by 1½″	
Style No. (knock-out configuration):	
10—Bottom: Three ½″, Two ¾″; other: Eight ½″, Four ¾″	5975–153–6398
11—Bottom: Three ½″, Two ¾″; other: Eight ¾″	5975–194–8864
12—Bottom: Five ½″; other Ten ½″	5975–194–8878
Size E—4″ by 2⅛″	
Style No. (knock-out configuration):	
13—Bottom: Three ½″, Two ¾″; other: Eight ¾″	5975–194–8880
14—Bottom: Two ¾″, Three ½″; other: Eight 1″	5975–280–4121
15—Bottom: Five ½″; other: Twelve ½″	5975–194–8877
Size F—4 11/16″ by 1½″	
Style No. (knock-out configuration):	
16—Bottom: Three ½″, Two ¾″; other: Eight ¾″	5975–194–8852
17—Bottom: Three ½″, Two ¾″; other: Twelve ½″	5975–223–4277
Size G—4 11/16″ by 2⅛″	
Style No. (knock-out configuration):	
18—Bottom: Three ½″, two ¾″; other: Eight 1″	5975–194–8879
19—Bottom: Three ½″, Two ¾″; other: Four ½″, Six ¾″	5975–194–8874
20—Bottom: Three ½″, Two ¾″; other: Eight ½″, Two ¾″	5975–194–8873
21—Bottom: Three ½″, Two ¾″; other: Twelve ½″	5975–224–6022

Type III—Handy junction box (nongangable device box)

Size H—4″ by 2⅛″ by 1½″	
Style No. (knock-out configuration):	
22—Bottom: Three ½″; other: Eight ½″	5975–194–8871
Size I—4″ by 2⅛″ by 1⅞″	
Style No. (knock-out configuration):	
23—Bottom: Three ½″; other: Eight ½″	5975–281–0090

Type III—Handy Junction Box (nongangable device box *(Cont'd)*

24—Bottom: Two ¾″; other: Six ¾″	5975–194–8870
Size J—4″ by 2⅛″ by 2⅛″	
Style No. (knock-out configuration):	
25—Bottom: Three ½″; other: Eight ½″	5975–284–5827

Type IV—Switch box, sectional type (gangable)

Size K—3″ by 2″ by 2″	
Style No. (knock-out configuration):	
29—Bottom: One ½″; other: Six ½″	5975–153–6387
30—Bottom: One ½″, Four 21/32″; other: Four 21/32″	5975–153–6386
Size L—3″ by 2″ by 2½″	
Style No. (knock-out configuration):	
31—Bottom: One ½″; other: six ½″	5975–153–6388
32—Bottom: One ½″; other: Eight 23/32″ w/armored cable clamps	5975–194–8856
33—Bottom: One ½″; other: Eight 23/32″ w/armored cable clamps and lateral bracket	5975–194–8855
Size M—3″ by 2″ by 2¾″	
Style No. (knock-out configuration):	
35—Bottom: One ½″; other: Eight 23/32″ w/armored cable clamps	5975–153–6389

Type V—Octagon junction box ring

Size M-N—3¼″ x 1½″	
Style No. (knock-out configuration):	
35.5—Four ½″	5975–557–2688
Size N—4″ x 1½″	
Style No. (knock-out configuration):	
36—Four ½″	5975–194–8848
37—Four ¾″	5975–194–8847
Size O—4″ by 2⅛″	
Style No. (knock-out configuration):	
38—Four ¾″	5975–280–6054

Type VI—Square junction box ring

Size P—4″ by 1½″	
Style No. (knock-out configuration):	
39—Ten ½″	5975–194–8868
40—Eight ¾″	5975–194–4997

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:54Z
Check the source to verify that this is the current version before use.

	Fed. Stock No.
Type VII—Handy junction box ring	
Size Q—4″ by 2⅛″ by 1½″	
Style No. (knock-out configuration):	
41—Eight ½″	5975–194–4998
Type VIII—Covers	
Size R—For 3¼″ octagon box	
Style No.	
42—Flat, closed	5975–153–6773
Size S—For 4″ octagon junction box	
Style No.	
43—Flat, closed	5975–153–6775
44—Flat, with ½″ K.O. in center	5975–296–1113
45—Raised, with ½″ K.O. in center, ⅝″ high	5975–153–6774
46—Raised with 27/64″ metal eyelet for drop cord	5975–188–1153
47—Raised, with 2¾″ opening, ⅝″ high	5975–281–0055
Size T—For 4 11/16″ square junction box	
Style No.	
50—Flat, closed	5975–280–7445
51—For 1″ flush device	5975–682–0343
Size U—For 4″ square junction box, surface mounted	
Style No.	
52—For toggle switch—⅛″ depth	5975–280–7187
53—For duplex receptacle—⅛″ depth	5975–284–6285
54—For toggle switch—½″ depth	5975–284–6652
55—For single receptacle—½″ depth	5975–284–6283
56—For duplex receptacle—½″ depth	5975–284–6284
57—For two toggle switches—½″ depth	5975–284–6287
58—For two duplex receptacles—½″ depth	5975–281–0051
59—For toggle switch and single receptacle—½″ depth	5975–281–0052
60—For toggle switch and duplex receptacle—½″ depth	5975–281–0053
Size V—For 4″ square junction box, flush mounted	
Style No.	
61—Flat, closed	5975–281–0056

Type VIII—Covers *(Cont'd)*	Fed. Stock No.
62—Flat, with ½″ knock-out	5975–281–0057
63—Raised, with 2¾″ opening	5975–188–1168
64—For one flush device—¼″ depth	5975–682–0344
65—For one flush device—½″ depth	5975–504–7670
66—For two flush devices—½″ depth	5975–188–1158
67—For one flush device—¾″ depth	5975–153–6770
68—For two flush devices—¾″ depth	5975–176–9028
Size W—For handy junction box	
Style No.	
69—Blank cover	5975–280–7921
70—For single receptacle	5975–280–3836
71—For duplex receptacle	5975–188–1164
72—For toggle switch	5975–501–4924
73—Multiple wiring device	5975–284–8837

S4. Changes. When a Federal agency considers that this standard does not provide for its essential needs, written request for changing or adding to the standard supported by adequate justification, shall be submitted to the Administration. This justification will explain wherein the standard does not provide for essential needs. The request should be sent in duplicate to the General Services Administration, Federal Supply Service, Standardization Division, Washington 25, D. C. The Administration will determine the appropriate action to be taken and will notify the agency.

S5. Conflict with referenced specification. Where the requirements specified in this standard conflict with any requirements in a referenced specification, the requirements of the standard shall apply. Nature of conflict between the standard and the referenced specification, shall be submitted in duplicate, to the General Services Administration, Federal Supply Service, Standardization Division, Washington 25, D. C.

MILITARY INTEREST:
Navy—Y

(Single copies of this standard are available without charge at the GSA Regional Offices in Boston, New York, Atlanta, Chicago, Kansas City, Mo., Dallas, Denver, San Francisco, Los Angeles, Seattle and Washington, D. C. Additional copies may be purchased [illegible] cents each from the General Services Administration, Business Service Center, Washington 25, D. C.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T12:54Z
Check the source to verify that this is the current version before use.