METRIC

A-A-55821
16 July 1996
SUPERSEDING
O-C-110C NOTICE 1
14 May 1992

COMMERCIAL ITEM DESCRIPTION

CALCIUM HYDROXIDE, TECHNICAL

The General Services Administration has authorized the use of this commercial item description as a replacement for O-C-110C NOTICE 1 for all federal agencies.

1. SCOPE. This commercial item description covers technical grade calcium hydroxide, Chemical Abstract Service Registry Number (CAS #)1305-62-0.

2. SALIENT CHARACTERISTICS. Calcium hydroxide (hydrated lime) shall meet the requirements of the American National Standards Institute/American Water Works Association (ANSI/AWWA) B202-93, "Quicklime and Hydrated Lime," with the following modifications:

2.1 Physical requirements. No less than 99.5 percent (by weight) of the calcium hydroxide shall pass through a 600 µm (No. 30) sieve and no less than 98.0 percent (by weight) shall pass through a 75 µm (No. 200) sieve when tested in accordance with American Society for Testing and Materials (ASTM) C 110.

Beneficial comments, recommendations, additions, deletions, clarifications, etc. and any other data which may improve this document should be sent by letter to: Defense Supply Center Richmond, ATTN: DSCR-VBD, 8000 Jefferson Davis Highway, Richmond, VA 23297-5610.

AMSC N/A FSC 6810

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:57Z
Check the source to verify that this is the current version before use.

2.2 Chemical requirements. Hydrated lime shall not have less than 68 percent available calcium oxide, which is equivalent to 90 percent calcium hydroxide, when tested in accordance with ASTM C 25, using the method for Available Lime Index, Procedure for Hydrate.

3. REGULATORY REQUIREMENTS. The products shall be labeled, packed and marked in accordance with Title 49 Code of Federal Regulations (CFR), Parts 100 to 199.

4. QUALITY ASSURANCE PROVISIONS

4.1 Product conformance. The products provided shall meet the salient characteristics of this commercial item description; conform to the producer's own drawings, specifications, standards, and quality assurance practices; and be the same product offered for sale in the commercial market. The government reserves the right to require proof of such conformance.

4.2 Market acceptability. The item offered must have been sold to the government or commercial market.

5. PACKAGING. Preservation, packing, labeling, and marking shall be as specified in ASTM C 50 or the contract or order.

6. NOTES

6.1 Source of documents.

6.1.1 The Code of Federal Regulations may be obtained from the Superintendent of Documents, U.S. Government Printing Office, Washington, DC 20402-0001.

6.1.2 Chemical Abstract Service files and data base may be obtained from the Chemical Abstract Service, Customer Services, P.O. Box 3012, Columbus, OH 43210.

6.1.3 American National Standards Institute (ANSI) standards may be obtained from the American National Standards Institute, 11 West 42nd St., New York, NY 10036.

6.1.4 American Water Works Association (AWWA) standards may be obtain from the American Water Works Association, 6666 West Quincy Avenue, Denver, Colorado 80235.

6.1.5 American Society for Testing and Materials (ASTM) standards may be obtained from the American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959.

6.2 Ordering data. Acquisition documents must specify the following:

a. Title, name, and date of this commercial item description.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:57Z
Check the source to verify that this is the current version before use.

b. Unit quantity required.
c. Packaging requirements.

6.3 National stock numbers (NSNs). NSNs 6810-00-656-1091 and 6810-01-039-2020 are the NSNs which correspond to this commercial item description. However, these may not be all possible NSNs associated with this document.

6.4 Sources of supply. The following products are known to meet the requirements of this commercial item description. Competition is not limited to the suppliers on this list.

United States Gypsum Company
125 South Franklin Street
P.O. Box 803871
Chicago, IL 60680-3871
(800) 621-9523

Dravo Lime Company
P.O. Box 37
Saginaw, Al 35137
(800) 633-4889

Continental Lime Incorporated
670 East 3900 South, Suite 205
Salt Lake City, UT 84108
(801) 262-3942

MILITARY INTERESTS:

Custodians
Army - EA
Navy - SH
Air Force - 68

Reviewers
Army - MI
Navy - YD-1, SA
Marine Corps - MC

CIVIL AGENCY COORDINATING ACTIVITIES:

GSA - FSS
EPA

PREPARING ACTIVITY:
DLA - GS

(Project No: 6810-1390)

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:57Z
Check the source to verify that this is the current version before use.