A-A-50488
June 23, 1987

COMMERCIAL ITEM DESCRIPTION

DISPLAY CASE, MECHANICALLY REFRIGERATED, REACH-IN MERCHANDISERS, GLASS DOOR, LOW AND MEDIUM TEMPERATURE

The General Services Administration has authorized the use of this commercial item description.

Salient characteristics.

Classification. The display cases covered by this commercial item description shall be of the following types and styles as specified in the contract or order:

TYPES
Type I: Low temperature (for frozen food)
Type II: Low temperature (for ice cream)
Type III: Medium temperature

STYLES
Style A: 3-door sections
Style B: 5-door sections

Construction. The cabinet of the display cases shall be constructed of steel. Each Style A and Style B cabinet shall be provided with one pair of insulated and removable end panels. When specified in the contract or order, joiner kits shall be provided for cabinet lineup. Clear polycarbonate plastic partitions shall be provided with each cabinet. All insulation shall be non-moisture absorbent and shall have a thermal resistance of not less than R-19. All trim shall be of stainless steel or polished aluminum. Cabinets shall be provided with kickplates and cart bumpers. Dissimilar metals shall not be placed in intimate contact with each other in order to prevent galvanic corrosion. Each cabinet shall be provided with not less than one waste drain measuring minimum 1 1/2 inches in diameter. Electrically heated, multiple pane, hermatically sealed, tempered glass doors shall be provided with the display cases and shall have magnetic gaskets and automatic door closures. Doors shall be not less than 56 inches and not greater than 61 inches in height. Door frames shall be constructed of polished aluminum or stainless steel; shall be insulated; and shall be provided with anti-sweat heaters. Doors shall be hinged for left or right opening as specified in the contract or order. Each door section shall be provided with a bottom wire rack with product retainer lip and

FSC 4110

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:43Z
Check the source to verify that this is the current version before use.

a minimum of four upper adjustable wire shelves with brackets. The shelves shall be not less than 22 inches in depth and adjustment shall be on 1 inch increments. Ticket moldings to fit standard size price and UPC tags shall be provided with each wire rack and shelf. Each door section shall be provided with not less than one Underwriters Laboratories approved cool white rapid start fluorescent lamp with a protective shield for cold temperature. Each lamp shall be capable of illuminating the entire door section.

Dimensions. The outside dimensions of Style A display cases shall be 96 ±6 inches in length, 40 ±1 inches in depth, and 80 ±1 inches in height. The outside dimensions of Style B display cases shall be 144 ±6 inches in length, 40 ±1 inches in depth, and 80 ±1 inches in height. Dimensions of merchandiser shall be compatible with dimensions of conventional type display cases.

Interior. Each display case shall be provided with an evaporator coil. The evaporator coil shall be copper tubing with aluminum fins and shall be sized to maintain product temperature of -10 degrees Fahrenheit (^{o}F) for Type I display cases, -15°F for Type II display cases, and between +35°F to +38°F for Type III display cases. Evaporator fans and defrost cycle shall be time initiated and temperature terminated. Thermostatic temperature control, complete with solenoid valve, shall be provided with each case. Safety controls shall be provided and shall de-energize evaporator fans during defrost cycle and when interior of cabinet reaches abnormally high temperatures.

Remote refrigeration system. The remote refrigeration shall be through air cooled condensers and semi-hermetic compressor system with sufficient capacity to support the connected load. Design capacity of the remote refrigeration system shall be based on 100°F ambient temperature. Integrally mounted controls shall be provided for operation at low ambients down to 0°F. Type I and Type II display cases shall be designed to use Type R-502 freon conforming to Federal Specification BB-F-1421 and Type III display cases shall be designed to use Type R-22 freon conforming to BB-F-1421. When specified in the contract or order, an outdoor weather hood for compressors shall be provided.

Electrical characteristics. Unless otherwise specified in the contract or order, compressors and condensing units shall designed to operate on 208 volts (V), 60 Hertz (Hz), single phase power supply and evaporator fan motors, lights and controls shall be designed to operate on 115V, 60 Hz, single-phase power supply. Wiring shall be in accordance with the National Electrical Manufacturers Association (NEMA) WD-5 or NEMA WD-7.

Color. Type I and Type II display cases shall be painted with baked on blue color acrylic paint conforming to color number 15200 of FED-STD-595. Type III display cases shall be painted with baked on gold color acrylic paint conforming to color number 13655 of FED-STD-595.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:43Z
Check the source to verify that this is the current version before use.

Regulatory requirements. The offeror/contractor is encouraged to use recovered materials in accordance with Public Law 94-580 to the maximum extent practicable.

Preservation, packaging, packing, labeling, and marking. Preservation packaging, packing, labeling, and marking shall be as specified in the contract or order.

Notes. Purchaser should specify the following:

a. Type and style required.
b. Hinged side of doors.
c. When joiner kits and ends caps are required for cabinet lineup.
d. When outdoor weather hoods are required for compressors.
e. Electrical characteristics, if other than as specified.
f. Preservation, packaging, packing, labeling, and marking required.

Source of information for Government documents.

FEDERAL SPECIFICATION

BB-F-1421 - Fluorocarbon Refrigerants

FEDERAL STANDARD

FED-STD-595 - Colors

Superintendent of Documents, U.S. Government Printing Office, Washington, DC 20402.

Source of information for non-Government documents.

National Electrical Manufacturers Association, 2101 L Street, N.W., Washington, DC 20037.

Underwriters Laboratories, Inc., 333 Pfingsten Road, Northbrook, IL 60062.

Suggested sources of supply.

Source	Model No.	CID equivelent
Hill Refrigeration Corp. Division of Emhart 5804 E. Slauson Ave. Los Angeles, CA 90040	ZAR-3GF	Type I, Style A
	ZAR-5GC	Type I, Style B
	ZAR-3GC	Type II, Style A
	ZAR-5GF	Type II, Style B
	BZAR-3G	Type III, Style A
	BZAR-5G	Type III, Style B

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:43Z
Check the source to verify that this is the current version before use.

Source	Model No.	CID equivelent
Tyler Refrigeration Corp. 1329-T Lake St. Niles, MI 49120	D5FGL-8FF	Type I, Style A
	D5FGL-12FF	Type I, Style B
	D5FGL-8IC	Type II, Style A
	D5FGL-12IC	Type II, Style B
	D5NGH-8	Type III, Style A
	D5NGH-12	Type III, Style B

MILITARY INTERESTS:

Military Coordinating Activity

Navy - YD

Custodians

Army - GL
Navy - YD

Review Activities

Army - MD, TS
DLA - GS

CIVIL AGENCY COORDINATING ACTIVITY:

GSA-FSS

PREPARING ACTIVITY:

Navy - YD

Project 4110-0400

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:43Z
Check the source to verify that this is the current version before use.