INTERIM AMENDMENT-1

FEDERAL SPECIFICATION

FIRE ALARM SYSTEM; LOCAL, ELECTRIC, SUPERVISED

SUCCESSION CODED, POSITIVE

NON-INTERFERING TYPE

This Interim Amendment was developed by General Services Administration Federal Supply Service, Washington, D. C., 20407, based upon currently available technical information. It is recommended that Federal agencies use it in procurement and forward recommendations for changes to the preparing activity at the address shown above.

The General Services Administration has authorized Federal agencies to use this Interim Amendment as a valid addition to Federal Specification W-F-391c, dated November 27, 1963.

Page 2, paragraph 2.2, between line 7 and line 8: Insert the following:

UL-38 - Manually Actuated Signalling Boxes for use with Fire-Protective Signalling Systems.

Page 2, paragraph 2.2, between line 9 and line 10: Insert the following:

UL-632 - Electrically Actuated Transmitters.

Page 3, paragraph 3.2.1, line 5: After "of" delete entire balance of line and substitute the following:

UL-38, UL-464, UL-521, UL-632, and UL-864.

Page 5, paragraph 3.4.1: At end of sentence delete period and add "and UL-38."

Page 6, paragraph 3.6.1: At end of sentence delete period and add "UL-632."

Page 10, paragraph 3.14.1.1: Delete in its entirety and substitute the following:

3.14.1.1 Stations and transmitters. The following requirements shall conform to NEMA Standard SB1-1962, Part 4, Section 1.

(a) Vibration
(b) Jarring
(c) Insulation resistance

3.14.1.1.1 Stations. In addition to the requirements of 3.14.1.1, the following requirements shall conform to UL-38:

(a) Normal operation
(b) Over-and under-current operation
(c) Overload and endurance
(d) Dielectric strength
(e) Spray (Style D stations only)
(f) Humidity (Style D stations only)

FSC 6350

Source: https://assist.dla.mil -- Downloaded: 202640-26T11:26Z
Check the source to verify that this is the current version before use.

3.14.1.1.2 Transmitters. In addition to the requirements of 3.14.1.1, the following requirements shall conform to UL-632:

(a) Normal operation
(b) Circuit-emergency operation
(c) Input and output current and voltage
(d) Over-and under-voltage operation
(e) Overload
(f) Endurance
(g) Dielectric strength

Page 11, paragraph 3.14.1.2: Delete "Unless otherwise specified (see 6.1)"

Page 11, paragraphs 3.14.2 and 3.14.3: Delete "Unless otherwise specified"

Page 13, paragraph 6.1: Delete (v) in its entirety.

Page 13, Notice: Delete in its entirety.

GSA DC 65-9913

Source: https://assist.dla.mil -- Downloaded: 202640-26T11:26Z
Check the source to verify that this is the current version before use.