W-F-414E
INT. AMENDMENT-1
September 12, 1973

INTERIM AMENDMENT

TO

FEDERAL SPECIFICATION

FIXTURE, LIGHTING (FLUORESCENT, ALTERNATING CURRENT, PENDANT MOUNTING)

This interim amendment was developed by the General Services Administration, Federal Supply Service, Washington, DC 20406, based upon currently available technical information. It is recommended that Federal agencies use it in procurement and forward recommendations for changes to the preparing activity at the address shown above.

The General Services Administration has authorized the use of this interim amendment as a valid exception to Federal Specification W-F-414E, dated February 9, 1973.

PAGE 1

Upper right hand corner, change superseding information as follows:

Delete the wording "Int. Fed. Spec. W-F-00414D (GSA-FSS) March 25, 1971 and W-F-414a May 8, 1957" and substitute "Int. Fed. Spec. W-F-00414D (GSA-FSS) March 25, 1971 and Fed. Spec. W-F-414a May 8, 1957."

Paragraph 1.1, last sentence, delete the words "and starters".

PAGE 2

Under "Federal Specifications:", change title for Federal Specification PPP-B-636 from "Box, Fiberboard" to "Boxes, Shipping, Fiberboard."

PAGE 3

Paragraph 2.2, under "American National Standards Institute (ANSI), Inc. Standard:" change title of reference to "C78.700-40-WATT T-12 Rapid-Start Fluorescent Lamp."

Paragraph 2.2, revise "Illuminating Engineering Society (IES) Handbook:" to read "Illuminating Engineering Society (IES) Publications:"

PAGE 4

Paragraph 3.2.2.1, last sentence, delete the word "tens" and replace with "stems".

Paragraph 3.2.2.2, delete paragraph in its entirety and substitute the following:

"3.2.2.2 End plates. Each mounting 2 fixture shall be designed such that end plates can be attached and detached at either end of fixture. Fixture shall be provided with the following number of end plates as required for the mounting specified:

2 for each individual fixture (Mounting 1)

1 for each continuous row fixture (Mounting 2)"

Paragraph 3.3, last sentence, delete the word "fixtures" and substitute the word "fixture."

PAGE 5

Paragraph 3.6, first sentence, delete sentence in its entirety and substitute the following:

"Ballast(s) shall conform to Federal Specification W-B-30 and shall be designed to operate on one of the following voltage ranges and alternating current frequencies: 110-125 volts, 60 Hertz; 250-290 volts, 60 Hertz; or 210-236 volts, 50 Hertz. The particular voltage range and frequency, one of those cited above, shall be specified (see 3.18 and 6.1)."

FSC 6210

Source: https://assist.dla.mil -- Downloaded: 202610-26T11:27Z
Check the source to verify that this is the current version before use.

PAGE 6

Paragraph 3.10.1.1, delete paragraph in its entirety and substitute the following:

3.10.1.1 Reflectance. When determined in accordance with 4.5.3, the average reflectance of test samples after exposure shall not decrease by more than 4 percent of the initial average reflectance before exposure. Also, the average reflectance of test samples after exposure shall be at least 96 percent of average reflectance value given for fixture in independent laboratory photometric test data (see 4.6.5). When tested in accordance with 4.5.4, fixture average reflectance shall be at least 96 percent of the average reflectance value given in photometric test data (again, see 4.6.5).

PAGE 7

Paragraph 3.18, delete in its entirety and substitute the following:

"3.18, Electrical requirements. Type I fixtures shall be designed to operate on one of the following 60 Hertz alternating current voltage ranges as specified (see 3.6 and 6.1): 110-125 volts; or 250-290 volts. Type II fixtures shall be designed to operate on one of the following voltages ranges and alternating current frequencies, as specified (see 3.6 and 6.1): 110-125 volts, 60 Hertz; 250-290 volts, 60 Hertz; or 210-236 volts, 50 Hertz."

PAGE 8

Paragraph 4.4.1, change title of paragraph from "Table IV. Classification of defects" to "Table III. Classification of defects."

PAGE 9

Paragraph 4.5.3, delete in its entirety and substitute the following:

4.5.3 Exposure test. Subject at least five sample plates, each flat, 4 inches wide by 6 inches long and representative of the reflector finish and material, to testing in the following manner. Determine initial average reflectance of sample plates by measuring the reflectance of each sample with a reflectometer, or instrument providing equivalent results, and averaging the cumulative reflectance measurements. Then expose sample plates for one hundred hours to the radiation of a glass enclosed carbon arc lamp, such as a Fade-O-Meter, operating on a current of 13 ± .5 amperes and electrical potential, at the arc, of 140 volts. Each sample shall be placed ten inches from the arc and the lamp so ventilated that the temperature at the sample does not exceed 105°F. After exposure in the above manner, again determine the average reflectance as outlined above. Determine hiding of black and white substrate in accordance with Method 4121 of Fed. Test Method Std. No. 141, and examine for indication of chipping, cracking, flaking or any other signs of loss of adhesion (see 3.10.1). Compare the initial average reflectance to average reflectance after exposure and ascertain compliance with the decrease of no more than 4 percent requirement of 3.10.1.1. Also, compare average reflectance value of test samples after exposure with average fixture reflectance value given in photometric test data (see 3.10.1.1 and 4.6.5). The exposure test need only be conducted for preproduction testing when a preproduction sample(s) is required (see 3.17), or only for the first lot of fixtures of each style, mounting and lamp arrangement specified in the invitation for bids, when a preproduction sample(s) is not required. Inability to meet applicable reflectance requirements of 3.10.1.1, signs of loss of adhesion on any sample, or failure of more than 40 percent of samples to comply with hiding of black and shite substrate requirement shall be cause for lot rejection.

Paragraph 4.5.6, first sentence, close parenthesis after "see 6.1" so that wording becomes "(see 6.1)."

Paragraph 4.6, first sentence, insert the word "complete" between the words "one" and "fixture" so that wording becomes "one complete fixture."

PAGE 10

Paragraph 4.6.4, first sentence, second and third lines, place quotation mark before the referenced RQQ Report No. 2 so that wording becomes "RQQ Report No. 2 (1972) - Outline of a Standard Procedure For Computing Visual Comfort Ratings For Interior Lighting".

Paragraph 4.6.5, second sentence, delete the reference to paragraph "3.6" and replace with "3.16".

Source: https://assist.dla.mil -- Downloaded: 202610-26T11:27Z
Check the source to verify that this is the current version before use.

PAGE 12

Paragraph 5.3, 4th sentence (sixth and seventh lines) delete in entirety and substitute the following: "The load shall be secured to the pallet with a minimum of two straps perpendicular to the length of the pallet and two perpendicular to the pallet width."

PAGE 13

Paragraph 6.1 (o), delete in entirety and substitute:

"(o) Whether civil or military marking is required (see 5.4)."

GSA DC 74-3017

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:27Z
Check the source to verify that this is the current version before use.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:27Z
Check the source to verify that this is the current version before use.