W-P-455
CANCELLATION
September 21, 1984

FEDERAL SPECIFICATION

PLATE, WALL, ELECTRICAL

This cancellation is approved by the Assistant Administrator, Office of Federal Supply and Services, General Services Administration.

Federal Specification W-P-455A, dated September 9, 1968, has been superseded by Underwriters Laboratories Inc. Standards UL 514A - Metallic Outlet Boxes and UL 514C - Nonmetallic Outlet Boxes, Flush Device Boxes, and Covers as follows:

UL 514A - Types I, II, III, IV, V, and VI.
Materials - Brass, Aluminum, Stainless Steel, Painted Steel, Zinc- or cadmium- plated steel.

UL 514C - Types I, II, III, IV, V, and VI.
Material - Plastic.

UL Standards 514A and 514C have been adopted by GSA-FSS and DoD.

FSC 5975

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:27Z
Check the source to verify that this is the current version before use.