INCH-POUND

MIL-C-43343E
26 February 1992
SUPERSEDING
MIL-C-0043343D(GL)
24 July 1991
AND
MIL-C-43343C
13 September 1989

MILITARY SPECIFICATION

CONTROL, FUEL FLOW, OIL BURNER

This specification is approved for use by all Departments and Agencies of the Department of Defense.

1. SCOPE

1.1 Scope. This specification covers two types of constant level fuel flow controls with multifuel capabilities for use with gravity feed oil burning equipment (see 6.1).

1.2 Classification. Fuel flow controls shall be of the following types as specified (see 6.2).

Type I - For use with the H-45 heater.
Type II - For use with the M-41 heater.

2. APPLICABLE DOCUMENTS

2.1 Government documents.

Beneficial comments (recommendations, additions, deletions) and any pertinent data which may be used in improving this document should be addressed to: U.S. Army Natick Research, Development, and Engineering Center, Natick, MA 01760-5017, by using the Standardization Document Improvement Proposal (DD Form 1426) appearing at the end of this document or by letter.

AMSC N/A FSC 4530

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-21T21:12Z
Check the source to verify that this is the current version before use.

2.1.1 Specifications, standards, and handbooks. The following specifications, standards, and handbooks form a part of this document to the extent specified herein. Unless otherwise specified, the issues of these documents are those listed in the issue of the Department of Defense Index of Specifications and Standards (DODISS) and supplement thereto, cited in the solicitation (see 6.2).

SPECIFICATIONS

FEDERAL

VV-F-800	-	Fuel Oil, Diesel
PPP-B-601	-	Boxes, Wood, Cleated-Plywood
PPP-B-636	-	Boxes, Shipping, Fiberboard

MILITARY

MIL-P-116	-	Preservation, Methods Of
MIL-C-5501	-	Caps and Plugs, Protective, Dust and Moisture Seal
MIL-T-5624	-	Turbine Fuel Aviation, Grades JP-4, JP-5 and JP-5/JP-8ST
MIL-A-8625	-	Anodic Coatings, for Aluminum and Aluminum Alloys
MIL-T-83133	-	Turbine Fuels, Aviation, Kerosene Types, NATO F-34 (JP-8) and NATO F-35

STANDARDS

FEDERAL

FED-STD-595	-	Colors Used in Government Procurement

MILITARY

MIL-STD-105	-	Sampling Procedures and Tables for Inspection by Attributes
MIL-STD-129	-	Marking for Shipment and Storage
MIL-STD-147	-	Palletized Unit Loads
MIL-STD-731	-	Quality of Wood Members for Containers and Pallets
MIL-STD-970	-	Standards and Specifications, Order of Preference for the Selection of

(Unless otherwise indicated, copies of federal and military specifications, standards, and handbooks are available from the Standardization Documents Order Desk, Building 4D, 700 Robbins Avenue, Philadelphia, PA 19111-5094.)

2.1.2 Other Government documents, drawings, and publications. The following other Government documents, drawings, and publications form a part of this document to the extent specified herein. Unless otherwise specified, the issues are those cited in the solicitation.

Source: https://assist.dla.mil - Downloaded: 2026-10-21T21:12Z
Check the source to verify that this is the current version before use.

DRAWINGS

U.S. ARMY NATICK RESEARCH, DEVELOPMENT, AND ENGINEERING CENTER

5-13-4454 - Control, Multi Fuel Flow, Oil Burner, Assembly, H-45
5-13-5130 - Control, Multi Fuel Flow, Oil Burner, Assembly, M-41

(Copies of drawings are available from the U.S. Army Natick Research, Development, and Engineering Center, ATTN: STRNC-UX, Natick, MA 01760-5017.)

2.2 Non-Government publications. The following documents form a part of this document to the extent specified herein. Unless otherwise specified, the issues of the documents which are DoD adopted are those listed in the issue of the DODISS cited in the solicitation. Unless otherwise specified, the issues of documents not listed in the DODISS are the issues of the documents cited in the solicitation (see 6.2).

AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)

B 633 - Electrodeposited Coatings of Zinc on Iron and Steel

D 439 - Automotive Gasoline

D 3951 - Standard Practice for Commercial Packaging

(Application for copies should be addressed to the American Society for Testing and Materials, 1916 Race Street, Philadelphia, PA 19103-1187.)

(Non-Government standards and other publications are normally available from the organizations that prepare or distribute the documents. These documents also may be available in or through libraries or other informational services.)

2.3 Order of precedence. In the event of a conflict between the text of this document and the references cited herein, the text of this document takes precedence. Nothing in this document, however, supersedes applicable laws and regulations unless a specific exemption has been obtained.

3. REQUIREMENTS

3.1 First article. When specified (see 6.2), a sample shall be subjected to first article inspection (see 6.3) in accordance with 4.3.

3.2 Materials and components. The materials and components shall be as specified herein and on the applicable drawing. Materials and components not specified shall be selected by the contractor in accordance with MIL-STD-970.

Source: https://assist.dla.mil -- Downloaded: 2026-10-21T21:12Z
Check the source to verify that this is the current version before use.

Materials and components specified in accordance with MIL-STD-970 shall not degrade the operation suitability of effectiveness of the burner. It is encouraged that recycled material be used when practical as long as it meets the requirements of this specification.

3.3 Design.

3.3.1 Fuel controls. The type I fuel control shall conform to Drawing 5-13-4454, and as specified herein. The type II fuel control shall conform to Drawing 5-13-5130, and as specified herein. The control shall maintain a constant fuel flow rate to a burner by means of a float actuated valve. The control shall include manually operated knobs for regulating fuel selection, fuel flow rate, and a shut off assembly. The metering knob shall have seven settings that provide an increase in fuel flow for each successive setting from "LO" to "HI" setting. The metering knob shall turn without binding and shall have a hole with screw to allow calibration of the fuel flow control without disassembly. The fuel type selector knob shall have three settings for the types of fuel as shown in table I for type I, and table II for type II, and as shown on the drawings. The fuel control shall compensate for the differences in viscosity of gasoline conforming to ASTM D 439, diesel conforming to VV-F-800, and jet fuels conforming to MIL-T-5624 and MIL-T-83133, by being calibrated to meet the specified flow rates of tables I and II.

3.3.2 Housing assembly. The housing assembly shall consist of a body, float assembly, strainer assembly, and shut off valves.

3.3.3 Body. The aluminum die cast body shall have a drain screw accessible through the protective shield, an overflow outlet, an inlet opening, two outlet openings, one of which is plugged per drawing, and an opening for the strainer assembly.

3.3.4 Strainer assembly. The strainer assembly shall have a 50 by 60 mesh monel or stainless steel wire cloth screen for filtering the fuel and be capable of being screwed to the body with common use tools and shall not require a sealer to render a leak free fit (see 4.5.5).

3.3.5 Cover assembly. The cover assembly shall consist of a gasket, top plate, and an aluminum cover plate showing fuel type locations, a fuel selection control and rotating plate showing 7 positions for setting the metering knob, a flow adjustment knob, and fuel flow shut off assembly.

3.3.6 Protective shield. The protective steel shield shall be as indicated on Drawings 5-13-4454 and 5-13-5130.

3.4 Physical requirements.

Source: https://assist.dla.mil -- Downloaded: 2026-10-21T21:12Z
Check the source to verify that this is the current version before use.

3.4.1 Type I control. The fuel flow rate shall be determined in accordance with 4.5.2 with the metering knob in each of the following eight positions: O, LO, 2, 3, 4, 5, 6, and HI using test fuel JP-8 conforming to MIL-T-83133. The fuel flow rate at the "O" and "HI" settings shall be as specified in table I. The flow rates shall increase with each successive setting from "O" to "HI".

TABLE I. Fuel flow rates for the type I control (H-45)

Position of fuel type selection knob	Setting of metering knob 1/	Flow rate (cc/min)
JP4-8/GAS	O	21 ± 2
	HI	52 ± 3
JP4-8 (BELOW-25°F)	O	29 ± 2
	HI	62 ± 3
DIESEL	O	29 ± 2
	HI	62 ± 3

1/ The "O" position of the metering knob ("O" position not identified on the control) is the lowest possible setting. This setting shall be located by turning the metering knob counter clockwise until it hits the stop. The "HI" setting of the knob allows the highest possible flow rate. The "HI" setting shall be reached by turning the knob clockwise until the cam surface (ramp rise) peaks and levels out at the "HI" setting.

3.4.2 Type II control. The fuel flow rate shall be determined in accordance with 4.5.2 with the metering knob in each of the following eight positions: O, LO, 2, 3, 4, 5, 6, and HI using test fuel JP-8 conforming to MIL-T-83133. The fuel flow rate at the "O" and "HI" settings shall be as specified in table II. The flow rates shall increase with each successive setting from "O" to "HI".

TABLE II. Fuel flow rates for the type II control (M-41)

Position of fuel type selection knob	Setting of metering knob 1/	Flow rate (cc/min) (+3cc/min)
Gas	"O" and "HI"	9-22
Jet	"O" and "HI"	10-23
Diesel	"O" and "HI"	16-58

Source: https://assist.dla.mil -- Downloaded: 202640-21T21:12Z
Check the source to verify that this is the current version before use.

1/ The "O" position of the metering knob ("O" position not identified on the control) is the lowest possible setting. This setting shall be located by turning the metering knob counterclockwise until it hits the stop. The "HI" setting of the knob allows the highest possible flow rate. The "HI" setting shall be reached by turning the knob clockwise until the cam surface (ramp rise) peaks and levels out at the "HI" setting.

3.4.3 Leakage. There shall be no evidence of leakage when the fully assembled control is tested as specified in 4.5.5.

3.4.4 Fuel flow shut off. When the fully assembled control is tested as specified in 4.5.3 the flow of fuel shall stop when the fuel shut off switch is in the "OFF" position.

3.4.5 Housing assembly (see 3.3.2).

3.4.5.1 Operating fuel level. When tested as specified in 4.4.2.1 the fuel level in the body shall be 1.050 to 1.150 inches when measured from the top surface of fuel to the center of the side outlet opening of the body.

3.4.5.2 Fuel level shut off. When tested as specified in 4.4.2.1 the flow of fuel into the body shall stop when the fuel in the body is less than 1.250 inches when measured from the top surface of fuel to the center of the side outlet opening of the body.

3.5 Marking.

3.5.1 Plates, knobs, controls. The nameplate on the front of the protective shield, the cover plate, fuel adjustment knob, fuel selection control and rotating plate shall be marked as specified on Drawings 5-13-4454 or 5-13-5130, as applicable, for the type of control specified. The markings shall be satin finish aluminum or white against a black background. The coating shall not peel or become capable of being rubbed off the marked surfaces when tested as specified in 4.4.2.1.

3.5.2 Body. The body specified in 3.3.3 shall be marked as specified on Drawings 5-13-4454 or 5-13-5130, as applicable for the type of control specified.

3.6 Finish. The finish of the body, flow adjusting knob, fuel selection control and rotating plate shall conform to either type I or II of MIL-A-8625. The color of the body and protective shield shall conform to X34087 of FED-STD-595. The color of the flow adjusting knob, fuel selection control, and rotating plate shall conform to 37030 of FED-STD-595. The cover plate, if constructed of steel material, shall be finished by a zinc coating in accordance with type II, class SC-2 thickness of ASTM B 633 (see 6.5). The cover plate and name plate shall be smooth and free from scratches, imbedded matter, and uncoated areas.

Source: https://assist.dla.mil -- Downloaded: 2026-10-21T21:12Z
Check the source to verify that this is the current version before use.

3.7 Workmanship. The end item shall conform to the quality of product established by this specification and the occurrence of defects shall not exceed the applicable acceptable quality levels.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the contractor is responsible for the performance of all inspection requirements (examinations and tests) as specified herein. Except as otherwise specified in the contract or purchase order, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in this specification where such inspections are deemed necessary to ensure supplies and services conform to prescribed requirements.

4.1.1 Responsibility for compliance. All items shall meet all requirements of sections 3 and 5. The inspection set forth in this specification shall become a part of the contractor's overall inspection system or quality program. The absence of any inspection requirements in the specification shall not relieve the contractor of the responsibility of ensuring that all products or supplies submitted to the Government for acceptance comply with all requirements of the contract. Sampling inspection, as part of manufacturing operations, is an acceptable practice to ascertain conformance to requirements, however, this does not authorize submission of known defective material, either indicated or actual, nor does it commit the Government to accept defective material.

4.1.2 Responsibility for dimensional requirements. Unless otherwise specified in the contract or purchase order, the contractor is responsible for ensuring that all specified dimensions have been met. When dimensions cannot be examined on the end item, inspection shall be made at any point, or at all points in the manufacturing process necessary to assure compliance with all dimensional requirements.

4.2 Classification of inspections. The inspection requirements specified herein are classified as follows:

a. First article inspection (see 4.3).
b. Quality conformance inspection (see 4.4).

4.3 First article inspection. When a first article is required (see 3.1 and 6.2), it shall be examined for the defects specified in 4.4.3 and 4.4.4 and shall be tested for the characteristics specified in 4.5.2, 4.5.3, 4.5.4, 4.5.5, and 4.5.6. Any nonconformance shall be cause for rejection of the first article.

4.4 Quality conformance inspection. Unless otherwise specified, sampling for inspection shall be performed in accordance with MIL-STD-105.

Source: https://assist.dla.mil -- Downloaded: 2026-10-21T21:12Z
Check the source to verify that this is the current version before use.

4.4.1 Component and material inspection. In accordance with 4.1, components and materials shall be inspected in accordance with all the requirements of referenced documents unless otherwise excluded, amended, modified, or qualified in this specification or applicable purchase document.

4.4.2 In-process inspection. Inspection of subassemblies shall be made to ascertain that construction details which cannot be examined in the finished product are in accordance with specified requirements. The Government reserves the right to exclude from consideration for acceptance any material or service for which in-process inspection has indicated nonconformance.

4.4.2.1 In-process testing. Prior to complete assembly of the fuel flow control, each housing assembly (see 3.3.2) shall be tested for the characteristics shown in table III. Failure to pass operating fuel level or fuel level shut off tests shall be cause for rejection of the failing item. The lot size for nameplates and cover plates shall be expressed in units of nameplates or cover plates, as applicable. The sample unit shall be one nameplate or cover plate, as applicable. The inspection level for this test shall be S-2 and the acceptable quality level (AQL), expressed in terms of defects per hundred units, shall be 4.0. Failure of the sample shall be cause for rejection of the lot.

TABLE III. In-process testing schedule

Component	Characteristic	Requirement paragraph	Test paragraph
Housing assembly	Operating fuel level	3.4.5.1	4.5.4.1
	Fuel level shut off	3.4.5.2	4.5.4.2
Plates, knobs and controls	Coating adhesion	3.5.1	4.5.6

4.4.3 End item visual examination. The end items shall be examined for the defects in table IV. The lot size shall be expressed in units of fuel flow controls. The sample unit shall be one fuel flow control. The inspection level shall be S-2 and the AQL, expressed in terms of defects per hundred units, shall be 2.5 for major defects and 6.5 for total (major and minor combined) defects.

Source: https://assist.dla.mil -- Downloaded: 2026-10-21T21:12Z
Check the source to verify that this is the current version before use.

TABLE IV. End item visual defects

Examine	Defect	Classification Major	Minor
Finish	Not anodized where required	101	
	Nameplate and cover plate coat not smooth and free from scratches, imbedded foreign matter, and areas of no paint.		201
Construction and workmanship	Not connected or joined as specified	102	
	Fuel flow control not assembled as specified		202
	Any component missing	103	
	Not clean and free from burrs, slivers, and sharp edges		203
	Not free from dents, blowholes, and fractures	104	
Metering knob	Binds when turned from "O" through "HI" settings	105	
Threaded fittings	Threads broken, stripped, fractured, or missing	106	
	Not securely tightened		204
Protective shield	No hole for access to drain screw	107	
Color	Not as specified		205
Marking	Marking on rotating plate, cover plate, fuel selector knob, metering knob, or on body: missing, incomplete, or illegible	108	

4.4.4 End item dimensional examination. The end items shall be examined for conformance to the dimensions specified on Drawings 5-13-4454 and 5-13-5130. Only those dimensions that can be evaluated without damaging or disassembling the end items shall be examined. Any dimension not within the specified tolerance shall be classified as a defect. The lot size shall be expressed in units of fuel flow controls. The sample unit shall be one fuel flow control. The inspection level shall be S-2 and the AQL, expressed in terms of defects per hundred units, shall be 4.0.

4.4.5 End item testing. All end items shall be subjected to the test specified in 4.5.2 and 4.5.3. The end items shall be tested as specified in 4.5.6 for the first article only. Failure to pass any test shall be cause for rejection of the inspection lot.

Source: https://assist.dla.mil -- Downloaded: 2026-10-21T21:12Z
Check the source to verify that this is the current version before use.

4.4.5.1 End item linear flow progression test. One out of one thousand end items shall be subjected to the test specified in 4.5.2.1. Failure of this test shall be cause for rejection of the lot.

4.4.6 Packaging examination. The fully packaged end items shall be examined for the defects listed below. The lot size shall be expressed in units of shipping containers. The sample unit shall be one shipping container fully packaged. The inspection level shall be S-2 and the AQL, expressed in terms of defects per hundred units, shall be 2.5.

Examine	Defect
Marking (exterior and interior)	Omitted; incorrect; illegible; of improper size, location, sequence, or method of application
Materials	Any component missing, damaged, or not as specified
Workmanship	Inadequate application of components, such as: incomplete sealing or closure of flap, improper taping, loose strapping, or inadequate stapling Bulged or distorted container
Content	Number per container is more or less than required

4.4.7 Palletization examination. The fully packaged and palletized end items shall be examined for the defects listed below. The lot size shall be expressed in units of palletized unit loads. The sample unit shall be one palletized unit load, fully packaged. The inspection level shall be S-1 and the AQL, expressed in terms of defects per hundred units, shall be 6.5.

Examine	Defect
Finished dimensions	Length, width, or height exceeds specified maximum requirement
Palletization	Pallet pattern not as specified Load not bonded as specified
Weight	Exceeds maximum load limits
Marking	Omitted; incorrect; illegible; of improper size, location, sequence, or method of application

Source: https://assist.dla.mil -- Downloaded: 2026-10-21T21:12Z
Check the source to verify that this is the current version before use.

4.5 Methods of inspection.

4.5.1 Methods of testing. The fuel flow control and housing assembly shall be level when conducting tests specified in 4.5.2 through 4.5.5. JP-8 fuel, conforming to MIL-T-83133, at a temperature between 60°F and 75°F shall be used for all tests. Fuel shall be allowed to flow through the control and housing until all air is removed prior to conducting the tests. The inlet test liquid head for the tests in 4.5.2, 4.5.3, and 4.5.4 shall be the vertical distance measured from the discharge opening of the test fuel container to the inlet opening of the housing assembly or to the inlet opening of the control assembly, as applicable.

4.5.2 Flow rate test at 0 and Hi positions. With an inlet test liquid head of between 18 and 24 inches (see 4.5.1), the completely assembled fuel flow control shall be operated with the metering knob set at the 0 and HI settings, respectively. After the test liquid has been flowing for a minimum of 1 minute while the metering knob is set at the 0 setting, the test liquid flow measurements in volume and time shall be taken to determine compliance with the requirements specified in 3.4.1 and 3.4.2. The same procedure shall be followed while the metering knob is set at the HI setting. Failure of the type I control to meet the requirements of table I or failure of the type II control to meet the requirements of table II shall be a test failure.

4.5.2.1 Flow rate test at Lo, 2, 3, 4, 5, and 6 positions. The flow rate shall be determined as indicated in 4.5.2, while the metering knob is at the LO, 2, 3, 4, 5, and 6 positions. One fuel flow control out of one thousand shall be selected for this test. Failure of the flow rate to increase at each setting shall constitute a test failure.

4.5.3 Fuel flow shut off test. The completely assembled fuel flow control shall be operated for 1 minute with an inlet test liquid head (see 4.5.1) of not less than 96 inches and the metering knob set at the HI setting. Then the fuel flow shut off switch shall be turned to the "OFF" position. Failure of the fuel to stop flowing shall constitute a test failure.

4.5.4 Housing assembly operational fuel level and operational shut off tests.

4.5.4.1 Operational fuel level test. All housing assemblies (see 3.3.2) shall be set at a discharge fluid flow rate of 40 ± 4 cubic centimeters per minute. With this flow setting and at an inlet test liquid head of not less than 96 inches (see 4.5.1), the housing assembly shall be operated with the test liquid for 1 minute. The liquid level in the housing assembly shall then be checked to determine compliance with the fuel level requirements of 3.4.5.1. Any nonconformance shall constitute failure to pass this test.

4.5.4.2 Operational shut off test. After determining the operating fuel level of all fuel flow controls, the discharge flow of the test liquid in the above test shall be stopped by blocking the fuel outlet. When the flow of

Source: https://assist.dla.mil -- Downloaded: 2026-10-21T21:12Z
Check the source to verify that this is the current version before use.

fuel into the body from the fuel source stops, the level of fuel in the housing shall be checked. Failure of the fuel flow to stop when the fuel level is less than 1.250 inches (see 3.4.5.2) shall constitute a test failure.

4.5.5 Body leak test. The drain hole, open portions of the body, outlet, and overflow openings of the body assembly shall be sealed externally. The fuel flow control assembly shall then be pressurized with air at 10 pounds per square inch pressure through the fuel inlet. Any decrease in pressure, or a steady stream of bubbles if the assembly is submerged in a clear liquid, shall be evidence of leakage and shall constitute a test failure.

4.5.6 Plates, knobs and controls finishes test. The following test shall be applied to the first article inspection only. The plates, knobs, and controls finish coats shall be exposed to an atmosphere of 100 percent relative humidity with a temperature between 50°F and 100°F for 72 hours. After the atmosphere test, the plates, knobs, and controls shall then be immersed in kerosene at a temperature between 110°F and 120°F for 10 days. The plates, knobs, and controls shall then be removed and examined for peeling and then rubbed 15 times with 2 fingers in a dry cloth to determine compliance with the paint requirements specified in 3.5.1. Any nonconformance shall constitute failure to pass this test.

5. PACKAGING

5.1 Preservation. Preservation shall be level A or Commercial, as specified (see 6.2).

5.1.1 Level A preservation.

5.1.1.1 Preservation application. The interior of each fuel control shall be cleaned by process C-1, thoroughly dried, and then fogged through one of the openings in the control with a preservative conforming to type P-10, grade 1 of MIL-P-116. The interior surfaces shall be completely covered with the preservative, and there shall be no collection of excess oil in the control. All openings into the control shall be protected with plastic plugs and cap thread protectors conforming to MIL-C-5501. The control (M-41 only), in an upright position, shall have its connecting nipple placed vertically on the flat portion of the right side and secured with minimum 0.020 inch diameter plastic coated wire passing through the nipple and around the outer shield of the control.

5.1.1.2 Unit packing. Each fuel flow control shall be unit packed upright in a fiberboard box conforming to Grade V3c or V3s of PPP-B-636. The inside box dimensions shall be approximately 5-1/8 inches in length, 4-1/4 inches in width, and 5-3/4 inches in depth. Each box shall be closed in accordance with method V of PPP-B-636.

Source: https://assist.dla.mil -- Downloaded: 2026-10-21T21:12Z
Check the source to verify that this is the current version before use.

5.1.2 Commercial preservation. The fuel flow controls shall be preserved in accordance with ASTM D 3951.

5.2 Packing. Packing shall be level A, B, or Commercial, as specified (see 6.2).

5.2.1 Level A packing. Thirty fuel flow controls, preserved as specified in 5.1, shall be packed on edge in a wood shipping container conforming to overseas type, style 1 of PPP-B-601. The inside container dimensions shall be approximately 24-1/4 inches in length, 16-1/4 inches in width, and 12-1/2 inches in depth. Each shipping container shall be closed and strapped in accordance with the appendix of PPP-B-601.

5.2.2 Level B packing. Thirty fuel flow controls, preserved as specified in 5.1, shall be packed on edge in a fiberboard shipping container conforming to style RSC, type CF, class domestic, grade 275 of PPP-B-636. The inside container dimensions shall be approximately 24-1/4 inches in length, 16-1/4 inches in width, and 12-1/2 inches in depth. Each shipping container shall be closed in accordance with method II of the appendix of PPP-B-636.

5.2.2.1 Weather-resistant fiberboard container. When specified (see 6.2), the shipping container shall be a grade V3c, V3s, or V4s fiberboard box fabricated in accordance with PPP-B-636 and closed in accordance with method III in the appendix of PPP-B-636.

5.2.3 Commercial packing. Fuel flow controls, preserved and packaged as specified in 5.1, shall be packed in accordance with ASTM D 3951.

5.3 Palletization. When specified (see 6.2), fuel flow control containers, packed as specified in 5.2, shall be palletized on a 4-way entry pallet in accordance with load type I or Ia of MIL-STD-147. Pallet type shall be type I (4-way entry), type II, type IV, or type V in accordance with MIL-STD-147. Pallets shall be fabricated from wood groups I, II, III, and IV of MIL-STD-731. Each prepared load shall be bonded with straps by means C and D or film bonding means F or G. Pallet pattern shall be Number 8 in accordance with the appendix of MIL-STD-147.

5.4 Marking. In addition to any special marking required by the contract or purchase order, unit packs, shipping containers, and palletized unit loads shall be marked in accordance with MIL-STD-129 or ASTM D 3951, as applicable.

6. NOTES

(This section contains information of a general or explanatory nature that may be helpful, but is not mandatory.)

Source: https://assist.dla.mil -- Downloaded: 2026-10-21T21:12Z
Check the source to verify that this is the current version before use.

6.1 Intended use. The type I control is intended to be used on Heater, Space, Radiant Type, Portable, 45,000 BTU/HR (H-45) per MIL-H-13514. The type II control is intended to be used as a spare part on Burner Assembly, Space Heater (M-41) per MIL-B-2029.

6.2 Acquisition requirements. Acquisition documents must specify the following:

a. Title, number, and date of this specification.
b. Type required (see 1.2).
c. Issue of DODISS to be cited in the solicitation, and if required, the specific issue of individual documents referenced (see 2.1.1 and 2.2).
d. When a first article is required (see 3.1, 4.3, and 6.3).
e. Levels of preservation and packing (see 5.1 and 5.2).
f. When weather-resistant fiberboard containers are required (see 5.2.2.1).
g. When palletization is required (see 5.3).

6.3 First article. When a first article is required, it shall be inspected and approved under the appropriate provisions of Federal Acquisition Regulation (FAR) 52.209. The first article should be a preproduction sample. The contracting officer should specify the appropriate type of first article and the number of units to be furnished. The contracting officer should also include specific instructions in all acquisition documents regarding arrangements for selection, inspection, and approval of the first article.

6.4 Subject term (key word) listing.

Metering valve
Regulator
Stove
Zinc

6.5 Material safety data sheets. Contracting officers will identify those activities requiring copies of completed Material Safety Data Sheets prepared in accordance with FED-STD-313. The pertinent Government mailing addresses for submission of data are listed in FED-STD-313.

6.6 Changes from previous issue. Marginal notations are not used in this revision to identify changes with respect to the previous issue due to the extensiveness of the changes.

Source: https://assist.dla.mil - Downloaded: 2026-10-21T21:12Z
Check the source to verify that this is the current version before use.

Custodians:

Army - GL
Navy - YD
Air Force - 99

Review activities:

Army - MD
Air Force - 84
DLA - CS

User activities:

Army - CE
Navy - MC

Preparing activity:

Army - GL

(Project 4530-0004)

Source: https://assist.dla.mil -- Downloaded: 2026-10-21T21:12Z
Check the source to verify that this is the current version before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

INSTRUCTIONS

1. The preparing activity must complete blocks 1, 2, 3, and 8. In block 1, both the document number and revision letter should be given.
2. The submitter of this form must complete blocks 4, 5, 6, and 7.
3. The preparing activity must provide a reply within 30 days from receipt of the form.

NOTE: This form may not be used to request copies of documents, nor to request waivers, or clarification of requirements on current contracts. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document(s) or to amend contractual requirements.

I RECOMMEND A CHANGE:	1. DOCUMENT NUMBER	2. DOCUMENT DATE (YYMMDD)
	MIL-C-43343E	1992 February 26

3. DOCUMENT TITLE
CONTROL, FUEL FLOW, OIL BURNER

4. NATURE OF CHANGE (Identify paragraph number and include proposed rewrite, if possible. Attach extra sheets as needed.)

5. REASON FOR RECOMMENDATION

6. SUBMITTER

a. NAME (Last, First, Middle Initial)	b. ORGANIZATION	
c. ADDRESS (Include Zip Code)	d. TELEPHONE (Include Area Code) (1) Commercial (2) AUTOVON (If applicable)	7. DATE SUBMITTED (YYMMDD)

8. PREPARING ACTIVITY

a. NAME	b. TELEPHONE (Include Area Code) (1) Commercial	(2) AUTOVON/DSN
U.S. Army Natick RD&E Center	508-651-4531	256-4531
c. ADDRESS (Include Zip Code) Commander, U.S. Army Natick RD&E Center ATTN: STRNC-UXT Natick, MA 01760-5017	IF YOU DO NOT RECEIVE A REPLY WITHIN 45 DAYS, CONTACT: Defense Quality and Standardization Office 5203 Leesburg Pike, Suite 1403, Falls Church, VA 22041-3466 Telephone (703) 756-2340 AUTOVON 289-2340	

Source: https://assist.dla.mil -- Downloaded: 2022-10-12 12:20 EDT
Check the source to verify that this is the current version before use.

DD Form 1426, OCT 89 Previous editions are obsolete 198/25