[INCH-POUND]
A-A-55429F
8 June 2022
SUPERSEDING
A-A-55429E
5 October 2017

COMMERCIAL ITEM DESCRIPTION

FUSEHOLDER, BLOCK, CLASS H, 100 AMPERE, 600 V AC, ONE, TWO, AND THREE POLE

The General Services Administration has authorized the use of this commercial item description for all federal agencies.

1. SCOPE. This commercial item description (CID) covers the general requirements for one, two, and three pole, 100 ampere, 600 V AC, type H fuseholder blocks. Fuseholders covered by this CID are intended for commercial/industrial applications.

2. CLASSIFICATION/PART OR IDENTIFICATION NUMBER (PIN). This CID uses a classification system which is included in the PIN as shown in the following example (see 7.1).

AA55429	-	001
CID number		Dash number (see table I)

3. SALIENT CHARACTERISTICS.

3.1 Interface and physical dimensions. Fuseholders supplied to this CID shall be as specified herein and shall meet the requirements of UL 4248-1 and UL 4248-6 for class H fuseholders (see figure 1).

3.2. Ampere rating. The ampere rating shall be 100 amperes maximum.

3.3 Voltage rating. The voltage rating shall be 600 V ac maximum.

3.4 Interrupting rating. This class H fuseholder shall be used with class H fuses that have an interrupting rating of 10,000 amperes maximum.

3.5 Wire termination. Wire termination shall be specified on figure 2 and as follows:

a. Screw connector for use with spade tugs or ring terminals.

b. Screw with pressure plate connector for use with solid or standard wire without terminal (recommended where vibration will be a factor).

c. Box lug connector (the most durable). For use with all types of wire without terminal.

Beneficial comments, recommendations, additions, deletions, clarifications, etc., and any data that may improve this document should be sent to: DLA Land and Maritime, ATTN: VAT, P.O. Box 3990, Columbus, OH 43218-3990, or email CircuitProtect@dla.mil. Since contact information can change you may want to verify the currency of the address information using the ASSIST Online database at https://assist.dla.mil/.

AMSC N/A
FSC 5920
DISTRIBUTION STATEMENT A. Approved for public release, distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:46Z
Check the source to verify that this is the current version before use.




FIGURE 1. Configuration and dimensions.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:46Z
Check the source to verify that this is the current version before use.

Inches	mm	Inches	mm
.261	6.53	2.125	53.97
.281	7.14	2.375	60.32
.343	8.73	2.620	66.67
.50	12.7	4.031	102.39
.671	17.06	4.250	107.95
.875	22.22	5.843	148.43
1.109	28.17	9.50	241.3
1.812	46.03		

NOTES:

1. Dimensions are in inches.
2. Tolerance is ±.005 inch (0.13 mm), unless otherwise specified.

FIGURE 1. Configuration and dimensions - Continued.




FIGURE 2. Wire termination configuration.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:46Z
Check the source to verify that this is the current version before use.

TABLE I. Characteristics.

AA55429-	Characteristics
001	1 pole with screw connectors. Fuse clips with reinforcing springs.
002	1 pole with box lug connectors. Fuse clips with reinforcing springs.
003	2 pole with screw connectors. Fuse clips with reinforcing springs.
004	2 pole with box lug connectors. Fuse clips with reinforcing springs.
005	3 pole with screw connectors. Fuse clips with reinforcing springs.
006	3 pole with box lug connectors. Fuse clips with reinforcing springs.

3.6 Wire size. The maximum wire size shall be #1/0 CU-AL for screw connectors and screw with pressure plate connectors and #6/0 CU-AL for box lug connectors.

3.7 Reinforcing spring. Reinforcing springs are used for reinforcement of the fuse clip. Spring reinforced fuse clips are recommended if frequent fuse replacement is expected.

3.8 Fuse accomodation. This fuseholder accepts class H fuses with dimensions of 7.875 inches, (200.02 mm) a blade thickness of .125 inch (3.17 mm), and a blade width of .750 inch (19.05 mm).

3.9 Marking. Fuseholders supplied to this CID shall be marked with the manufacturer's (MFR's) standard commercial PIN and the UL listing mark. (NOTE: The part number marked on the unit pack shall be the CID PIN.)

3.10 Recycled, recovered, or environmentally preferable, or biobased materials. Recycled, recovered, or environmentally preferable, or biobased materials should be used to the maximum extent possible provided that the material meets or exceeds the operational and maintenance requirements, and promotes economically advantageous life cycle costs.

3.11 Workmanship. Fuseholders shall be processed in such a manner as to be uniform in quality and shall be free from other defects that will affect life, serviceability, or appearance.

4. REGULATORY REQUIREMENTS. The offeror/contractor is encouraged to use recovered materials to the maximum extent practicable, in accordance with 23.403 of the Federal Acquisition Regulation (FAR).

5. PRODUCT CONFORMANCE PROVISIONS

5.1 Product conformance. The products provided shall meet the salient characteristics of this CID, conform to the producer's own drawings, specifications, standards, and quality assurance practices, and be the same product offered for sale in the commercial market. The Government reserves the right to require proof of such conformance.

5.2 Market acceptance. The following market acceptance criteria are necessary to document the quality of the product to be provided under this CID:

a. The company producing the item must have been producing a product meeting the requirements of this CID for at least 2 years.

b. The company producing the item must have sold 1,000 units meeting this CID in the commercial marketplace over the past 2 years.

6. PACKAGING. Preservation, packing, and marking shall be as specified in the contract or order.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:46Z
Check the source to verify that this is the current version before use.

7. NOTES.

7.1 PIN. The PIN should be used for Government purposes to buy commercial products to this CID. See section 2 for PIN format example.

7.2 Commercial and Government Entity (CAGE) code. For ordering purposes, inventory control, and submission of these fuseholders to DLA Land and Maritime under the Parts Management Evaluation Team (PMAT) evaluation program, CAGE code 58536 should be used.

7.3 Source of documents.

FEDERAL REGULATIONS

FAR - Federal Acquisition Regulations (FAR)

(Copies of this document is available online at https://www.acquisition.gov/.

Other Publications

UNDERWRITERS LABORATORIES, INCORPORATED (UL)

UL 4248-1 - UL Standard for Safety Fuseholders - Part 1: General Requirements.

UL 4248-6 - UL Standard for Safety Fuseholders- Part 6: Class H.

(Copies of these documents are available online at https://www.ul.com/.

(Industry association specifications and standards are generally available for reference from libraries. They are also distributed among technical groups and using Federal agencies.)

7.4 Ordering data. The contract or order should specify the following:

a. CID document number, revision, and CID PIN.

b. Product conformance provisions.

c. Packaging requirements.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:46Z
Check the source to verify that this is the current version before use.

7.5 Commercial products. As part of the market analysis and research effort, this CID was coordinated with the following manufacturers of commercial products. At the time of CID preparation and coordination, these manufacturers were known to have commercial products that would meet the requirements of this CID. (NOTE: This information should not be considered as a list of approved manufacturers or be used to restrict procurement to only the manufacturers shown.)

MFR's CAGE	MFR's name and address
26405	Marathon Special Products Corporation 13300 Van Camp Road Bowling Green, OH 43402-9391 Phone number (419) 352-8441 Facsimile number (800) 515-7151 E-mail: bret.danks@regalbeloit.com Uniform Resource Locator (URL): https://www.marathonsp.com/
71400	Cooper Bussmann, Incorporated 114 Old State Road Ellisville, MO 63021-5915 Phone number (636) 394-2877 Facsimile number (636) 527-1415 E-mail: debbiewortmann@eaton.com URL: https://www.eaton.com
71424	Mersen 374 Merrimac Street Newburyport, MA 01950-1930 Phone number (978) 462-6662 Facsimile number (978) 462-6760 E-mail: tom.giuliano@mersen.com URL: https://mersen.com
75915	Littelfuse Incorporated 8755 W. Higgins Road; Suite 500 Chicago, IL 60631-2701 Phone number (847) 391-0210 Facsimile number (847) 391-0753 E-mail: jbaker@littelfuse.com URL: https://www.littelfuse.com

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:46Z
Check the source to verify that this is the current version before use.

7.6 Part number (P/N) supersession data. This CID PINs supersedes the following MFR's P/N's as shown. This information is being provided to assist in reducing proliferation in the government inventory system.

TABLE III. P/N supersession data.

CID dash number AA55429-	MFR's CAGE 26405	MFR's CAGE 71400	MFR's CAGE 71424	MFR's CAGE 75915
	MFR's P/N 1/	MFR's P/N 1/	MFR's P/N 1/	MFR's P/N 1/
001	N/A	H60100-1SR	N/A	N/A
002	R6F100A1B	H60100-1CR	61036	LH60100-1C
003	N/A	H60100-2SR	N/A	N/A
004	R6F100A2B	H60100-2CR	N/A	LH60100-2C
005	N/A	H60100-3SR	N/A	N/A
006	R6F100A3B	H60100-3CR	61038	LH60100-3C

1/ The manufacturer's P/N shall not be used for acquisition to the requirements of this CID. At the time of preparation of this CID, the aforementioned commercial products were reviewed and could be replaced by the CID P/N shown. For actual part marking requirements see 3.9.

7.7 Government users. To acquire information on obtaining these fuseholder blocks from the Government inventory system, contact DLA Land and Maritime, ATTN: DLA Land and Maritime-FMTE, P.O. Box 3990, Columbus, OH 43218-3990, or telephone (614) 692-4023.

7.7.1 National stock number (NSN). The following is a list of NSN's assigned which correspond to this CID. The list is for information only and may not be indicative of all possible NSN's associated with the CID. For up to date information on assigned NSN's, please contact the aforementioned DLA Land and Maritime office (See 7.7).

TABLE IV. NSN's.

Dash number (see table I) AA55429-	NSN
001	N/A
002	N/A
003	N/A
004	N/A
005	N/A
006	5920-01-284-9038

7.8 Changes from previous issue. Margins of this CID are marked with vertical lines to indicate where changes from the previous issue were made. This was done as a convenience only and the Government assumes no liability whatsoever for any inaccuracies in these notations. Bidders and contractors are cautioned to evaluate the requirements of this document based on the entire content irrespective of the marginal notations and relationship to the last previous issue.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:46Z
Check the source to verify that this is the current version before use.

MILITARY INTERESTS:

Custodians:
Navy - EC
DLA - CC

CIVIL AGENCY COORDINATING ACTIVITY:

GSA - FAS

Preparing activity:

DLA-CC

Project 5920-2022-015

NOTE: The activities listed above were interested in this document as of the date of this document. Since organizations and responsibilities can change, you should verify the currency of the information above using the ASSIST Online database at https://assist.dla.mil.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T09:46Z
Check the source to verify that this is the current version before use.