MILITARY SPECIFICATION SHEET

GENERATOR SETS, DIESEL ENGINE DRIVEN,

10 KW, 400 HERTZ; TACTICAL, UTILITY

This specification is approved for use by all Departments and Agencies of the Department of Defense.

REQUIREMENTS

1. Drawings. The set shall be in accordance with Top Assembly 30554-71-112 and as specified herein.

2. Short circuit. The generator, exciter and voltage regulator, operating as a unit, shall withstand, without damage, 10 consecutive and instantaneous 3 second single-phase line-to-line, single-phase line-to-neutral, and symmetrical 3 phase short circuits at the generator output terminals when operating at rated load and frequency without reduction of dielectric strength to a point where it will not meet the requirements of 3.9.5. The instantaneous short circuit current shall be not less than 350 percent of rated output current. The sustained 3 second short circuit current shall be not less than 250 percent of rated output current. This requirement applied to each of the following conditions:

(a) 120V, 1 phase: L1-L3.
(b) 120/240V, 1 phase: L1-L0, L3-L0, L1-L3.
(c) 120/208V, 3 phase: L1-L0, L2-L0, L3-L0, L1-L2-L3, L1-L2, L2-L3, L1-L3.

3. Transient reactance, rated voltage. With the generator connected for 120/208 volts, 3 phase, 4 wire, the direct axis transient reactance shall not exceed 16 percent. The single phase transient reactance, with the set connected for 120 V, 1 phase, 2 wire shall not exceed 25 percent.

4. Negative sequence impedance. The generator negative sequence impedance, with the set connected for 120/208 V, 3 phase, 4 wire, shall not exceed 15 percent.

5. Voltage modulation. The voltage modulation shall not exceed 1.0 percent.

6. Field current. With the generator temperature stabilized at normal ambient conditions, the exciter field current shall not exceed 0.88 ampere for no load and 1.3 amperes for rated load.

7. Generator efficiency. The generator (including the excitation system) efficiency shall not be less than 78 percent at 0.8 pf in the 3 phase 120/208 voltage connection.

FSC 6115

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:39Z
Check the source to verify that this is the current version before use.

8. Alternating current circuit breaker. The circuit breaker shall operate as follows for all voltage connections. At 110 percent of rated set current, the circuit interrupter shall not open. At 140 percent of rated set current, the circuit interrupter shall open between 1.0 and 15 minutes at ambient temperatures above 60° F (15.6° C) and within 30 minutes below 60° F (15.6° C). The circuit interrupter shall open within 0.03 seconds in the 120 V single phase and 120/208 V three phase connections, and within .150 seconds in the 120/240V single phase connection under the conditions of a short circuit in any one phase or in all phases simultaneously. In all cases, all phases shall open simultaneously.

Custodians:
Army - ME
Navy - YD
Air Force - 99

Review activities:
Navy - MC
DLA - GS

User activity:
Navy - CG

Preparing activity:
Army - ME

Project 6115-0230

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:39Z
Check the source to verify that this is the current version before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

INSTRUCTIONS: This form is provided to solicit beneficial comments which may improve this document and enhance its use. DoD contractors, government activities, manufacturers, vendors, or other prospective users of the document are invited to submit comments to the government. Fold on lines on reverse side, staple in corner, and send to preparing activity. Attach any pertinent data which may be of use in improving this document. If there are additional papers, attach to form and place both in an envelope addressed to preparing activity. A response will be provided to the submitter, when name and address is provided, within 30 days indicating that the 1426 was received and when any appropriate action on it will be completed.

NOTE: This form shall not be used to submit requests for waivers, deviations or clarification of specification requirements on current contracts. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document(s) or to amend contractual requirements.

DOCUMENT IDENTIFIER (Number) AND TITLE MIL-G-52889/3 Generator Sets, Diesel Engine Driven, 10 KW, 400 Hertz; Tactical, Utility

NAME OF ORGANIZATION AND ADDRESS OF SUBMITTER

☐ VENDOR ☐ USER ☐ MANUFACTURER

1. ☐ HAS ANY PART OF THE DOCUMENT CREATED PROBLEMS OR REQUIRED INTERPRETATION IN PROCUREMENT USE? ☐ IS ANY PART OF IT TOO RIGID, RESTRICTIVE, LOOSE OR AMBIGUOUS? PLEASE EXPLAIN BELOW.

A. GIVE PARAGRAPH NUMBER AND WORDING

B. RECOMMENDED WORDING CHANGE

C. REASON FOR RECOMMENDED CHANGE(S)

2. REMARKS

SUBMITTED BY. (Printed or typed name and address — Optional)

TELEPHONE NO.

DATE

DD FORM 1 OCT 76 1426 EDITION OF 1 JAN 72 WILL BE USED UNTIL EXHAUSTED.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:39Z
Check the source to verify that this is the current version before use.

FOLD

DEPARTMENT OF THE ARMY

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE $300

NO POSTAGE NECESSARY IF MAILED IN THE UNITED STATES

BUSINESS REPLY CARD

FIRST CLASS PERMIT NO. 12062 WASHINGTON D. C.

POSTAGE WILL BE PAID BY THE DEPARTMENT OF THE ARMY

Commander
US Army Mobility Equipment Research and
Development Command
ATTN: DRDME-DS
Fort Belvoir, VA 22060

FOLD

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:39Z
Check the source to verify that this is the current version before use.