INCH POUND

MIL-C-915/74C
29 September 1989
SUPERSEDING
MIL-C-915/74B
18 June 1985

MILITARY SPECIFICATION SHEET

CABLE, POWER ELECTRICAL, 600 VOLTS, FOR OUTBOARD USE ONLY
(NOT FOR INBOARD USE) TYPE 5SS

This specification sheet is approved for use by all Departments and Agencies of the Department of Defense.

The requirements for acquiring the product described herein shall consist of this specification sheet and the issue of the following specification listed in that issue of the Department of Defense Index of Specifications and Standards (DoDISS) specified in the solicitation: MIL-C-915.

REQUIREMENTS:

Qualification required.

Construction (non-watertight)

First	- Copper conductor, uncoated. AWG size 18, class M stranding, (41/no. 34).
Second	- Separator.
Third	- Synthetic rubber insulation. Nominal thickness 0.032 inch. Identification by method 3; one conductor black, two white, one red and one green.
Fourth	- Braided shield (one white conductor only) of AWG no. 34 tin coated copper. Braid angle of 30 to 35 degrees; minimum coverage of 88 percent.
Fifth	- Shield insulation of one 0.002-inch thick polyester tape applied helically with 50 percent minimum overlap.
Sixth	- The five conductors cabled with a 3.75 ± 0.25-inch right hand lay around a moisture resistant jute center. Cabling sequence shall be black, white, white with shield, green and red.
Seventh	- Binder tape 0.012-inch thick double-faced, rubber-filled cotton tape applied helically with overlap.
Eighth	- Overall braided shield of AWG no. 34 tin coated copper. Braid angle of 30 to 35 degrees; minimum coverage of 88 percent.

AMSC N/A FSC 6145

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 202610-16T12:16Z
Check the source to verify that this is the current version before use.

REQUIREMENTS - Continued

Ninth - Shield insulation of one 0.002-inch thick polyester tape applied helically with 50 percent overlap.

Tenth - Polychloroprene jacket. Minimum thickness 0.050 inch. Cable diameter 0.500 inch minimum, 0.560-inch maximum. Surface of cable shall be embossed at approximately 3-foot intervals with the following information: The year of manufacture, type 5SS 5 CONDCT No. 18 SHLD 600 VOLTS.

EXAMINATION AND TESTS:

	Requirements
Basic electrical:	
Conductor resistance - ohms/1000 feet, at 25°C, maximum	7.15
Voltage withstand - volts, root mean square, minimum	
Conductor to shield	1000
Shield to shield (single shields only)	500
Insulation resistance - megohms/1000 feet, minimum	
Conductor to shield	5000
Shield to shield (single shields only)	100
Group A:	
Visual and dimensional	No failure
Group B:	
Physicals (unaged)	
Insulation	
Tensile strength - lbf/in², minimum	1000
Elongation - percent, minimum	350
Set - inch, maximum	3/8
Jacket	
Tensile strength - lbf/in², minimum	2400
Elongation - percent, minimum	325
Tensile stress - lbf/in², minimum at 200 percent elongation (ASTM D 470)	700
Set - inches, maximum	1/4
Tear - pounds per inch thickness, minimum (ASTM D 470)	40
Bending endurance - cycles at minus 30 ± 2°C on 4-inch maximum diameter mandrel	1000
Group C:	
Physicals (aged)	
Insulation	
Air pressure heat	
Tensile strength - percent of unaged, minimum	75
Elongation - percent of unaged, minimum	60

Source: https://assist.dla.mil -- Downloaded: 202610-16T12:16Z
Check the source to verify that this is the current version before use.

EXAMINATION AND TESTS - Continued

	Requirements
Jacket	
Air pressure heat	
Tensile strength - percent of unaged, minimum	65
Elongation - percent of unaged, minimum	60
Oxygen pressure	
Tensile strength - percent of unaged, minimum	65
Elongation - percent of unaged, minimum	60
Shield-conformance to material coverage and construction	No failure

QUALIFICATION INSPECTION:

Qualification inspection shall include basic electrical, plus all of groups A, B and C.

UNIT ORDERING LENGTHS:

Two thousand feet continuous lengths, except that 20 percent of total quantity may be in lengths between 1000 and 2000 feet but none less than 1000 feet.

NOTE: Cable shall be shipped on nonreturnable reels, one length per reel and the outside end of cable shall have the conductors in clockwise sequence as follows: green, red, black, white and white-shielded.

NOTE: Not for Air Force use.

Revision letters are not used to denote changes due to the extensiveness of the changes.

Custodians:
Army - MI
Navy - SH

Preparing activity:
Navy - SH
(Project 6145-1127-17)

Review activities:
Army - CR, ER
Navy - EC
DLA - IS

User activities:
Army - AL, AR, ME
Navy - CG

Source: https://assist.dla.mil -- Downloaded: 2026-10-16T12:16Z
Check the source to verify that this is the current version before use.