A-A-2218
July 19, 1984

COMMERCIAL ITEM DESCRIPTION

LAMP, MERCURY VAPOR

The General Services Administration has authorized the use of this commercial item description.

This description covers mercury vapor lamps of 250 watts.

Salient characteristics.

The base shall be made of brass.
Burning position - Any.
Use on mercury ballasts, ANSI H-5 or H37.
Base - Mogul screw.
Maximum Overall Length - 8-1/4 inches
Rated average life -24,000 Hours
The lamps shall have the characteristics listed in Table I.

TABLE I

Type	ANSI Code	NSN 6240-00-	Bulb	Color	Approximate Lumens Vert. Operation Initial*/Mean**	
1	H37KC-250/DX	885-6821	E-28, BT-28	D.White	12,100	9,800
2	H37KB-250	758-3367	E-28, BT-28	Clear	11,200	9,800

*Initial lumen ratings are based on photometry of lamps operating vertically, on a standard reference ballast, after lamps have been operated for 100 hours.

**Mean lumen ratings are based on photometry of lamps operating vertically, on a standard reference ballast, after lamps have been operated for 50 percent of their rated life at 10 hours per start on typical commercial ballasts.

The lamps shall be measured in accordance with ANSI Standards C78.386 and C78.1325.

The issues of ANSI Standards C78.386 and C78.1325 in effect on the date

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:20Z
Check the source to verify that this is the current version before use.

of the solicitation shall be used to determine compliance with these requirements.

Regulatory requirements. The offeror/contractor is encouraged to use recovered materials in accordance with Public Law 94-580 to the maximum extent practical.

Preservation, packaging, packing, labeling, and marking. The preservation, packaging, packing, labeling, and marking shall be as specified in the contract or order.

Preproduction inspection. One package of lamps, produced using the same tooling, production, and assembly methods that are used for production lots, shall be submitted for examination and test in accordance with the above requirements. Documentation consisting of the certification and test data shall be presented for examination during performance of the preproduction inspection. Failure of the preproduction samples to pass the examination of one or more of the tests, the lack of required documentation, or failure of the documentation to substantiate conformance to the requirements of this CID shall be cause for rejection.

Notes. ANSI Standard C78,386 and C78.1325 are available from the American National Standards Institute, Inc., 1430 Broadway, New York, New York 10018.

The commercial item certification clause is not required when this commercial item description is used for procurement.

Military Coordinating Activity

None. DoD has waived coordination on this commercial item description until further notice.

PREPARING ACTIVITY:
GSA-FSS

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:20Z
Check the source to verify that this is the current version before use.