A-A-2294
November 21, 1984

COMMERCIAL ITEM DESCRIPTION

EDUCTOR (BY-PASS & INLINE)

The General Services Administration has authorized the use of this commercial item description.

This description covers an eductor which proportions chemicals into water by venturi action or by-passes and delivers plain water. Eductors shall be furnished in the following styles. All sizes shown are in inches.

Style	Type	Flow (GPM)	Inlet Size	Outlet Size
1	Inline	30	1-1/2	1-1/2
2	Inline	60	1-1/2	1-1/2
3	Inline	95	1-1/2	1-1/2
4	Inline	95	2-1/2	1-1/2
5	By-Pass	95	1-1/2	1-1/2
6	Inline	120	2-1/2	2-1/2
7	Inline	250	2-1/2	2-1/2

Salient characteristics

Eductor shall be calibrated to operate at a pressure of 200 psi.
The pick-up tube shall be made of clear plastic with a removable strainer.
The eductor body shall be made of cast brass.
A calibrated metering valve providing for positive stops for 1-, 2-, 3-, and 6-percent foam setting shall be furnished.
Nozzle gallonage must match that of eductor used. If nozzle has a selection dial, it should be set at that GPM matching the listed rating of the eductor.
Eductor shall be provided with a ball check valve to prevent back-flow into foam.
Unless otherwise specified all threads shall be of the NH series.
Shall be provided with rocker lugs.
By-Pass handle shall be parallel with the central axis of the outlet waterway.

Conformance testing.

Vacuum Test. Pick-up tube base shall withstand a vacuum of 25 inches of mercury.

Dry Torque Test. (By-pass type only). The eductor shall be dry and without hydrostatic pressure. A torque wrench shall be installed in place of the by-pass handle and turned to its open and closed position, The peak torque shall not exceed 150 pound-inches.

Hydrostatic Pressure Torque Test (By-pass type only). The eductor shall be connected to a hydrostatic pressure source and 200 psi pressure applied The eductor discharge end shall be open. The torque wrench shall be turned to the by-pass open and closed position. The peak torque shall not exceed 200 pound-inches.

Proof Pressure Test (Both types). The eductor shall be connected to a hydrostatic pressure source and a pressure of 500 psi applied. The eductor

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:21Z
Check the source to verify that this is the current version before use.

discharge shall be closed. The eductor shall then be examined for any distortion, mechanical damage, failures, or leaks.

Hose Lay Limits on Discharge Side of Eductor with 200 psi Inlet Pressure:

30 GPM	500 ft of 1-1/2 inch hose
60 GPM	300 ft of 1-1/2 inch hose
95 GPM	150 ft of 1-1/2 inch hose
120 GPM	750 ft of 2-1/2 inch hose
250 GPM	200 ft of 2-1/2 inch hose

Workmanship. Cast parts shall be fine-grained and free from blowholes, porosity, hard spots, shrinkage, cracks, and other defects. Exterior surfaces shall be smooth. Excessive material on edges shall not be allowed. Eductor shall be free of any defects which may affect the durability, appearance, or serviceability.

Regulatory requirements. The offeror/contractor is encouraged to use recovered materials in accordance with Public Law 94-580 to the maximum extent practicable.

Preservation, packaging, packing, labeling, and marking. The preservation, packaging, packing, labeling, and marking shall be as specified in the contract or order.

Note. When this commercial item description is used for procurement the commercial item certification clause must appear in the solicitation.

Purchaser shall specify style desired.

Review Interest

Army - ME

PREPARING ACTIVITY:

GSA-FSS

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:21Z
Check the source to verify that this is the current version before use.