MILITARY SPECIFICATION

EXTINGUISHING SYSTEM, FIRE, AIRCRAFT,
HIGH-RATE-DISCHARGE TYPE, INSTALLATION AND TEST OF

This amendment forms a part of Military Specification MIL-E-22285 (Wep) of 11 December 1959, and has been approved by the Bureau of Naval Weapons, Department of the Navy.

Page 3, paragraph 3.8, line 2: Delete "at least 15 percent by volume" and substitute "at least 6 percent by volume in air (22% by weight)."

Page 4, paragraph 3.8.3: Delete and substitute:

"3.8.3 Added factor for agent loss - Where long discharge lines are used, compliance with 3.8 may require an increase in the value of W obtained in the formulas of 3.8.1, in order to compensate for agent lost in wetting the discharge lines.

Page 5, paragraph 3.16: Delete the second sentence and substitute: "Supply lines between the containers and the discharge opening should, where practicable, be 10 feet or less in length."

Page 5: Add the following new paragraph:

"3.15.2.1 Number of containers - In a 4 engine aircraft, both initial and reserve fire extinguishing coverage may be obtained by using a total of 4 agent containers. This includes 2 central systems, with each central system serving 2 engines. Each central system thus includes one initial discharge container and one reserve discharge container."

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T11:48Z
Check the source to verify that this is the current version before use.