
FEDERAL SPECIFICATION SHEET

FUSE, CARTRIDGE, CLASS H, RENEWABLE, 250 VOLTS, 31-60 AMPERES

(DETAIL SPECIFICATION)

This specification was approved by the Commissioner, Federal Supply Service, General Services Administration, for the use of all Federal agencies.

The complete requirements for procuring the fuses described herein shall consist of this document and the latest issue of Specification W-F-1726.



NOTES:
1. Dimensions are in inches.
2. Metric equivalents (to the nearest .01 mm) are given for general information only and are based upon 1 inch = 25.4 mm.
3. Minimum acceptable thickness of tube wall .062 (1.57 mm), ferrule sidewall .029 (.74 mm).
4. Metric equivalents are in parentheses.

FSC 5920

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:35Z
Check the source to verify that this is the current version before use.

REQUIREMENTS:

Design and construction - See figure.

Physical:
Renewable - The fuse shall be designed to permit replacement of the renewal element and restore service after each interruption. Each fuse tested shall be capable of renewal five times. No special tools shall be required to facilitate renewal.
Terminals - Ferrule type.
Material - Brass or copper alloy.
Strength - 5 pound-inches torque between body and ferrules.
Alignment - The inside diameter of tubular gage shall be not more than 0.823 inch.
Ferrules - Shall be approximately circular in cross-section.

Body:
Insulating material - Fiber, ceramic, melamine-impregnated glass fiber, or other suitable material.

Electrical:
Voltage - 250 volts or less.

Current - See table.

Current carrying capacity - 110 percent indefinitely with temperature rise not to exceed 50°C above ambient on the body and the ferrules.

Overload interrupt - Shall interrupt within 1 hour at 135 percent of rated current and within 4 minutes at 200 percent of rated current.

Short circuit interrupt - 10,000 amperes at 250 volts.

Applicable fuseholders: Type II in accordance with W-F-870.

Part number: See table.

Government part number	Current rating (amps)
WF1726/14-001	35
002	40
003	45
004	50
005	60

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:35Z
Check the source to verify that this is the current version before use.

MILITARY CUSTODIANS:

Army - EL
Navy - YD
Air Force - 80

Review activities:

Army - EL
Navy - SH, MC
Air Force - 80
DSA - ES
NS

User activities:

Army -
Navy - AS, OS
Air Force - 11

Preparing activity:

DSA - ES

Civil Agency Coordinating Activities:

AEC - AEC
DOT - FIS
GSA - FSS, PBO
NASA - JFK, MSF
HEW - NIH
USDA - AFS

(Project 5920-0328-14)

Orders for this publication are to be placed with General Services Administration, acting as an agent for the Superintendent of Documents. See section 2 of the general specification to obtain extra copies and other documents referenced herein. Price 10 cents each.

Source: https://assist.dla.mil -- Downloaded: 20260-26T11:35Z
Check the source to verify that this is the current version before use.