INTERIM AMENDMENT

TO

FEDERAL SPECIFICATION

DRY CHEMICAL, FIRE EXTINGUISHING,
POTASSIUM BICARBONATE

This interim amendment was developed by the Naval Facilities Engineering Command, Naval Construction Battalion Center, Port Hueneme, CA 93043, based upon currently available technical information. It is recommended that Federal agencies use it in procurement and forward recommendations for changes to the preparing activity at the address shown above.

The General Services Administration has authorized the use of this interim amendment as a valid exception to Federal Specification O-D-1407, dated August 9, 1972.

PAGE 4

Paragraph 3.1.1, Table I. Delete Table I and substitute:

"TABLE I. Chemical and physical requirements

Requirement	Value	Test Paragraph
Potassium bicarbonate ($KHCO_3$) content, percent by weight, min	92.0	4.3.1
Moisture content, percent by weight, max	0.2	4.3.2
Hygroscopicity, percent gain in weight, max	2.5*	4.3.3
Apparent density, grams per ml, min	0.88	4.3.4
Caking and lumping tendency, penetration, min	23.5 mm or 235 units*	4.3.5
Packed density, grams per ml, min	1.12	4.3.6
Packed powder discharge, percent by weight, min	88.0	4.3.7
Foam compatibility, average drainage rate, ratio of drainage rate with dry chemical added compared to blank, max	2.5	4.3.8
Specific surface area, square cm per gram	4200-6000*	4.3.9
Color identification	purple	4.3.10

*Value changed from O-D-1407"

FSC 4210

Source: https://assist.dla.mil -- Downloaded: 202610-26T11:16Z
Check the source to verify that this is the current version before use.

Table II. In "Minimum" column for U. S. screen size 325, delete "12.0" and substitute "10.0".

PAGE 11

Paragraph 6.3. Delete paragraph in its entirety.

Preparing activity:

Navy - YD

Project No. 4210-0301

Source: https://assist.dla.mil -- Downloaded: 202610-26T11:16Z
Check the source to verify that this is the current version before use.