A-A-2284
August 27, 1984

COMMERCIAL ITEM DESCRIPTION

HOSE ASSEMBLY, NON-METALLIC (FIRE; COTTON; SINGLE-JACKETED)

The General Services Administration has authorized the use of this commercial item description in preference to Federal Specification ZZ-H-451F, Type I, Class C.

This description covers cotton, lined, single-jacketed hose for fire protection purposes.

The hose assemblies shall be furnished in two types, as specified:

Type I - 1 inch minimum inside hose diameter with 1 inch by 11 1/2 NPSH threads.
Type II - 1 1/2 inch minimum inside hose diameter with 1 1/2 by 9 NH threads.

Salient characteristics.

Configuration. The hose assemblies shall consist of a hose section fitted with one male coupling and one female coupling.

Hose. Cotton, woven, lined, single-jacketed with a 50 foot minimum length and the inside diameter as specified.

Coupling. One threaded male piece with expansion ring and one threaded female piece with swivel section and expansion ring shall be provided. Couplings shall be provided with rocker lugs. The couplings shall be made of either brass of hardcoated aluminum, meeting the requirements of UL Standard 236.

Proof pressure. 300 psi

Kink pressure. 300 psi

Burst pressure. 600 psi

Conformance. Type I hose shall be certified by the manufacturer that it meets the intent of Underwriters Laboratories (UL) Standard 19. Type II hose shall meet the requirements of UL Standard 19.

The issues of UL standards in effect on the date of the solicitation shall be used to determine compliance with these requirements.

Workmanship. Jacket shall be well, evenly, and firmly woven and as free from unsightly defects, dirt, knots, lumps, and irregularities of twist as is consistent with good manufacturing practice. The waterway surface of the lining shall be practically free from pitting corrugations or other irregularities or imperfections. The hose shall be free of defects which may affect the durability, appearance or serviceability.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:21Z
Check the source to verify that this is the current version before use.

Regulatory requirements. The offeror/contractor is encouraged to use recovered materials in accordance with Public Law 94-580 to the maximum extent practicable.

Preservation, packaging, packing, labeling, and marking (GSA). The preservation, packaging, packing, labeling, and marking shall be as specified in the contract or order.

Preservation, packaging, packing, labeling, and marking (DOD). Military packaging shall be as specified when shipments are to be overseas Department of Defense (DoD) consignees. Commercial packaging may be as specified for shipments to DoD consignees within the continental United States and to non-DoD consignees worldwide. When a supplier's normal packaging will satisfy the requirements for military packaging, it may be used.

Military packaging. Each hose shall be preserved and packed to protect it against physical damage and deterioration in a logistic environment characterized by the following:

1. Multiple handling during transporation and intransit storage.
2. Shock, vibration, and static loading forces during worldwide shipment by all transport modes.
3. Uncontrolled warehouse storage for extended periods.
4. Weather exposure during shipment and intransit transfers.
5. Stacking loads during shipment and storage.

Quantities of hose destined to a single addressee may be unitized into one or more loads.

Commercial. Each hose shall be packaged in accordance with the supplier's normal method of retail distribution. Hoses shipped to a single destination may be unitized to handling as a single unit. Shipping containers shall comply with Uniform Freight Classification or National Motor Freight Classification rules.

Marking. Unit, intermediate (when provided), and exterior packs shall be marked with the item nomenclature, stock or part number, quantity per pack, and contract number as a minimum; additional marking shall be as specified in the contract or order. Exterior packs shall have in addition the complete consignee's address. Markings shall be applied in a legible manner, in a contrasting color, of an appropriate size and of waterproof materials.

Notes. 1) Users should select the options permitted by this commercial item description and should specify the following in contract or purchase documents:

   a. Type of hose assembly required.
   b. Type of coupling material.

2) When this commercial item description is used for procurement, the commercial item certification clause must appear in the solicitation.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:21Z
Check the source to verify that this is the current version before use.

Underwriters Laboratories (UL) standards are available from Underwriters Laboratories, 333 Pfingsten Road, Northbrook, IL 60062.

MILITARY INTERESTS:

Review Activity
Army - ME

PREPARING ACTIVITY:

GSA-FSS

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:21Z
Check the source to verify that this is the current version before use.