INCH-POUND
MIL-DTL-24643/44F
1 October 2009
SUPERSEDING
MIL-DTL-24643/44E
22 August 2002

DETAIL SPECIFICATION SHEET

CABLE, ELECTRICAL, -20 °C TO +90 °C, 600 VOLTS, TYPE LS3SF

This specification is approved for use by all Departments and Agencies of the Department of Defense.

The requirements for acquiring the product described herein shall consist of this specification sheet and MIL-DTL-24643.

Construction, Non-Watertight

First	-	Copper conductor, coated or uncoated, 18 AWG, Class B stranding, ASTM B8, (7 by 0.0152 inches).
Second	-	Separator may be used at manufacturer's option where required to provide free-stripping insulation.
Third	-	Thermoset insulation. Nominal wall thickness 0.020 inch; wall thickness may vary from nominal as necessary in order for completed cable to meet the specified electrical requirements.
Fourth	-	Three conductors (one black, one white, and one red), shall be cabled together with a nominal lay or 1½ inches to form a triad.
Fifth	-	An optional binder.
Sixth	-	Braided shield of 34 or 36 AWG coated or uncoated copper. Braid angle of 30 to 35 degrees. Minimum coverage of 85 percent.
Seventh	-	Shield insulation of two polyester tapes, outer tape sealed. An alternate shield insulation may consist of one polyester tape plus an extruded jacket of a suitable transparent material, minimum average thickness of the transparent material 0.003 inch. The standard identification code shall be applied by Method 2.
Eighth	-	The specified number of triads (see table I) cabled around a central filler, with a lay in accordance with 3.4.4 of MIL-DTL-24643. Cabling sequence shall be consecutive. A single triad shall not be used as the central core of the cable. Fillers may be used as necessary to form a firm, well-rounded assembly.
Ninth	-	An optional binder.
Tenth	-	Cross-linked polyolefin jacket. Minimum average wall thickness of 0.080 inch.

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T00:12Z
Check the source to verify that this is the current version before use.

TABLE I. Details.

Military part no. M24643/44	Type and size	Number of triads	Overall diameter	
			min. (inch)	max. (inch)
-01UN	LS3SF-7	7	1.000	1.040

REQUIREMENTS:

Qualification required.

INSPECTION:

Basic Electricals:

Conductor resistance (ohms/1000 feet at 25 °C, max.)	7.06
Voltage withstand (volts, root mean square, min.)	
Conductor to conductor	2000
Conductor to shield	1000
Component shield to component shield	500
Insulation resistance (megohms/1000 feet, min.)	
Conductor to conductor	500
Conductor to shield	500
Component shield to component shield	100
Conductor continuity	No failure
Shield continuity	No failure

Group A:

Visual and dimensional	No failure
Capacitance	
Mutual capacitance, 1 kilohertz (KHz) (pF/ft, max.)	30
Capacitance unbalanced (percent max.)	10

Group B:

Thermoset proof test (percent, max.)	
Insulation	50
Jacket (when tested at 200 °C)	50
Cold bending cable at minus 30±2 °C	No failure
Bending endurance at 25±2 °C (cycles, min.)	25
Physicals (unaged)	
Insulation (extruded)	

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T00:12Z
Check the source to verify that this is the current version before use.

Tensile strength (lb/in^2, min.)	700
Elongation (percent, min.)	150
Jacket (cable)	
Tensile strength (lb/in^2, min.)	1300
Elongation (percent, min.)	160
Tear (lb/in thickness, min.)	35
Group C:	
Physicals (aged) air oven	
Insulation (extruded)	
Tensile strength (percent of unaged, min.)	75
Elongation (percent of unaged, min.)	75
Jacket (cable)	
Tensile strength (percent of unaged, min.)	60
Elongation (percent of unaged, min.)	60
Permanence of printing (jacket) (cycles, min.)	125
Heat distortion (percent of unaged, max.)	30
Shrinkage	No failure
Shield (conformance to material, construction and coverage)	No failure
Group D:	
Flame propagation (cable)	No failure
Qualification Inspection:	
Qualification inspection shall include basic electricals; groups A, B, C, and D; plus the following:	
Aging and compatibility (cable) (125±5 °C)	No failure
Abrasion resistance (jacket) (scrapes, min.)	75
Acid gas equivalent (percent, max.)	
Jacket	2
Fillers	2
Insulation	18
Shield insulation	2
Halogen content (percent, max.)	
Jacket	0.2
Fillers	0.2
Insulation	0.2

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T00:12Z
Check the source to verify that this is the current version before use.

Immersion (jacket)	
Tensile strength (percent of unaged, min.)	50
Elongation (percent of unaged, min.)	50
Smoke index (max.)	
Jacket	25
Fillers	45
Insulation	45
Toxicity index (max.)	
Jacket	5
Fillers	5
Insulation	1.5
Durometer (jacket) - Type A (hardness, min.)	80
Weathering (jacket)	No failure
Electrical moisture absorption	No failure

UNIT ORDERING LENGTHS:

Type and size	Feet (nominal)
LS3SF-7	1000

CHANGES FROM PREVIOUS ISSUE: Marginal notations are not used in this revision to identify changes with respect to the previous issue due to the extent of the changes.

Custodians:
Army – MI
Navy – SH

Preparing Activity:
Navy – SH
(Project 6145-2008-048)

Review Activities:
Army – AR, AV, CR
Navy – CG, EC
DLA – CC

NOTE: The activities listed above were interested in this document as of the date of this document. Since organizations and responsibilities can change, you should verify the currency of the information above using the ASSIST Online database at http://assist.daps.dla.mil.

Source: https://assist.dla.mil -- Downloaded: 2026-10-20T00:12Z
Check the source to verify that this is the current version before use.