MIL-M-23677A(SH)
20 July 1987
SUPERSEDING
MIL-M-23677(SHIPS)
16 September 1963
(See 6.7)

MILITARY SPECIFICATION

METER, AMPERE-HOUR (NONMERCURY TYPE)

This specification is approved for use within the Naval Sea Systems Command, Department of the Navy, and is available for use by all Departments and Agencies of the Department of Defense.

1. SCOPE

1.1 Scope. This specification covers ampere-hour meters used to record the energy that enters or leaves a submarine storage battery.

1.2 Classification. Ampere-hour meters shall be classified as follows:

Type I - Designed to operate from a 2500-ampere, 100-millivolt (mV) shunt.
Type II - Designed to operate from a 3000-ampere, 100-mV shunt.
Type III - Designed to operate from a 4000-ampere, 100-mV shunt.
Type IV - Designed to operate from a 5000-ampere, 100-mV shunt.

2. APPLICABLE DOCUMENTS

2.1 Government documents.

2.1.1 Specifications and standard. The following specifications and standard form a part of this specification to the extent specified herein. Unless otherwise specified, the issues of these documents shall be those listed in the issue of the Department of Defense Index of Specifications and Standards (DoDISS) and supplement thereto, cited in the solicitation.

Beneficial comments (recommendations, additions, deletions) and any pertinent data which may be of use in improving this document should be addressed to: Commander, Naval Sea Systems Command, SEA 55Z3, Department of the Navy, Washington, DC 20362-5101 by using the self-addressed Standardization Document Improvement Proposal (DD Form 1426) appearing at the end of this document or by letter.

AMSC N/A FSC 6625
DISTRIBUTION STATEMENT A Approved for public release; distribution unlimited

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T17:37Z
Check the source to verify that this is the current version before use.

SPECIFICATIONS

MILITARY

MIL-S-901 - Shock Tests, H.I. (High Impact); Shipboard Machinery, Equipment and Systems, Requirements for.
MIL-E-917 - Electric Power Equipment, Basic Requirements (Naval Shipboard Use).
DOD-D-1000 - Drawings, Engineering and Associated Lists.
MIL-E-2036 - Enclosures for Electric and Electronic Equipment, Naval Shipboard.
MIL-P-15024 - Plates, Tags and Bands for Identification of Equipment.
MIL-P-15024/5 - Plates, Identification.
MIL-M-15071 - Manuals, Technical: Equipment and Systems, Content Requirements for.
MIL-M-16034 - Meters, Electrical-Indicating (Switchboard and Portable Types).
MIL-E-16400 - Electronic Interior Communication and Navigation Equipment, Naval Ship and Shore: General Specification for.
MIL-E-17555 - Electronic and Electrical Equipment, Accessories, and Provisioned Items (Repair Parts): Packaging of.
MIL-T-55164 - Terminal Boards, Molded, Barrier Screw and Stud Types, and Associated Accessories, General Specification for.

STANDARD

MILITARY

MIL-STD-167-1 - Mechanical Vibrations of Shipboard Equipment, (Type I - Environmental and Type II - Internally Excited).

(Copies of specifications and standards required by contractors in connection with specific acquisition functions should be obtained from the contracting activity or as directed by the contracting activity.)

2.2 Other publications. The following document forms a part of this specification to the extent specified herein. Unless otherwise specified, the issues of the documents which are DoD adopted shall be those listed in the issue of the DoDISS specified in the solicitation. Unless otherwise specified, the issues of documents not listed in the DoDISS shall be the issue of the nongovernment documents which is current on the date of the solicitation.

UNIFORM CLASSIFICATION COMMITTEE AGENT

Uniform Freight Classification Ratings, Rules and Regulations

(Application for copies should be addressed to the Uniform Classification Committee Agent, Tariff Publication Officer, Room 1106, 222 South Riverside Plaza, Chicago, IL 60606.)

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T17:37Z
Check the source to verify that this is the current version before use.

(Nongovernment standards and other publications are normally available from the organizations which prepare or which distribute the documents. These documents also may be available in or through libraries or other informational services.)

2.3 Order of precedence. In the event of a conflict between the text of this specification and the references cited herein (except for associated detail specifications, specification sheets or MS standards), the text of this specification shall take precedence. Nothing in this specification, however, shall supersede applicable laws and regulations unless a specific exemption has been obtained.

3. REQUIREMENTS

3.1 First article. When specified in the contract or purchase order, a sample shall be subjected to first article inspection (see 4.4 and 6.3).

3.2 Materials. Materials used in the construction of the ampere-hour meters shall be as specified herein.

3.2.1 Prohibited materials.

3.2.1.1 Mercury. The use of the element mercury in any component parts of the meter and for any manufacturing process shall be prohibited.

3.2.1.2 Thermionic devices. The use of thermionic devices such as electron tubes is prohibited.

3.2.2 Recovered materials. Unless otherwise specified herein, all equipment, material, and articles incorporated in the products covered by this specification shall be new and may be fabricated using materials produced from recovered materials to the maximum extent practicable without jeopardizing the intended use. The term "recovered materials" means materials which have been collected or recovered from solid waste and reprocessed to become a source of raw materials, as opposed to virgin raw materials. None of the above shall be interpreted to mean that the use of used or rebuilt products is allowed under this specification unless otherwise specifically specified.

3.3 Design. The ampere-hour meter shall consist of two major components as follows:

(a) Integrating unit. An integrating unit consisting of electrical and electronic parts arranged to permit device performance as specified herein shall be provided. The parts shall be assembled and wired on a sub-panel not to exceed 10 inches in length and a cubic content not to exceed 640 cubic inches. The sub-panel shall be for mounting within a switchboard but shall be mounted within a bulkhead-mounted, dripproof enclosure as specified in 3.4.3.

(b) Indicator. A four-digit unidirectional electric cyclometer shall be used as the indicator. The counter shall be capable of being reset to zero. The figures on the counter shall be black on a white background and shall be not less than 3/16 inch high and

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T17:37Z
Check the source to verify that this is the current version before use.

1/8 inch wide. The counter shall be mounted on a panel suitable for flush mounting on a switchboard. The dimensions of this panel shall not exceed the cross section dimensions specified for 4-1/2-inch switchboard meters under MIL-M-16034. The indicator shall not exceed 4 inches in depth. The indicator shall be electrically isolated from the shunt input. The designation of the quantity measured (ampere hours) shall be marked on the front of the indicator or on an identification plate located below the cyclometer counter. The indicator shall be flush-mounted on the front of the bulkhead-mounted, dripproof enclosure.

3.3.1 Input power. Power required to operate the meter will be supplied from a 115-volt, 400-hertz (Hz), single-phase source.

3.3.2 Input resistance. Input resistance to the meter shall be not less than 1000 ohms.

3.3.3 Corrosion protection. Metal parts shall be protected against corrosion in accordance with MIL-E-917.

3.3.4 Interchangeability. In no case shall parts be physically interchangeable or reversible unless such parts are also interchangeable or reversible with regard to function, performance and strength.

3.4 Component parts.

3.4.1 Terminal boards. Terminal boards shall be in accordance with MIL-T-55164.

3.4.2 Identification plates. Identification plates in accordance with MIL-P-15024 and MIL-P-15024/5 shall be furnished for the indicator and the integrator. An identification plate shall be furnished covering the ampere-hour meter.

3.4.3 Enclosure. The enclosure shall be in accordance with MIL-E-2036, and shall be of dripproof construction.

3.4.3.1 Painting. Enclosures shall be painted in accordance with MIL-E-917, except that only one coat of grey enamel shall be applied. Touching up shall be permitted for marks or scratches due to assembly, testing or other factory handling.

3.4.4 Electronic parts. Electronic parts utilized in the meter shall conform to MIL-E-16400. Approval of nonstandard parts shall be required prior to submission of first article sample for test or if first article tests are waived, prior to production of ampere-hour meters under the contract.

3.5 Performance requirements.

3.5.1 Initial accuracy of registration. The meter shall not exceed the errors specified in 3.8 (see 4.6.1).

3.5.2 Temperature range. The meter shall not exceed the errors specified in 3.8 (see 4.6.2).

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T17:37Z
Check the source to verify that this is the current version before use.

3.5.3 Variation of frequency and voltage of 400 Hz power source. The meter shall not exceed the errors specified in 3.8 (see 4.6.3).

3.5.4 Inclination. The meter shall not exceed the errors specified in 3.8 when inclined to an angle of 60 degrees from the vertical in any direction.

3.5.5 Vibration. The meter shall not exceed the errors specified in 3.8 (see 4.6.5).

3.5.6 Shock (high impact). The permanent change in indication shall not exceed the values specified in 3.8 and no parts shall become unduly damaged (see 4.6.6).

3.6 Dielectric stress. Ampere-hour meters shall withstand a voltage of 2600 volts alternating current (Vac) without damage to components or flashover (see 4.6.7).

3.7 Insulation resistance. The insulation resistance shall be not less than 20 megohms (see 4.6.8).

3.8 Detail requirements. Detail requirements for types I, II, III, and IV nonmercury ampere-hour meters shall be as specified hereinafter:

(a) Total registration - 10,000 ampere hours.
(b) Dimensions of enclosure. - Not to exceed 10 inches high, 13 inches wide, and 12 inches deep.
(c) Operating current ranges:
Type I - 2 to 3000 amperes.
Type II - 2 to 3500 amperes.
Type III - 3 to 4700 amperes.
Type IV - 4 to 5800 amperes.
(d) Performance requirements shall be as specified in table I.

TABLE I. Performance requirements.

Meter	Current ranges - amperes 1/		
	Discharge current ranges		Charge or discharge current ranges
Type I	2 to 5	6 to 49	50 to 3000
Type II	2 to 5	6 to 49	50 to 3500
Type III	3 to 6	7 to 69	70 to 4700
Type IV	4 to 8	9 to 82	83 to 5800

See footnote at end of table.

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T17:37Z
Check the source to verify that this is the current version before use.

TABLE I. Performance requirements. - Continued

Meter	Current ranges - amperes 1/		
	Discharge current ranges		Charge or discharge current ranges
Initial accuracy	25.0 percent	6.0 percent	1 percent
Temperature range	25.0 percent	6.0 percent	1 percent
Variation of voltage and frequency of 400 Hz power supply	25.0 percent	6.0 percent	1 percent
Inclination	25.0 percent	3.0 percent	0.5 percent
Vibration	25.0 percent	3.0 percent	0.5 percent
Shock	25.0 percent	3.0 percent	0.5 percent
Maximum allowable total error first article sample	30.0 percent	10.0 percent	2.5 percent

1/ Accuracies are listed in percent of total registration (10,000 ampere hours).

3.9 Drawings. Drawings shall conform to DOD-D-1000. Deviation from the requirements of DOD-D-1000 will be permitted when approved by the command or agency concerned.

3.9.1 Approval of ampere-hour meter drawings shall be required prior to production of meters furnished under a contract.

3.9.1.1 Contents. Ampere-hour meter drawings shall contain the following minimum data:

(a) Outline (not necessarily to scale) giving dimensions and essential details of the ampere-hour meter enclosure. No gauge numbers or similar arbitrary designations of thickness, diameter and size shall be used. A note describing the cable entrance plate, gasketing, and gasket material, when furnished, shall be given. Drilling, mounting, and overall dimensions shall be complete, and shall not be obtained from the summation of partial dimensions.
(b) Outline (not necessarily to scale) of the ampere-hour meter equipment within the enclosure showing the outlines of the components and referencing the components to the piece numbers of the list of materials.
(c) Connection diagrams, as wired, shall be shown. Terminal location and markings shall be as shown on the equipment. The connection diagram shall be marked as to the view shown. The connection diagram shall be accompanied by a schematic or elementary diagram.
(d) A list of material to include the following information for each item:
    (1) Item number.
    (2) Description of item.
    (3) Manufacturer.

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T17:37Z
Check the source to verify that this is the current version before use.

(4) Manufacturer's drawing number or service part number.
(5) Contractor.
(6) Contractor drawing number or service part number.
(7) Applicable Military specification.

3.10 Manuals. Manuals shall conform to type II of MIL-M-15071.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the contractor is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract or purchase order, the contractor may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure supplies and services conform to prescribed requirements.

4.1.1 Responsibility for compliance. All items must meet all requirements of sections 3 and 5. The inspection set forth in this specification shall become a part of the contractor's overall inspection system or quality program. The absence of any inspection requirements in the specification shall not relieve the contractor of the responsibility of assuring that all products or supplies submitted to the Government for acceptance comply with all requirements of the contract. Sampling in quality conformance does not authorize submission of known defective material, either indicated or actual, nor does it commit the Government to acceptance of defective material.

4.2 Classification of inspections. The inspection requirements specified herein are classified as follows:

(a) First article inspection (see 4.4).
(b) Quality conformance inspection (see 4.5).

4.3 Test conditions and general instructions.

4.3.1 Atmospheric conditions. Unless otherwise specified herein, all tests shall be made at ambient temperatures of 23 to 27 degree Celsius (°C), at existing barometric pressure, and with relative humidity less than 80 percent.

4.3.2 Thermal stability. For all tests, care shall be taken to attain thermal stability at the specified temperature. Thermal stability will be considered attained when the temperature of the meter does not vary by more than 1°C per hour.

4.3.3 Registration checks. The charge or discharge current rates at which accuracy checks shall be made shall be as specified in table I. The length of time of a registration check at a specified rate of charge or discharge current shall be as follows:

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T17:37Z
Check the source to verify that this is the current version before use.

(a) For discharge currents from the minimum rate (2, 3, or 4 amperes as applicable) up to and including 49 amperes, the test procedure shall be determined by the manufacturer subject to approval by the command or agency concerned.
(b) For charge or discharge currents from 50 amperes to the maximum rate (3000, 3500, 4700 and 5800 amperes, as applicable), the registration check at each current rate shall be required to be conducted for a minimum time of 15 minutes.

4.4 First article inspection. First article samples shall be subjected to the examination and tests specified in table II, and any other tests considered necessary to determine conformance to this specification.

TABLE II. First article inspection.

Test	Requirement paragraph	Test paragraph
Visual and mechanical examination	3.3.1 through 3.4.4, 3.8(b)	-----
Initial registration accuracy	3.5.1	4.6.1
Temperature range 0 to 65°C	3.5.2	4.6.2
Variation of voltage and frequency of 400-Hz power source	3.5.3	4.6.3
Inclination	3.5.4	4.6.4
Vibration	3.5.5	4.6.5
Shock	3.5.6	4.6.6
Dielectric stress	3.6	4.6.7
Insulation resistance	3.7	4.6.8

4.4.1 Samples. One sample meter representative of the manufacturer's normal production or a custom made sample shall be submitted for first article inspection. When a manufacturer's design for a particular type is basically the same for all ratings, one unit may be submitted for approval of that design.

4.5 Quality conformance inspection. All production meters produced on a contract shall be subjected to the tests shown in table III in the order listed.

TABLE III. Quality conformance inspection.

Test	Requirement paragraph	Test paragraph
Visual and mechanical examination	3.3.1 through 3.4.4, 3.8	-----
Initial registration accuracy	3.5.1	4.6.1
Dielectric strength	3.6	4.6.7
Insulation resistance	3.7	4.6.8

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T17:37Z
Check the source to verify that this is the current version before use.

4.6 Test procedures.

4.6.1 Initial registration accuracy at 50°C. Initial accuracy tests shall be conducted with the meter in an ambient environment of 50°C. Initial accuracy shall be conducted at the following currents:

(a) Minimum (2, 3, or 4 amperes as applicable), 5, 10, and 50 amperes simulating battery discharge currents.
(b) 100, 200, 500, 1000, and maximum (3000, 3500, 4700, or 5800 as applicable) simulating battery charge and discharge currents.

4.6.1.1 The procedure for determining the initial registration accuracy at the minimum 5, 10, and 50-ampere rates shall be devised by the contractor subject to approval by the command or agency concerned. The tests at the other charge and discharge current rates noted above shall be conducted at each current for a minimum of 15 minutes.

4.6.2 Temperature range 0 to 65°C. Ampere-hour meter shall be maintained at temperatures of 0, 25, and 65°C, for a time sufficient to attain thermal stability at each temperature. Registration accuracy checks shall be made at each temperature at the following currents:

(a) Minimum (2, 3, or 4 amperes as applicable), 5, 10, and 50 ampere discharge currents. Test procedure identical to 4.6.1(a).
(b) 100, 200, 500, 1000, and maximum (3000, 3500, 4700, and 5800 amperes as applicable), charge and discharge current rates. Test procedures shall be identical to 4.6.1(b).

4.6.3 Variation of voltage and frequency of 400-Hz power source. Registration accuracy checks shall be made at successive currents (simulating battery discharge) of 10, 50, and 100 amperes under the following conditions of the 400-Hz power source:

Input voltage percent rated voltage	Input frequency percent rated frequency
110	105
110	95
90	105
90	95

Test should be conducted for at least 15 minutes at the 50- and 100-ampere rate. The test at the 5- and 15-ampere rates shall be conducted for the length of time required as determined by the initial accuracy test procedure (see 4.6.1(a)).

4.6.4 Inclination. Registration accuracy checks shall be made at currents of 10, 50, and 1000 amperes when the ampere-hour meter is mounted in each of the following inclined positions 60 degrees from the vertical:

Forward
Backward
Right
Left

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T17:37Z
Check the source to verify that this is the current version before use.

4.6.5 Vibration. Vibration tests shall be conducted in accordance with type I of MIL-STD-167-1. During the test the meter shall be energized and registering at the maximum discharge rate (3000, 3500, 4700, or 5800 amperes, as applicable). Following the vibration test, the meter shall be checked for registration accuracy at minimum discharge rate (2, 3, or 4 amperes, as applicable), 50 amperes and the maximum discharge rate (3000, 3500, 4700, or 5800 amperes, as applicable).

4.6.6 Shock (high impact). Shock tests shall be grade B, hull mounted, principal unit, class I, lightweight equipment, type A of MIL-S-901, utilizing the standard mounting shown on fixture 6E of MIL-S-901. Following the shock test a registration accuracy check shall be made at discharge currents of 10, 50, and charge and discharge currents of 100, 1000, and rated currents (2500, 3000, 4000, or 5000, as applicable).

4.6.7 Dielectric stress. Ampere-hour meters shall withstand a dielectric test voltage of twice rated voltage plus 1000 between the input terminals and the enclosure and the counter reset. The test voltage shall be nominal 60 Hz, and shall approximate as closely as possible a true sine wave in form. The test voltage shall be applied continuously for a period of 60 seconds. The test voltage shall be measured by the voltmeter method, whereby the measuring meter derives its voltage from the high-potential circuit either directly or by means of a voltmeter coil placed in the testing transformer, or by means of an auxiliary ratio transformer. To avoid voltage surges, the applied voltage shall be raised to its full value gradually and upon completion of the 60-second test period shall be gradually reduced. Any damage or flash-over shall be noted.

4.6.8 Insulation resistance. The insulation resistance of the meter shall be determined using a potential of 500 volts direct current (Vdc) applied between the input terminals and the enclosure.

4.7 Inspection of packaging. Sample packages and packs, and the inspection of the preservation-packaging, packing and marking for shipment and storage shall be in accordance with the requirements of section 5 and the documents specified therein.

5. PACKAGING

(The packaging requirements specified herein apply only for direct Government acquisition. For the extent of applicability of the packaging requirements of referenced documents listed in section 2, see 6.5.)

5.1 Domestic shipment and early equipment installation and for storage of on board repair parts.

5.1.1 Ampere-hour meter.

5.1.1.1 Preservation and packaging. Preservation and packaging shall afford adequate protection against corrosion, deterioration and physical damage during shipment from the supply source to the using activity and until early installation and may conform to the supplier's commercial practice when such meets these requirements.

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T17:37Z
Check the source to verify that this is the current version before use.

5.1.1.2 Packing. Packing shall be accomplished in a manner which will insure acceptance by common carrier at the lowest rate and will afford protection against physical or mechanical damage during direct shipment from the supply source to the using activity for early installation. The shipping containers or method of packing shall conform to the Uniform Freight Classification Ratings, Rules and Regulations or other carrier regulations as applicable to the mode of transportation and may conform to the supplier's commercial practice when such meets these requirements.

5.1.1.3 Marking. Shipment marking information shall be provided on interior packages and exterior shipping containers in accordance with the contractor's commercial practice. The information shall include nomenclature, Federal stock number or manufacturer's part number, contract or order number, contractor's name and destination.

5.1.2 On board repair parts. The on board repair parts shall be preserved and packaged level A, packed level C, and marked in accordance with MIL-E-17555.

5.2 Domestic shipment and storage or overseas shipment. The requirements and levels of preservation and packaging, packing, and marking for shipment shall be as specified by the contracting activity (see 6.2).

5.2.1 Preservation and packaging, packing, and marking. The equipment and accessories, repair parts, and technical publications shall be preserved and packaged level A, packed level A or B as specified, and marked in accordance with MIL-E-17555.

6. NOTES

6.1 Intended use. The meters covered by this specification are intended for use in measuring submarine storage battery energy.

6.2 Ordering data. Acquisition documents should specify the following:

(a) Title, number, and date of this specification.
(b) Type required (see 1.2).
(c) When first article inspection is required (see 3.1).
(d) Preservation and packaging, packing and marking instructions if other than as specified in 5.1 (see 5.2).

6.3 First article. When a first article inspection is required, the items should be a first article sample. The first article should consist of one unit. The contracting officer should include specific instructions in acquisition documents regarding arrangements for examinations, approval of first article test results and disposition of first articles. Invitations for bids should provide that the Government reserves the right to waive the requirement for samples for first article inspection to those bidders offering a product which has been previously acquired or tested by the Government, and that bidders offering such products, who wish to rely on such production or test, must furnish evidence with the bid that prior Government approval is presently appropriate for the pending contract.

6.4 Provisioning. Provisioning Technical Documentation (PTD), spare parts, and repair parts should be furnished as specified in the contract.

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T17:37Z
Check the source to verify that this is the current version before use.

6.4.1 When ordering spare parts or repair parts for the equipment covered by this specification, the contract should state that such spare parts and repair parts should meet the same requirements and quality assurance provisions as the parts used in the manufacture of the equipment. Packaging for such parts should also be specified.

6.5 Sub-contracted material and parts. The packaging requirements of referenced documents listed in section 2 do not apply when material and parts are acquired by the contractor for incorporation into the equipment and lose their separate identity when the equipment is shipped.

6.6 Subject term (key word) listing.

Ampere-hour
Battery
Meter

6.7 Changes from previous issue. Asterisks are not used in this revision to identify changes with respect to the previous issue due to the extensiveness of the changes.

Preparing activity:
Navy - SH
(Project 6625-N901)

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T17:37Z
Check the source to verify that this is the current version before use.

INSTRUCTIONS: In a continuing effort to make our standardization documents better, the DoD provides this form for use in submitting comments and suggestions for improvements. All users of military standardization documents are invited to provide suggestions. This form may be detached, folded along the lines indicated, taped along the loose edge *(DO NOT STAPLE)*, and mailed. In block 5, be as specific as possible about particular problem areas such as wording which required interpretation, was too rigid, restrictive, loose, ambiguous, or was incompatible, and give proposed wording changes which would alleviate the problems. Enter in block 6 any remarks not related to a specific paragraph of the document. If block 7 is filled out, an acknowledgement will be mailed to you within 30 days to let you know that your comments were received and are being considered.

NOTE This form may not be used to request copies of documents, nor to request waivers, deviations, or clarification of specification requirements on current contracts. Comments submitted on this form do not constitute or imply authorization to waive any portion of the referenced document*(s)* or to amend contractual requirements.

(Fold along this line)

(Fold along this line)

DEPARTMENT OF THE NAVY

COMMANDER
NAVAL SEA SYSTEMS COMMAND (SEA 55Z3)
DEPARTMENT OF THE NAVY
WASHINGTON, DC 20362-5101

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE $300

BUSINESS REPLY MAIL
FIRST CLASS PERMIT NO 12503 WASHINGTON D C
POSTAGE WILL BE PAID BY THE DEPARTMENT OF THE NAVY

NO POSTAGE NECESSARY IF MAILED IN THE UNITED STATES

COMMANDER
NAVAL SEA SYSTEMS COMMAND (SEA 55Z3)
DEPARTMENT OF THE NAVY
WASHINGTON, DC 20362-5101

Source: https://assist.dla.mil -- Downloaded: 2026-10-19T17:37Z
Check the source to verify that this is the current version before use.

STANDARDIZATION DOCUMENT IMPROVEMENT PROPOSAL

(See Instructions – Reverse Side)

1. DOCUMENT NUMBER	2 DOCUMENT TITLE
MIL-M-23677A(SH)	METER, AMPERE-HOUR (NONMERCURY TYPE)

3a. NAME OF SUBMITTING ORGANIZATION	4 TYPE OF ORGANIZATION *(Mark one)*
	☐ VENDOR
b ADDRESS *(Street, City, State, ZIP Code)*	☐ USER
	☐ MANUFACTURER
	☐ OTHER *(Specify)* _____

5 PROBLEM AREAS

a. Paragraph Number and Wording

b Recommended Wording

c Reason/Rationale for Recommendation

6 REMARKS

7a NAME OF SUBMITTER *(Last, First, MI)* – Optional	b WORK TELEPHONE NUMBER *(Include Area Code)* – Optional
c MAILING ADDRESS *(Street, City, State, ZIP Code)* – Optional	8 DATE OF SUBMISSION *(YYMMDD)*

(TO DETACH THIS FORM, CUT ALONG THIS LINE.)

DD FORM 82 MAR 1426 PREVIOUS EDITION IS OBSOLETE.

Source: https://assist.dla.mil - Downloaded: 2025-10-19T17:37Z
Check the source to verify that this is the current version before use.