MILITARY SPECIFICATION SHEET

ARRESTER, ELECTRICAL SURGE, F-1483( )/G and F-1495( )/G

This amendment forms a part of Military Specification Sheet MIL-A-49201 (CR), dated 25 January 1980 and is approved for use by USA Communications Research and Development Command, Department of the Army and is available for use by all Departments and Agencies of the Department of Defense.

PAGE 3

PARA 3.3.1.1.1: Delete the second sentence. Add: "A fast rising pulse is defined for the purposes of this specification as one which rises from 10 percent to 90 percent of peak value in less than 20 nanoseconds and comes from a source resistance of 10 ohms or less. (See 4.6.1.1.)".

PAGE 4

PARA 3.3.1.4: Seventh line; Replace "Fall time, 100% to 5%", with "Fall time 100% to 50%".

PAGE 8

FIGURE 1: Item #5. Loading Resistor; Replace "10-12 ohms", with 20-25 ohms".

PAGE 10

PARA 4.43: Replace with the following;

4.4.3 Sampling. -

4.4.3.1 Group B. - Sampling for group B tests shall be IAW MIL-STD-105 inspection level S-4.

4.4.3.2 Group C. -

4.4.3.2.1 Subgroup 1. - Two units shall be selected from each hundred units or fraction thereof produced and submitted to these tests.

4.4.3.2.2 Subgroups 2, 3, & 4. The two units selected for the first production subgroup 1 tests will be used in tests of these subgroups. One unit of Subgroup 1 will be submitted to subgroup 2 & 3 tests. The second unit will be submitted to subgroup 4 tests. For each additional 1000 units or fraction thereof produced, two samples will be selected from those that have passed subgroup 1 tests. One of these units will be submitted to subgroup 2 & 3 tests and the other subgroup 4 tests.

PAGE 11

TABLE III: Group C inspect, Replace "Group C", with "Group B". Replace "Subgroup 1" with Group C Subgroup 1".

FSC 5920

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T19:55Z
Check the source to verify that this is the current version before use.

FIGURE 3: Item 5. Loading Resistor, Replace "3 ohm max" with "5-6 ohm".

CUSTODIAN
ARMY - CR

PREPARING ACTIVITY
ARMY-CR
PROJECT NO: 5920-N-164
FSC 5920

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T19:55Z
Check the source to verify that this is the current version before use.