FF-H-121D
July 15, 1974
SUPERSEDING
Fed. Spec. FF-H-121c
June 18, 1954

FEDERAL SPECIFICATION

HARDWARE, BUILDERS'; DOOR CLOSERS

This specification was approved by the Commissioner, Federal Supply Service, General Services Administration, for use of all Federal Agencies.

1. SCOPE AND CLASSIFICATION

1.1 Scope. This specification covers mechanical devices for automatically closing and controlling hinged or pivoted doors by means of a suitable combination of metal springs and liquid or air controlled checks.

1.2 Classification.

1.2.1 Types, grades, and sizes. Door closers and accessory items, and supplementary pivots and thresholds, shall be of the types, grades, and sizes described in American National Standards Institute (ANSI) A156.4, as specified (see 6.2). When required (see 6.2), optional features (o.f.) for door closers shall be specified as described in ANSI A156.4. Door closers shall be furnished in the sizes for use in accordance with the door widths set forth in Table I.

TABLE I. Closer sizes

ANSI A156.4 Type	Closer size	Maximum door width (Interior)	Maximum door width (Exterior)
Surface closers, Traditional 1/	II	2'8"	3'0" light screen or combination storm doors.
Surface closers, Modern with cover	III	3'2"	2'6"
	IV	4'0"	3'0"
Surface closers, Modern no cover	V	Extra large and subject to strong drafts.	3'6"
	VI	N/A	Extra heavy or of unusual height and width.

FSC 5340

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:45Z
Check the source to verify that this is the current version before use.

TABLE I. Closer sizes (con.)

Concealed-in-door closers	II	2'6"	N/A
	III	3'0"	N/A
	IV	3'6"	N/A
Overhead concealed closers. 2/	II	3'0"	2'6"
	III	3'3"	2'10"
	IV	3'8"	3'6"
C06012, C06013, C06021, C06022, C06023, C06031, C06032, C06033 C06041, C06042, C06043, C06051 C06052, C06053 3/	II	3'0"	2'6"
	III	3'6"	2'10"
	IV	4'0"	3'6"
C06061, C06062, C06071, C06072	IV	For lead lined doors or extra heavy doors weighing up to 1000 pounds.	
C09533, C09543, C09343, C09353, C09363	One size only. For light screen doors not over 3'0".		

The schedule of sizes is based on standard closer installations for doors subject to normal operating conditions. Where strong drafts or excessive air pressure variations are encountered, the next larger size should be applied. The use of corner brackets, parallel arms, and top jamb mounting applications may also require the use of a larger size. The manufacturer's recommendations for applicable installations and the handling of unusual conditions should be followed. Within the minimum closing force required by ANSI A156.4, individual manufacturers may vary closing force adjustments which will make one manufacturer's size range different from another's.

1/ Some traditional door closers available in size II, III and IV only. ANSI A156.4 should be checked for specific types.

2/ Some manufacturers provide these type door closers in larger sizes than those listed.

3/ Grade 2 for interior and exterior doors;, Grade 3 for interior doors only.

2. APPLICABLE DOCUMENTS

2.1 The following documents, of the issue in effect on date of invitation for bids or request for proposal, form a part of the specification to the extent specified herein.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:45Z
Check the source to verify that this is the current version before use.

Federal Specification:

PPP-H-1581 - Hardware (Fasteners and Related Items), Packaging and Packing for Shipment and Storage of.

Federal Standard:

Fed. Std. No. 123 - Marking for Domestic Shipment (Civil Agencies).

(Activities outside the Federal Government may obtain copies of Federal Specifications, Standards, and Handbooks as outlined under General Information in the Index of Federal Specifications and Standards, at the prices indicated in the Index. The Index, which includes cumulative monthly supplements as issued, is for sale on a subscription basis by the Superintendent of Documents, U.S. Government Printing Office, Washington, DC 20402.

(Single copies of this specification and other Federal specifications required by activities outside the Federal Government for bidding purposes, are available, without charge, from Business Service Centers at the General Services Administration Regional Offices in Boston, New York, Washington, DC, Atlanta, Chicago, Kansas City, MO, Fort Worth, Denver, San Francisco, Los Angeles, and Seattle, WA.

(Federal Government activities may obtain copies of Federal Specifications, Standards, and Handbooks, and the Index of Federal Specifications and Standards from established distribution points in their agencies.)

Military Standards:

MIL-STD-105 - Sampling Procedures and Tables for Inspection by Attributes.
MIL-STD-129 - Marking for Shipment and Storage.

(Copies of Military Specifications and Standards, required by suppliers in connection with specific procurement functions, should be obtained from the procuring activity or as directed by the contracting officer.)

2.2 Other publications. The following documents form a part of this specification to the extent specified herein. Unless a specific issue is identified, the issue in effect on date of invitation for bids or request for proposal shall apply.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:45Z
Check the source to verify that this is the current version before use.

American National Standards Institute (ANSI):

A156.4 - Door Controls - Closers.

(Application for copies should be addressed to the American National Standards Institute, 1430 Broadway, New York, NY 10018.)

Builders' Hardware Manufacturer's Association (BHMA):

1301 - Materials and Finishes Standard.

(Application for copies should be addressed to the Builders' Hardware Manufacturer's Association, 60 East 42nd Street, New York, NY 10017.)

National Motor Freight Traffic Association, Inc. Agent:

National Motor Freight Classification.

(Application for copies should be addressed to the American Trucking Associations, Inc., Tariff Order Section, 1616 P Street, N.W., Washington, DC 20036.)

Uniform Classification Committee, Agent:

Uniform Freight Classification.

(Application for copies should be addressed to the Uniform Classification Committee, Room 1106, 222 South Riverside Plaza, Chicago, IL 60606.)

(Technical society and technical association specifications and standards are generally available for reference from libraries. They are also distributed among technical groups and using Federal agencies.)

3. REQUIREMENTS

3.1 Standards compliance. Except as otherwise specified herein, door closers and accessory items, and supplementary pivots and thresholds shall conform to the requirements specified in ANSI A156.4.

3.2 Standard commercial product. The door closers and accessory items, and supplementary pivots and thresholds shall as a minimum be in accordance with the requirements of this specification and shall be the manufacturer's standard commercial product. Additional or better features which are not specifically prohibited by this specification but which are a part of the manufacturer's standard commercial product shall be in-

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:45Z
Check the source to verify that this is the current version before use.

cluded in the hardware being furnished. Standard commercial product is a product which has been or will be sold on the commercial market through advertisements or manufacturer's catalogs or brochures, and represents the latest production model(s).

3.3 First article. When specified (see 6.2), the contractor shall furnish a door closer and accessory items, and supplementary pivot and threshold of each type ordered for first article inspection and approval (see 4.2.1 and 6.3).

3.4 Installation and regulating instructions. Each door closer shall be furnished with clear, detailed instructions for installation and regulation of the closer, as well as all the necessary templates (see 6.5), and instructions for their use.

3.5 Fastenings. Hardware furnished under this specification shall be complete with all screws, bolts, or other fastenings necessary for proper application. Such fastenings shall be of suitable size and type, and shall harmonize with the hardware as to material and finish. When specified (see 6.2), through bolts, for fastening closers to doors, shall be furnished.

3.6 Finishes. Exposed surfaces of hardware shall have one of the applicable standard finishes, as specified (see 6.2 and 6.6). As far as practicable, finishes, as defined in BHMA 1301, should be confined to aluminum lacquer (BHMA 689) or bronze lacquer (BHMA 691) for exposed surfaces of closers. Finishes for pivots should be confined to satin bronze, clear coated (BHMA 612) or satin chromium plated (BHMA 626).

3.7 Special tools. Special tools required for adjustment, such as a spanner or a socket wrench, shall be furnished.

3.8 Identification marking. The manufacturer's name or trademark, or other marking by which the source of manufacture can be readily identified, shall be clearly and permanently marked on the body, or on a nameplate securely attached to the body of the closer. In addition, the manufacturer's size designation shall be permanently marked or cast in the case, cover, arm, or cap for overhead surface-mounted closers, and for concealed closers, so as to be visible after installation, upon removal of cover or finish plates. Each checking floor hinge shall also have the size designation cast or stamped in the outer case (cement case) so as to be visible after the outer case is built into the floor.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:45Z
Check the source to verify that this is the current version before use.

3.9 Workmanship. The quality of workmanship shall be such as to produce door closers and accessories, and supplementary pivots and thresholds that are in accordance with the requirements of this specification, and are so constructed as to insure proper functioning of all parts of the unit. All hardware shall be free from imperfections and defects which affect its appearance, or which may impair its durability and serviceability. All finished parts of hardware that are to be set flush shall have smooth, true edges and corners.

4. QUALITY ASSURANCE PROVISIONS

4.1 Responsibility for inspection. Unless otherwise specified in the contract or purchase order, the supplier is responsible for the performance of all inspection requirements as specified herein. Except as otherwise specified in the contract or order, the supplier may use his own or any other facilities suitable for the performance of the inspection requirements specified herein, unless disapproved by the Government. The Government reserves the right to perform any of the inspections set forth in the specification where such inspections are deemed necessary to assure that supplies and services conform to prescribed requirements.

4.1.1 Inspection of materials and components. In accordance with 4.1, the supplier is responsible for insuring that materials and components used were manufactured, examined, and tested to the extent specified, in accordance with the requirements of referenced subsidiary specifications and standards.

4.2 Classification of inspections. The inspection requirements specified herein are classified as follows:

a. First article inspection (see 4.2.1).
b. Quality conformance inspection (see 4.2.2).

4.2.1 First article inspection. First article inspection shall be performed on one of each type door closer and accessory items, and supplementary pivots and thresholds when a first article sample is required (see 3.3). This inspection shall include the examination of 4.5 and the tests of 4.6.1. Failure of the first article to pass the examination or any of the tests shall be cause for rejection. The first article may be a standard production item from the supplier's current inventory, provided the unit meets the requirements of this specification and is representative of the design, construction, and manufacturing technique applicable to the remaining units to be furnished under the contract.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:45Z
Check the source to verify that this is the current version before use.

4.2.2 Quality conformance inspection. Quality conformance inspection shall be performed on the sample door closers and accessory items, and supplementary pivots and thresholds selected in accordance with 4.4. This inspection shall include the examination of 4.5 and the tests of 4.6.2.

4.3 Inspection lot. All units of the same type, grade, and size, offered to the Government at one time, shall be considered a lot for purposes of inspection. The sample unit shall be one complete door closer.

4.4 Sampling.

4.4.1 Sampling for visual examination. A random sample of door closers and accessory items, and supplementary pivots and thresholds shall be selected from each lot offered to the Government in accordance with MIL-STD-105 at inspection level II. The acceptable quality level shall be 1.5 percent defective for major defects and 4.0 percent defective for minor defects.

4.4.2 Sampling for tests. A random sample of door closers and accessory items, and supplementary pivots and thresholds, shall be selected from each lot offered to the Government in accordance with MIL-STD-105 at inspection level S-1. The acceptable quality level shall be 2.5 percent defective.

4.5 Examination. Each door closer and accessory items, and supplementary pivots and thresholds selected in accordance with 4.4.1, shall be examined to verify compliance with this specification. Examination shall be conducted as specified in Table II.

TABLE II. Classification of defects

Categories	Defects
Major:	
101	Type of hardware not as specified
102	Missing or unsatisfactory installation and regulating instructions
103	Failure to supply necessary adjustment tools
104	Incomplete or improper marking
Minor:	
201	Finish not uniform
202	Edges and corners not smooth and true
203	Polished finish not uniform or is scratched

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:45Z
Check the source to verify that this is the current version before use.

4.6 Tests.

4.6.1 First article. First article door closer shall be tested in accordance with ANSI A156.4. A certificate of compliance accompanied by certified copies of reports of tests either conducted in the manufacturer's plant and certified by an independent testing laboratory or conducted in an independent laboratory, will be accepted as evidence that the hardware has passed the required tests. When door closers have been previously tested, the test requirements for the first article may be met by submittal of the certified test data from previous first article tests, in accordance with this specification, provided the design, construction, and manufacturing techniques have not been changed, and the supplier provides a certified statement to that effect.

4.6.2 Quality conformance. Each door closer selected in accordance with 4.4.2 shall be subjected to the performance test PT11 specified in ANSI A156.4, except that the cycle test designated as PT11-6 shall not be required.

4.7 Performance tests for finishes. Finishes shall conform to the performance requirements as specified in ANSI A156.4.

4.8 Inspection of preparation for delivery. Preparation for delivery requirements of the door closers shall be inspected to determine conformance with the applicable requirements of section 5 of this specification.

5. PREPARATION FOR DELIVERY

5.1 Preservation and packaging. Preservation and packaging shall be level A or C, as specified (see 6.2).

5.1.1 Level A. The door closers and accessories, and supplementary pivots and thresholds shall be preserved and packaged in accordance with the applicable level A requirements of PPP-H-1581.

5.1.2 Level C. The door closers and accessories, and supplementary pivots and thresholds shall be preserved and packaged in accordance with the supplier's standard practice.

5.2 Packing. Packing shall be level A, B, or C as specified (see 6.2).

5.2.1 Level A. The door closers and accessories, and supplementary pivots and thresholds shall be packed in accordance with the applicable level A requirements of PPP-H-1581.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:45Z
Check the source to verify that this is the current version before use.

5.2.2 Level B. The door closers and accessories, and supplementary pivots and thresholds shall be packed in accordance with the applicable level B requirements of PPP-H-1581.

5.2.3 Level C. The door closers and accessories, and supplementary pivots and thresholds shall be packed in a manner which will insure arrival at destination in satisfactory condition and be acceptable to the carrier at lowest rates. Containers and packing shall comply with Uniform Freight Classification rules or National Motor Freight Classification rules.

5.3 Marking (see 6.2).

5.3.1 Civil agencies. In addition to any special marking required by the contract or order, the interior packages and external shipping containers shall be marked in accordance with Fed. Std. No. 123.

5.3.2 Military activities. In addition to any special marking required by the contract or order, the interior packages and external shipping containers shall be marked in accordance with MIL-STD-129.

6. NOTES

6.1 Intended use. Hardware covered by this specification is intended to check the swing of opening doors and to return these doors to the closed position with a safely controlled swing.

6.2 Ordering data. Purchasers should select the preferred options offered herein and include the following data in procurement documents:

6.2.1 Procurement requirements.

(a) Title, number, and date of this specification.
(b) Type, grade, and size of hardware desired, and when required, the o.f. for door closers (see 1.2). NOTE: When material requirements or needs differ from the materials designated by the established ANSI type numbers, select and specify the type material desired or the optional material allowed (see ANSI A156.4 numbering system and manufacturer's literature for general types of materials used).
(c) When a first article is required for inspection and approval (see 3.3).
(d) When through bolts are required (see 3.5).
(e) Type of finish required (see 3.6).
(f) Level of preservation and packaging and level of packing required (see 5.1 and 5.2).
(g) Marking required (see 5.3).

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:45Z
Check the source to verify that this is the current version before use.

6.2.2 Contract data requirements. When this specification is used in a procurement which incorporates a DD Form 1423 and invokes the provisions of paragraph 7-104.9(n) of the Armed Services Procurement Regulation, the data requirements identified below will be developed as specified by an approved Data Item Description (DD Form 1664) and delivered in accordance with the Contract Data Requirements List (DD Form 1423) incorporated into the contract. When the provisions of ASPR 7-104.9(n) are not invoked, the data specified below shall be delivered in accordance with the contract requirements. Deliverable data required by this specification is cited in the following paragraphs.

Paragraph	Data Requirement	Applicable DD 1664
4.6.1	Certificate of Compliance	DI-E-2121

(Copies of Data Item Descriptions required by contractors in connection with specific procurement functions should be obtained from the procuring activity or as directed by the contracting officer.)

6.3 First article. When a first article is required, it shall be tested and approved under the appropriate provisions of paragraph 7-104.55 of the Armed Services Procurement Regulation. The first article may be a standard production item from the manufacturer's current inventory. The first article should consist of one unit. The contracting officer should include specific instructions in all procurement instruments, regarding arrangements for examinations, test and approval of the first article.

6.4 Classification cross reference. Classification cross-reference, as pertains to door closers, is furnished for information purposes only. When ordering hardware covered by this specification, the procuring agency should use the type, grade, size, and optional feature (o.f.) classification available in ANSI A156.4. Type numbers listed in table III are only those equal to items previously listed in FF-H-121c, dated June 18, 1954. Many other types are available in ANSI A156.4 depending on individual needs and applications.

TABLE III. Classification cross-reference

Classification FF-H-121c		Corresponding ANSI A156.4 designation	
Type	Description	Type 1/	Description
3001	Door closer, overhead surface mounted; closing force range adjustable 50% over minimum spring load.	C01012 w/o.f. PT-4C	Surface closer, traditional type; hinge side mounting; with o.f., closing force range adjustable 50% over minimum spring load.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:45Z
Check the source to verify that this is the current version before use.

TABLE III. Classification cross-reference (con.)

3001H	Door closer, overhead surface mounted; hold-open arm; closing force range adjustable 50% over minimum spring load.	C01052 w/o.f. PT-4C	Surface closer, traditional type; holder arm; hinge side mounting; with o.f., closing force range adjustable 50% over minimum spring load.
3001HH	Door closer, overhead surface mounted; hospital hold-open arm; closing force range adjustable 50% over minimum spring load.	C01132 w/o.f. PT-4C	Surface closer, traditional type; hospital arm with two-point hold-open function; hinge side mounting; with o.f., closing force range adjustable 50% over minimum spring load.
3001F	Door closer, overhead surface mounted; fusible link hold-open arm; closing force range adjustable 50% over minimum spring load.	C01092 w/o.f. PT-4C	Surface closer, traditional type; fusible link holder arm; hinge side mounting; with o.f., closing force range adjustable 50% over minimum spring load.
3001P	Door closer, overhead surface mounted; parallel arm mounting; closing force range adjustable 50% over minimum spring load.	C01022 w/o.f. PT-4C	Surface closer, traditional type; parallel arm mounting; with o.f., closing force range adjustable 50% over minimum spring load.
3004	Door closer, overhead surface mounted; closing force range adjustable 50% over minimum spring load.	C01013 w/o.f. PT-4C	Surface closer, traditional type; hinge side mounting; with o.f., closing force range adjustable 50% over minimum spring load.
3004H	Door closer, overhead surface mounted; hold-open arm; closing force range adjustable 50% over minimum spring load.	C01053 w/o.f. PT-4C	Surface closer, traditional type; holder arm; hinge side mounting; with o.f., closing force range adjustable 50% over minimum spring load.
3004HH	Door closer, overhead surface mounted; hospital hold-open arm; closing force range adjustable 50% over minimum spring load.	C01033 w/o.f. PT-4C	Surface closer, traditional type; hospital arm with two-point hold-open function; with o.f., closing force range adjustable 50% over minimum spring load.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:45Z
Check the source to verify that this is the current version before use.

TABLE III. Classification cross-reference (con.)

3004F	Door closer, overhead surface mounted; fusible link hold-open arm; closing force range adjustable 50% over minimum spring load.	C01093 w/o.f. PT-4C	Surface closer, traditional type; fusible link holder arm; with o.f., closing force range adjustable 50% over minimum spring load.
3004P	Door closer, overhead surface mounted; parallel arm mounting; closing force range adjustable 50% over minimum spring load.	C01023 w/o.f. PT-4C	Surface closer, traditional type; parallel arm mounting; with o.f., closing force range adjustable 50% over minimum spring load.
3009	Door closer, overhead surface mounted; closing force range adjustable 15% over minimum spring load.	C01011 w/o.f. PT-4A or C03011 w/o.f. PT-4A	Surface closer, traditional type; hinge side mounting; with o.f., closing force range adjustable 15% over minimum spring load. Surface closer, modern type, no cover; hinge side mounting; with o.f., closing force range adjustable 15% over minimum spring load.
3009H	Door closer, overhead surface mounted; hold-open arm; closing force range adjustable 15% over minimum spring load.	C01051 w/o.f. PT-4A or C03051 w/o.f. PT-4A	Surface closer, traditional type; holder arm; hinge side mounting; with o.f., closing force range adjustable 15% over minimum spring load. Surface closer, modern type, no cover; holder arm; hinge side mounting; with o.f., closing force range adjustable 15% over minimum spring load.
3009HH	Door closer, overhead surface mounted; hospital hold-open arm; closing force range adjustable 15% over minimum spring load.	C01141 w/o.f. PT-4A	Surface closer, traditional type; hospital arm with two-point hold-open function; bracket mounting; with o.f., closing force range adjustable 15% over minimum spring load.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:45Z
Check the source to verify that this is the current version before use.

TABLE III. Classification cross-reference (con.)

3009F	Door closer, overhead surface mounted; fusible link hold-open arm; closing force range adjustable 15% over minimum spring load.	C01091 w/o.f. PT-4A or C03091 w/o.f. PT-4A	Surface closer, traditional type; fusible link holder arm; hinge side mounted; with o.f., closing force range adjustable 15% over minimum spring load. Surface closer, modern type, no cover; fusible link holder-arm; hinge side mounting; with o.f., closing force range adjustable 15% over minimum spring load.
3009P	Door closer, overhead surface mounted; parallel arm mounting; closing force range adjustable 15% over minimum spring load.	C01021 w/o.f. PT-4A or C03021 w/o.f. PT-4A	Surface closer, traditional type; parallel arm mounting; with o.f., closing force range adjustable 15% over minimum spring load. Surface closer, modern type, no cover; parallel arm mounting; with o.f., closing force range adjustable 15% over minimum spring load.
3010	Door closer for light screen doors.	C09533	Door closer for light screen door; traditional type.
3015	Door closer for light screen doors.	C09353	Door closer for light screen door; tubular type.
3200	Double-acting overhead concealed door closer.	C05063	Overhead concealed closer; double-acting; center pivoted.
3205	Double-acting overhead concealed door closer; adjustable backcheck.	C05062 w/o.f. PT-8F	Overhead concealed closer; concealed arm and track; single-acting; pivot hung; with o.f., adjustable hydraulic backcheck.
3210	Single-acting overhead concealed door closer.	C05033	Overhead concealed closer; concealed arm and track; single-acting; pivot hung.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:45Z
Check the source to verify that this is the current version before use.

TABLE III. Classification cross-reference (con.)

3215	Single-acting overhead concealed door closer.	C05053	Overhead concealed closer; concealed arm; single-acting; center pivoted.
3220	Single-acting overhead concealed door closer.	C05043	Overhead concealed closer; concealed arm; single-acting; pivot hung.
3225	Single-acting overhead concealed door closer, style E [2/], butt hung.	C05013	Overhead concealed closer; exposed arm; surface shoe; single-acting; butt hinge hung.
3225	Single-acting overhead concealed door closer, style E [2/], pivot hung.	C05023	Overhead concealed closer; exposed arm; surface shoe; single-acting; pivot hung.
3230	Single-acting overhead concealed door closer, style G [3/].	C04023	Concealed-in-door closer; double lever arm; mortised soffit plate; for interior doors only.
3230	Single-acting overhead concealed door closer, Modified [4/].	C02012	Surface closer; modern type with cover; hinge side mounting.
3500	Double-acting checking floor hinge.	C06013	Double-acting closer; center pivoted.
3510	Double-acting checking floor hinge.	C06012	Double-acting closer; center pivoted.
3520	Single-acting checking floor hinge.	C06022	Single-acting closer; center pivoted.
3520A	Single-acting checking floor hinge.	C06042	Single-acting closer; offset pivoted.
3520B	Single-acting checking floor hinge; asylum type top pivot.	C06042	Single-acting closer; offset pivoted; asylum type top pivot.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:45Z
Check the source to verify that this is the current version before use.

TABLE III. Classification cross-reference (con.)

3520C	Single-acting checking floor hinge.	C06072	Single-acting closer; offset pivoted.
3522	Single-acting floor mounted door closer.	C06032	Single-acting closer; butt hung or offset pivoted.
3525	Intermediate or supplementary offset pivot.	C07321	Offset intermediate pivot.
3525A	Intermediate or supplementary offset pivot, asylum type.	C07361	Offset intermediate pivot with asylum type knuckle.
3525B	Intermediate or supplementary pivot for lead-lined doors.	C07311	Offset intermediate pivot for lead-lined or extremely heavy doors.
3530	Floor pivot, center hung.	C07021	Center pivot set.
3530A	Floor pivot, single-acting, offset type.	C07121	Offset pivot set.
3530B	Floor pivot, single-acting, offset type for lead-lined doors.	C07111	Offset pivot set for lead-lined doors.
3560A	Threshold	C18011 or C38011	Threshold Threshold
3560B	Threshold	C18031 or C38031	Threshold Threshold
3560CS	Threshold	C18051 or C38051	Threshold Threshold
3560D	Threshold	C18071 or C38071	Threshold Threshold
3560DS	Threshold	C18091 or C38091	Threshold Threshold

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:45Z
Check the source to verify that this is the current version before use.

1/ The designation for o.f., e.g. w/o.f. PT-4C, does not relieve the manufacturer from meeting any other performance tests specified in ANSI A156.4.

2/ Style E. Mechanism mortised in overhead frame. Centerline of spindle located beyond face of door. All parts fully concealed when door is closed, except arms and cover plate.

3/ Style G. Mechanism mortised in top rail or hinge stile of door. All parts fully concealed when door is closed, except arms may be exposed.

4/ Modified. Mechanism surface mounted on door and furnished with a cover plate. Available with regular, parallel, hold-open, hospital hold-open, and fusible link arm application.

6.5 Templates. Templates, for purposes of this specification (see 3.4), shall be defined as illustrations showing exact locations where the closer and arm are to be mounted on the door and the lintel, and where holes are to be drilled for fasteners. Templates may be full size or constructed to a constant scale. For closers which have possible different mountings, a template should be included for each. Templates for concealed type closers should show the exact nature of cutouts to be made in door, head, or floor, as applicable.

6.6 Finishes.

6.6.1 Selection of finishes. Where finishes other than those specified in 3.6 are required, selection of finishes, as defined in BHMA 1301 should be confined to finishes shown in Table IV.

TABLE IV. Finish standards

BHMA Code	Finish description	Base metal	Category	Nearest U.S. Equivalent
600	Primed for paint	Steel	D	USP
605	Bright brass, clear coated	Brass	A	US3
611	Bright bronze, clear coated	Bronze	A	US9
625	Bright chromium plated	Brass or Bronze	A	US26
627	Satin aluminum, clear coated	Aluminum	A	US27
628	Satin aluminum, clear anodized	Aluminum	A	US28
629	Bright stainless steel	Stainless steel 300 series	A	US32

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:45Z
Check the source to verify that this is the current version before use.

6.6.2 Standard finishes. The standard finishes for builders' hardware are intended primarily to promote reasonable uniformity in the appearance of builders' hardware items. These finishes are subject to variations in appearance, and samples are used by the manufacturer as a guide for color and texture. Samples of the following finishes are available for reference purposes: BHMA 605, BHMA 606, BHMA 612, BHMA 618, BHMA 625, BHMA 626, BHMA 627, BHMA 628, BHMA 629, and BHMA 630. These may be obtained singly, or in sets from the Builders' Hardware Manufacturers' Association, 60 East 42nd Street, New York, NY 10017.

6.6.3 Comparison of standard finishes. Owing to differences in the processes of producing hardware finishes and the variety of metals to which they are applied, it is commercially impracticable to attain an exact match. Therefore, it is understood that hardware delivered in a standard finish from two or more sources will compare reasonably when the items are viewed at arm's length and approximately 2 feet apart. This approximates the conditions of use, as for example, hinges and lock trim on opposite edges of a door.

6.7 Asterisks are not used in this revision to identify changes with respect to the previous issue, due to the extensiveness of the changes.

MILITARY CUSTODIANS:
Army - WC
Navy - YD
Air Force - 82

Review activity:
Navy - SH

User activities:
Army - ME
Navy - MC

Preparing activity:
Navy - YD

Civil Agency Coordinating Activity:
GSA - FSS
GSA - PBS
VA - DMS
NBS
HEW - FEC

Orders for this publication are to be placed with General Services Administration, acting as an agent for the Superintendent of Documents. See section 2 of this specification to obtain copies and other documents referenced herein. Price ' , cents each.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:45Z
Check the source to verify that this is the current version before use.