COMMERCIAL ITEM DESCRIPTION

HOSE, NONMETALLIC
(FIRE, SUCTION, HARD & SOFT)

The General Services Administration has authorized the use of this commercial item description.

This description covers hoses that transfer water from hydrant or draft to the pumper and shall be furnished in the following classes and sizes:

Class A - Soft
Class B - Hard
Class C - Hard, Corrugated

Size 1 - 2-1/2 inches
Size 2 - 3 inches
Size 3 - 3-1/2 inches
Size 4 - 4 inches
Size 5 - 4-1/2 inches
Size 6 - 5 inches
Size 7 - 6 inches

Salient characteristics:

Hose length. Class A - up to 50 feet, as specified
Class B - up to 20 feet, as specified
Class C - up to 20 feet, as specified

Configuration. The assembly shall consist of one male coupling, one female coupling, and one section of hose of specified length.

Hose. Class A - Synthetic, woven, double-jacketed, lined or synthetic, woven, single-jacketed, rubber covered, lined.
Class B - Outer surface is reinforced with multiple plies of fabric and a helix spring steel. Outer cover is made of rubber, lined.
Class C - Same as Class B except corrugated.

Suction coupling. One threaded male piece with expansion ring and one threaded female piece with swivel section and expansion ring shall be provided. Suction coupling in sizes 1, 2, and 3 shall be furnished with rocker lugs, sizes 4, 5, 6, and 7 shall be provided with long handles. All threads shall be of the NH series, unless otherwise specified. Material of suction couplings shall be either brass or hardcoated aluminum at the manufacturers option, unless otherwise specified. The thread size for 4-inch and larger suction hose shall be standard for the size connections specified in NFPA 1901.

Acceptance pressure test. Class A - Shall withstand a hydrostatic pressure test of 200 psi and meet specifications satisfactory to the authority having jurisdiction.
Class B and C - Will not collapse under a vacuum of 23 inches of mercury and will also withstand a hydrostatic pressure test of 200 psi.

Conformance. Hose shall meet or exceed the requirements of the National Fire Protection Association (NFPA) Standard 1961.

The issues of NFPA Standards 1901 and 1961 in effect on the date of the solicitation shall be used to determine compliance with these requirements.

FSC 4210

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:20Z
Check the source to verify that this is the current version before use.

Workmanship. Both the woven jacket and the rubber cover shall be as free from unsightly defects, dirt, knots, lumps and other irregularities as is consistent with good manufacturing practice. The waterway surface of the lining shall be free from pitting, corrugations, or other irregularities or imperfections. Hose shall be free of defects which may affect appearance or serviceability.

Regulatory requirements. The offeror/contractor is encouraged to use recovered materials to the maximum extent practicable.

Preservation, packaging, packing, labeling, and marking (Civilian). The preservation, packaging, packing, labeling, and marking shall be as specified in the contract or order.

Preservation, packaging, packing, labeling, and marking (DoD). Military packaging shall be specified when shipments are to be overseas Department of Defense (DoD) consignees. Commercial packaging may be specified for shipments to DoD consignees within the Continental United States and to non-DoD consignees worldwide. When a suppliers normal packaging will satisfy the requirements for military packaging, it may be used.

Military packaging. Each hose shall be preserved and packed to protect it against physical damage and deterioration in a logistic environment characterized by the following:

1. Multiple handling during transportation and intransit storage.
2. Shock, vibration and static loading forces during worldwide shipment by all transport modes.
3. Uncontrolled warehouse storage for extended periods.
4. Weather exposure during shipment and intransit transfers.
5. Stacking loads during shipment and storage.

Quantities of hoses destined to a single addressee may be unitized into one or more loads.

Commercial. Each hose shall be packaged in accordance with the suppliers normal method for retail distribution. Hoses shipped to a single destination may be unitized to handling as a single unit. Shipping containers shall comply with Uniform Freight Classification or National Motor Freight Classification rules.

Marking. Unit, intermediate (when provided), and exterior packs shall be marked with the item nomenclature, stock or part number, quantity per pack and contract number as a minimum; additional marking shall be as specified in the contract or order. Exterior packs shall have in addition the complete consignee's address. Markings shall be applied in a legible manner, in a contrasting color, of an appropriate size and of waterproof materials.

Notes: Users should select the options permitted by this commercial item description and should specify the following in contract or purchase documents:

1. Class and size of hose required.
2. Length of hose required.

NFPA standards are available from the National Fire Protection Association, Battery March Park, Quincy, MA 02269.

MILITARY INTERESTS:

Custodians

Army - ME
Navy - YD
Air Force - 99

Review Activities

DSA - CS
Navy - SH

User Activities

Navy - CG, MC

CIVIL AGENCY COORDINATING ACTIVITIES:

DC GOVT - DCG
HHS - FEC
USDA - AFS

PREPARING ACTIVITY:

GSA - FSS

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:20Z
Check the source to verify that this is the current version before use.