(METRIC)
A-A-694C
August 12, 1994
Superseding A-A-694B
June 22, 1983

COMMERCIAL ITEM DESCRIPTION

SODIUM CHLORIDE, TECHNICAL

The General Services Administration has authorized the use of this commercial item description, for all federal agencies.

1. SALIENT CHARACTERISTICS:

1.1 This description covers two types and three forms of crystalline sodium chloride (salt):

Type I - 97.5 percent purity
Type II - 99.5 percent purity

Form 1 - Compressed pellets
Form 2 - Large granules (Rock, Solar or Evaporated)
Form 3 - Small granules (table salt size)

1.2 Sodium chloride used for water conditioning shall be suitable for ion-exchange columns in which sodium chloride is used for regeneration.

1.3 Material. Sodium Chloride shall be homogeneous and shall be free from dirt, fibers, lint, trash or other foreign matter. Anti-caking or iodizing agents shall not be added.

1.4 Color. Sodium chloride shall be white, grayish pink, or brownish white.

Chemical Requirements	Limits	
	Type I	Type II
Moisture, percent, max.	0.5	0.5
Sodium Chloride, percent, min (dry basis)	97.5	99.5
Water-soluble Impurities (dry basis), percent, max		
Calcium & Magnesium (Ca & Mg)	0.75	0.15
Sulfate (SO_4)	1.25	0.35
Water-insoluble Impurities (dry basis), percent, max.	0.50	0.05
Soluble & Insoluble Impurities (dry basis), percent, max.	2.50	0.50
Grease, fat and oil, percent, max.	0.01	0.01
pH, (Types I and II)	(5.0 to 9.5)	

Physical Requirements Particle size analysis, cumulative percent passing review							
Sieve	19.0 mm (3/4 in)	9.5 mm (3/8 in)	6.35 mm (1/4 in)	3.35 mm No. 6	2.00 mm No. 10	1.70 mm No. 12	150 µm No. 100
Form 1	100 min	-	15 max	8 max	-	-	-
Form 2	100 min	95 min	-	-	20 max	5 max	-
Form 3	-	-	-	-	100 min	-	5 max

DISTRIBUTION STATEMENT: Approved for public release. Distribution is unlimited.

FSC 6810

Source: https://assist.dla.mil -- Downloaded: 202610-26T08:10Z
Check the source to verify that this is the current version before use.

Chemical requirements shall be tested in accordance with latest issue of AWWA B 200 for Sodium Chloride. Physical requirements shall be tested in accordance with ASTM C 136 and E 11.

1.5 Certification. The contractor shall certify that the product offered meets the salient characteristics of this description, and that the product conforms to the producer's own drawings, specifications, standards and quality assurance practices and is the same product offered for sale in the commercial marketplace. The Government reserves the right to require proof of such conformance prior to first delivery and thereafter as may be otherwise provided for under the provisions of the contract.

1.6 Packaging, Packing and Marking shall be as specified in the contract or order.

1.7 Notes:

1.71 Selection of the type sodium chloride to be used in a particular water-softening unit should be in accordance with the unit manufacturer's recommendation. Different types of salt may be interchangeable for use in a particular unit. Unit manufacturer's recommendation should be followed and their advice obtained whenever regeneration of the ion exchanger presents difficulty.

1.7.2 AWWA Standard B 200 may be obtained from the American Water Works Association, 6666 West Quincy Ave, Denver, CO 80235.

1.7.3 ASTM C 136 and ASTM E 11 may be obtained from the American Society for Testing & Materials, 1916 Race Street, Philadelphia, PA 19103

Preparing Activity

GSA - FSS

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T08:10Z
Check the source to verify that this is the current version before use.