INCH-POUND
MIL-PRF-15160/2F
AMENDMENT 2
22 March 2001

SUPERSEDING
AMENDMENT 1
26 July 2000

PERFORMANCE SPECIFICATION SHEET

FUSES, INSTRUMENT, POWER, AND TELEPHONE
(NONINDICATING), STYLE F02

This amendment forms a part of MIL-PRF-15160/2F, dated 12 October 1999, and is approved for use by all Departments and Agencies of the Department of Defense.

PAGE 6

TABLE II, delete Insulation resistance and associated number of sample fuses.

Short circuit test paragraph, delete in its entirety and substitute:

"Short circuit test: The number of group III samples for qualification and qualification retention (group C) testing shall consist of 4 sample fuses of each of the types and of the current ratings as shown in table IV. Short circuit interrupt tests shall be conducted at the ac voltage indicated, and the fuses shall withstand a minimum short circuit current as shown in table IV."

PAGE 8

TABLE IV, delete title and substitute: "TABLE V. Cross reference."

PAGE 9

TABLE IV, delete title and substitute: "TABLE V. Cross reference - Continued."

Custodians:
Army - CR
Navy - SH
Air Force - 11
DLA - CC

Review activities:
Army - AR, AT, CR4, MI
Navy - AS, CG, MC, OS
Air Force - 19, 99

Preparing activity:
DLA - CC

(Project 5920-0708)

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T05:39Z
Check the source to verify that this is the current version before use.