: INCH-POUND :

MIL-F-51525A(EA)
AMENDMENT 4
14 March 1990
SUPERSEDING
AMENDMENT 3
13 November 1989

MILITARY SPECIFICATION

FILTER, GAS, 200 CFM

This amendment forms a part of MIL-F-51525A(EA), dated 3 February 1988, and is approved for use within the U.S. Army Chemical Research, Development and Engineering Center, Department of the Army, and is available for use by all Departments and Agencies of the Department of Defense.

PAGE 3

3.3.2: Change "Airstream-relative humidity (RH)" from "less than or equal to 30 percent" to "less than or equal to 50 percent".

PAGE 4

3.3.3: Change filter preheat test parameter requirement from "110° ± 5°F" to "120 ± 10°F".

PAGE 6

4.3.3.2(c): Delete (c) in its entirety and subsitute "(c) CK gas-life. CK gas-life shall be performed in accordance with 4.4.4.5. Any failure of a sample constitutes failure of the preproduction lot."

PAGE 7

4.3.3.3.1: Add the following sentence to the end of the paragraph: "The preproduction lot of filters shall be rejected if any filter fails to meet the requirements of 3.3.3."

AMSC N/A

FSC 4240

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:03Z
Check the source to verify that this is the current version before use.

4.4.4.1: Add the following sentence to the end of the paragraph: "Purge the filter by passing fresh air in the reverse direction through the filter at its rated airflow for 1 minute."

4.4.4.3(a) - (i): Delete subparagraphs in their entirety and substitute the following:

"(a) Preheat sample filter to 120 ± 10°F for a minimum of 30 minutes.
(b) While in the bypass mode adjust the controls until rated airflow is reached and the temperature is 110 ± 5°F. Generate DMMP vapor until the influent concentration detection (see 6.6) indicates 5.0 ± 0.01 milligrams DMMP per liter air.
(c) Insert preheated sampled filter using the applicable test fixture if necessary.
(d) Switch to test mode and start timer. Make final adjustments to airflow, temperature, and DMMP concentration.
(e) Stop the test and record when the effluent concentration detector indicates that the break concentration has been reached. Record the airflow resistance (iwg) of the filter."

Custodian:

Army - EA

Preparing activity:

Army - EA

Project No. 4240-A996

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:03Z
Check the source to verify that this is the current version before use.