INCH-POUND
MIL-PRF-15160/40A
AMENDMENT 1
16 July 2001

PERFORMANCE SPECIFICATION SHEET

FUSES, STYLE F40

This amendment forms a part of MIL-PRF-15160/40A, dated 16 February 1998 and is approved for use by all Departments and Agencies of the Department of Defense.

PAGE 3

VERIFICATION, delete in its entirety and substitute:

"VERIFICATION:

Qualification inspection is not applicable for characteristic B fuses of this specification sheet and is replaced by first article inspection which shall consist of Group A and Group B inspection of MIL-PRF-15160.

Qualification inspection (Characteristic A only): The number of qualification samples required shall be:

a. 24 samples maximum current rating of each voltage and design.

b. 24 samples minimum current rating of each voltage and design."

Custodians:
Army - CR
Navy - SH
Air Force - 11
DLA - CC

Review activities:
Air Force - 99

Preparing activity:
DLA - CC

(Project 5920-0740)

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T05:46Z
Check the source to verify that this is the current version before use.