J-C-103b
AMENDMENT—2
FEBRUARY 16, 1961

SUPERSEDING
Int. Amend.—1
October 6, 1960

FEDERAL SPECIFICATION

CABLE, POWER, ELECTRICAL, (RUBBER-INSULATED, BUILDING-TYPE) AND WIRE, ELECTRICAL, (RUBBER-INSULATED, BUILDING-TYPE)

This amendment which forms a part of Federal Specification J-C-103b, dated May 2, 1960, was approved by the Commissioner, Federal Supply Service, General Services Administration, for the use of all Federal agencies.

Page 6, paragraph 4.4.1, delete entire paragraph and substitute:

4.4.1 *Nonmilitary.*—The label of Underwriters' Laboratories, Inc., (see 3.3.1), may be accepted by the purchaser as proof that the wire and cable delivered conform to the requirements of this specification. If further testing is desired, it shall be so stated in the invitation for bids and the material shall be tested in accordance with 4.4.3 through 4.4.7.3, as described in the referenced methods of Federal Specification J-C-98.

Page 10, paragraph 6.1, add:

(*d*) Tests nonmilitary. (See paragraph 4.4.1.)

MILITARY INTERESTS:
Army—O Sig E
Navy—Y S MC
Air Force.

Source: https://assist.dla.mil -- Downloaded: 202640-26T11:07Z
Check the source to verify that this is the current version before use.