This cancellation notice is being reissued March 16, 1987 to provide corrected supersession data. Please replace any previous copies with this updated notification.

FEDERAL SPECIFICATION SHEET

FUSE, CARTRIDGE, HIGH INTERRUPTING CAPACITY,
CLASS K9 (NONCURRENT-LIMITING) 250 VOLTS, 61-100 AMPERES

(DETAIL SPECIFICATION)

This cancellation was approved by the Assistant Administrator, Office of Federal Supply and Services, General Services Administration, for the use of all Federal agencies.

Federal Specification Sheet W-F-1814/13, dated May 23, 1974, has been superseded by W-F-1814/58, Fuses, Cartridge, High-Interrupting Capacity, Classes RK1 and RK5 (Current-Limiting) 250 Volts, 61-100 Amperes, dated October 21, 1982.

TABLE I. Current rating and part number designation.

Government part number	Current rating (amperes)	Superseded by WF1814/58- RK5	
		Instantaneous	Time delay
WF1814/13-001	70	F5070	
-002	80	F5080	
-003	90	F5090	
-004	100	F5100	
-005	70		D5070
-006	80		D5080
-007	90		D5090
-008	100		D5100

PREPARING ACTIVITY:

DLA - ES

(Project 5920-0433-3)

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.
Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:36Z
Check the source to verify that this is the current version before use.