This cancellation notice is being re-issued March 16, 1987 to provide corrected supersession data. Please replace any previous copies with this updated notification.

FEDERAL SPECIFICATION SHEET

FUSE, CARTRIDGE, HIGH INTERRUPTING CAPACITY,
CLASS K9 (NONCURRENT-LIMITING) 600 VOLTS, 0-30 AMPERES

(DETAIL SPECIFICATION)

This cancellation was approved by the Assistant Administrator, Office of Federal Supply and Services, General Services Administration, for the use of all Federal agencies.

Federal Specification Sheet W-F-1814/17, dated May 23, 1974, has been superseded by W-F-1814/62, Fuses, Cartridge, High-Interrupting Capacity, Classes RK1 and RK5 (Current-Limiting) 600 Volts, 0-30 Amperes, dated October 21, 1982.

TABLE I. Current rating and part number designation.

Government part number	Current rating (amperes)	Superseded by WF1814/62- RK5 Instantaneous	Superseded by WF1814/62- RK5 Time delay
WF1814/17-001	1	F501	
-002	3	F503	
-003	6	F506	
-004	10	F510	
-005	15	F515	
-006	20	F520	
-007	25	F525	
-008	30	F530	
-009	1		D501
-010	3		D503
-011	6		D506
-012	10		D510
-013	15		D515
-014	20		D520
-015	25		D525
-016	30		D530

PREPARING ACTIVITY:

DLA - ES

(Project 5920-0433-7)

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.
Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:36Z
Check the source to verify that this is the current version before use.