This cancellation notice is being re-issued March 16, 1987 to provide corrected supersession data. Please replace any previous copies with this updated notification.

FEDERAL SPECIFICATION SHEET

FUSE, CARTRIDGE, HIGH INTERRUPTING CAPACITY,
CLASS K9 (NONCURRENT-LIMITING) 600 VOLTS, 31-60 AMPERES

(DETAIL SPECIFICATION)

This cancellation was approved by the Assistant Administrator, Office of Federal Supply and Services, General Services Administration, for the use of all Federal agencies.

Federal Specification Sheet W-F-1814/18, dated May 23, 1974, has been superseded by W-F-1814/63, Fuses, Cartridge, High-Interrupting Capacity, Classes RK1 and RK5 (Current-Limiting) 600 Volts, 31-60 Amperes, dated October 21, 1982.

TABLE I. Current rating and part number designation.

Government part number	Current rating (amperes)	Superseded by WF1814/63-	
		RK5	
		Instantaneous	Time delay
WF1814/18-001	35	F535	
-002	40	F540	
-003	45	F545	
-004	50	F550	
-005	60	F560	
-006	35		D535
-007	40		D540
-008	45		D545
-009	50		D550
-010	60		D560

PREPARING ACTIVITY:

DLA - ES

(Project 5920-0433-8)

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil/ - Downloaded: 2026-10-26T11:36Z
Check the source to verify that this is the current version before use.