This cancellation notice is being re-issued March 16, 1987 to provide corrected supersession data. Please replace any previous copies with this updated notification.

FEDERAL SPECIFICATION SHEET

FUSE, CARTRIDGE, HIGH INTERRUPTING CAPACITY,
CLASS K9 (NONCURRENT-LIMITING) 600 VOLTS, 101-200 AMPERES

(DETAIL SPECIFICATION)

This cancellation was approved by the Assistant Administrator, Office of Federal Supply and Services, General Services Administration, for the use of all Federal agencies.

Federal Specification Sheet W-F-1814/20, dated May 23, 1974, has been superseded by W-F-1814/65, Fuses, Cartridge, High-Interrupting Capacity, Classes RK1 and RK5 (Current-Limiting) 600 Volts, 101-200 Amperes, dated October 21, 1982.

TABLE I. Current rating and part number designation.

Government part number	Current rating (amperes)	Superseded by WF1814/65-	
		RK5	
		Instantaneous	Time delay
WF1814/20-001	110	F5110	
-002	125	F5125	
-003	150	F5150	
-004	175	F5175	
-005	200	F5200	
-006	110		D5110
-007	125		D5125
-008	150		D5150
-009	175		D5175
-010	200		D5200

PREPARING ACTIVITY:

DLA - ES

(Project 5920-0433-10)

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:36Z
Check the source to verify that this is the current version before use.
DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.