This cancellation notice is being re-issued March 16, 1987 to provide corrected supersession data. Please replace any previous copies with this updated notification.

FEDERAL SPECIFICATION SHEET

FUSE, CARTRIDGE, HIGH INTERRUPTING CAPACITY,
CLASS K5 (NONCURRENT-LIMITING) 600 VOLTS, 31-60 AMPERES

(DETAIL SPECIFICATION)

This cancellation was approved by the Assistant Administrator, Office of Federal Supply and Services, General Services Administration, for the use of all Federal agencies.

Federal Specification Sheet W-F-1814/30, dated May 23, 1974, has been superseded by W-F-1814/63, Fuses, Cartridge, High-Interrupting Capacity, Classes RK1 and RK5 (Current-Limiting) 600 Volts, 31-60 Amperes, dated October 21, 1982.

TABLE I. Current rating and part number designation.

Government part number	Current rating (amperes)	Superseded by WF1814/63- RK5 Time delay
WF1814/30-001	35	D535
-002	40	D540
-003	45	D545
-004	50	D550
-005	60	D560

PREPARING ACTIVITY:

DLA - ES

(Project 5920-0433-20)

AMSC N/A FSC 5920

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:36Z
Check the source to verify that this is the current version before use.