This cancellation notice is being reissued March 16, 1987 to provide corrected supersession data. Please replace any previous copies with this updated notification.

W-F-1814/41
CANCELLATION
15 July 1985

FEDERAL SPECIFICATION SHEET

FUSE, CARTRIDGE, HIGH INTERRUPTING CAPACITY,
CLASS K1 (NONCURRENT-LIMITING) 600 VOLTS, 0-30 AMPERES

(DETAIL SPECIFICATION)

This cancellation was approved by the Assistant Administrator, Office of Federal Supply and Services, General Services Administration, for the use of all Federal agencies.

Federal Specification Sheet W-F-1814/41, dated May 23, 1974, has been superseded by W-F-1814/62, Fuses, Cartridge, High-Interrupting Capacity, Classes RK1 and RK5 (Current-Limiting) 600 Volts, 0-30 Amperes, dated October 21, 1982.

TABLE I. Current rating and part number designation.

Government part number	Current rating (amperes)	Superseded by WF1814/62-	
		RK1	
		Instantaneous	Time delay
WF1814/41-001	1	F101	
-002	3	F103	
-003	6	F106	
-004	10	F110	
-005	15	F115	
-006	20	F120	
-007	25	F125	
-008	30	F130	
-009	1		D101
-010	3		D103
-011	6		D106
-012	10		D110
-013	15		D115
-014	20		D120
-015	25		D125
-016	30		D130

PREPARING ACTIVITY:

DLA - ES

(Project 5920-0433-31)

AMSC N/A

FSC 5920

DISTRIBUTION STATEMENT A. Approved for public release; distribution is unlimited.

Source: https://assist.dla.mil -- Downloaded: 2026-10-26T11:36Z
Check the source to verify that this is the current version before use.